



Adaptive Fuzzy PID Control for a Class of Uncertain MIMO Nonlinear Systems with Dead-zone Inputs' Nonlinearities

Nidhal Cherrat¹ · Hamid Boubertakh¹ · Hichem Arioui²

Received: 6 March 2017 / Accepted: 9 November 2017 / Published online: 5 February 2018
© Shiraz University 2018

Abstract

This paper proposes an adaptive fuzzy PID control for a class of multi-input multi-output disturbed nonlinear systems with unknown dynamics and unknown dead-zone inputs' nonlinearities. Within this scheme, a fuzzy system is used in order to approximate the PID gains instantaneously according to whole control system objective. Specifically, a gradient descent algorithm is used to update online the fuzzy system parameters such that the error between the fuzzy PID control and the unknown ideal control converges to an adjustable region. The control design and the stability analysis of the closed-loop system are given by the Lyapunov approach. The effectiveness of the proposed controller is highlighted by simulated examples .

Keywords PID control · Fuzzy systems · Adaptive fuzzy control · MIMO nonlinear systems · Gradient descent algorithm · Lyapunov stability

1 Introduction

The control problem of uncertain complex nonlinear systems is one of the biggest challenges of the control engineering. Fortunately, the advanced control system theory has gained a huge progress in the past decades to deal with this issue as testify the big number of publications, where some recent literature can be found in (Seo et al. 2007; Jovanovic 2002; Feki 2003; Hua et al. 2005; Nejati et al. 2012; Kaddissi et al. 2005; Majd and Mobayen 2015; Mobayen 2015a, b, c, d; Mobayen and Tchier 2016; Poursafar et al. 2010; Ghaffari et al. 2013; Akhtar and Bernstein 2005; Babaei and Salamci 2014; Gomez-Ortega et al. 2001; Bernard and Kuntze 1999; Ge et al. 2001;

Poursamad and Markazi 2009; Khazaei et al. 2017; Fu et al. 2016; Cui et al. 2017). Effectively, depending on the system complexity, many techniques have been proposed; feedback linearization control (Seo et al. 2007; Jovanovic 2002), adaptive feedback control (Feki 2003; Hua et al. 2005), backstepping control (Nejati et al. 2012; Kaddissi et al. 2005), sliding mode control (SMC) (Majd and Mobayen 2015; Mobayen 2015a, b; Mobayen and Tchier 2016), model predictive control (Poursafar et al. 2010; Ghaffari et al. 2013), composite nonlinear feedback control (CNF) (Mobayen 2015c, d), model reference adaptive control (Akhtar and Bernstein 2005; Babaei and Salamci 2014), intelligent control (Gomez-Ortega et al. 2001; Bernard and Kuntze 1999) and adaptive controls based on the universal approximators (fuzzy systems and neural networks) (Ge et al. 2001; Poursamad and Markazi 2009; Khazaei et al. 2017; Fu et al. 2016; Cui et al. 2017).

Despite the enormous progress of the control theory, the classical proportional integral derivative (PID) control remains the most commonly control technique in the industry (Astrom et al. 1995). This popularity is attributed to the controller's simple and universal structure familiar to operators, its effectiveness in a wide range of operation conditions, its low cost and ease of implementation.

✉ Nidhal Cherrat
cherratnidhal@yahoo.fr

Hamid Boubertakh
boubert_hamid@yahoo.com

Hichem Arioui
hichem.arioui@ibisc.fr

¹ Laboratoire d'Automatique de Jijel-LAJ, University MSBY of Jijel, Jijel, Algeria

² IBISC-Lab, EA2456, University of Evry Val d'Essonne, Evry, France

In order for a PID controller to work well it needs to be adequately tuned, such as the closed loop system behaves in specified desired way quickly and precisely. Many techniques have been proposed in literature to this end. Some traditional methods have been used for many decades ago. In empirical methods like Ziegler–Nichols (Astrom et al. 1995; Ziegler and Nichols 1942), the parameters are calculated based on the system step response experiment and predefined tables. In frequency domain design methods (Astrom et al. 1995), given a model of the system to control, the controller's parameters are calculated analytically or by using frequency plotting in order to meet a set of frequency specifications such as phase margin and gain margin for good stability robustness. Time-domain design methods (Astrom et al. 1995; Zhang et al. 2002) are to satisfy the requirement of some temporal performance indices such as the integral squared error (ISE) or the integral time absolute error (ITAE), etc.

To enhance the capabilities of classical PID parameter tuning techniques, several intelligent approaches have been proposed in recent literature (Lu et al. 2010; Srikanth and Chandra 2012; Andromeda et al. 2012; Chiou et al. 2012; Ercin and Coban 2011; Ma 2009; Hanifah et al. 2013; Knoop and Pérez 1994). Genetic algorithms (GA) (Lu et al. 2010; Srikanth and Chandra 2012), particle swarm optimization (PSO) (Andromeda et al. 2012; Chiou et al. 2012), bees algorithm (BA) (Ercin and Coban 2011), and ant colony optimization (ACO) (Ma 2009; Hanifah et al. 2013).

The role of the entire above mentioned methods is to find fixed values of the PID controller parameters which will be kept unchanged when the control system is operating while satisfying a set of specifications. Unfortunately, such designed controllers cannot give good performances when the system under control operates on multiple set-points, its dynamics is unknown, or exhibit changing parameters.

In order to cope with these classes of systems, it is highly suitable to increase the capabilities of PID controllers by adding new features. Some approaches have been proposed in literature. The gain scheduling techniques (Knoop and Pérez 1994; Yesil et al. 2004) are used when the system exhibits distinct operating ranges. An appropriate mechanism is used such as the controller switch between a set of controller parameter values. The fuzzy supervisors (Soyguder et al. 2009; Babulu and Kumar 2012; Lai et al. 2016; Juang et al. 2008) are used to adjust the PID controller parameters according to the error between the setpoint and the controlled signal by means of a set of linguistic rules and a fuzzy logic inference system.

To further extend the PID control performance for unknown systems or systems that the dynamics change over time, additional PID control that involves parameters online adjustments are needed, which is adaptive PID

control (Huang et al. 2002; Mizumoto et al. 2009; Yu 2006; Kumar et al. 2016; Al-zohairy and Salem 2016a, b; Yu et al. 2007; Guo et al. 2009; Der Chang et al. 2003; Eslami et al. 2006; Tamura and Ohmori 2006, 2007; Shen et al. 2014; Boubakir et al. 2011). The case of adaptive PID control for MIMO systems has been studied in (Yu et al. 2007; Guo et al. 2009; Al-zohairy and Salem 2016b; Der Chang et al. 2003; Eslami et al. 2006; Tamura and Ohmori 2006, 2007; Shen et al. 2014; Boubakir et al. 2011). In (Yu et al. 2007; Guo et al. 2009), the authors have used indirect scheme. First, a neural network (NN) is used to approximate the plant dynamics, where the learning task is carried out by the Extended Kalman Filter (EKF). Then, the PID control parameters' adaptation is done using the Lyapunov design method such as to minimize the squared tracking error. The disadvantage of this approach is the complexity of the NN adaptation using the EKF. In (Al Zohairy and Salem 2016b; Der Chang et al. 2003; Eslami et al. 2006), the authors have proposed a direct adaptation approach of the PID controller parameters by using a NN whose parameters are adjusted by the gradient descent-based algorithm. The absence of the stability demonstration and the non guarantee of the closed-loop variables boundedness make these results questionable. In (Tamura and Ohmori 2006, 2007), the authors propose a MIMO PID adaptive control law for a class of linear system under certain restrictive assumptions. The adaptation law is derived using the Lyapunov's stability theorem.

In (Shen et al. 2014; Boubakir et al. 2011), the authors propose a self-tuning PID controller for a class of nonlinear MIMO systems, in which the PID controller parameters are adjusted online by using the gradient decent method.

The present work aims to improve the adaptive PID controller in (Shen et al. 2014; Boubakir et al. 2011) by the introduction of a fuzzy system to estimate the PID control gains to deal with a class of disturbed MIMO nonlinear systems with unknown dynamics and dead-zone input nonlinearities.

The main advantage of the proposed approach over the existing fuzzy adaptive control techniques in literature (Poursamad and Markazi 2009; Khazaei et al. 2017; Fu et al. 2016; Cui et al. 2017) with the present problem is that the proposed control scheme in this paper combines the advantages of the classical PID control and the advanced adaptive control, namely the simple universal structure familiar to industrial operators of the former and the good performance with complex systems of the latter.

The main contributions of this work are as follows: (i) According to the universal approximation theorem discussed by Wang (1994), using the fuzzy system in this paper guarantees that the approximation error is of the order of the modeling error. In fact, the introduction of this fuzzy system in this paper allows canceling the restrictive assumptions about the approximation error in (Shen et al.

2014; Boubakir et al. 2011). (ii) In order to overcome these drawbacks related to the use of σ -modification in the adaptive law (Shen et al. 2014; Boubakir et al. 2011), in the present work we have introduced the e -modification concept. (iii) The proposed control scheme deal with a large class of MIMO systems; disturbed and unknown dynamics and dead-zone type input nonlinearities. (iv) A comparative study is carried out between the proposed approach with σ -modification adaptation law, the proposed approach with e -modification adaptation law and the adaptive fuzzy control law developed in (Cui et al. 2017).

The paper is organized as follows: Section 2 presents the problem formulation; the class of the MIMO systems under study is presented and the control objective is defined. In Sect. 3 the proposed fuzzy PID control scheme is presented; the adaptation law is given and stability of the whole system is analyzed. Section 4 shows simulation results with two systems; a two-link manipulated robot and a quadrotor. Section 5 concludes the paper.

2 Problem formulation and ideal control law

2.1 Problem formulation

Consider the class of uncertain nonlinear MIMO systems represented by the following differential equations:

$$\begin{aligned} y_1^{(r_1)} &= f_1(x) + \sum_{j=1}^p g_{1j}(x)N_j(u_j) + \delta_1(t) \\ &\vdots \\ y_p^{(r_p)} &= f_p(x) + \sum_{j=1}^p g_{pj}(x)N_j(u_j) + \delta_p(t) \end{aligned} \tag{1}$$

where $x = [y_1, \dot{y}_1, \dots, y_1^{(r_1-1)}, \dots, y_p, \dot{y}_p, \dots, y_p^{(r_p-1)}]^T$ is the overall state vector, which is assumed available for measurement. $u = [u_1, \dots, u_p]$ is the control input vector, $y = [y_1, \dots, y_p]$ is the output vector. $f_i(x), g_{ij}(x), (i, j = 1, \dots, p)$ are unknown nonlinear functions. $N(u) = [N_1(u_1), \dots, N_p(u_p)]$ is the dead-zone type inputs' nonlinearities vector which is considered unknown. $\delta = [\delta_1(t), \delta_2(t), \dots, \delta_p(t)]$ is the vector of bounded disturbances; we suppose here $|\delta_i(t)| \leq \delta_i^*$, where δ_i^* is a positive constant ($i = 1, \dots, p$).

We can write the system (1) in a compact form as

$$y^{(r)} = f(x) + G(x)N(u) + \delta, \tag{2}$$

where $y^{(r)} = [y_1^{(r_1)} \dots y_p^{(r_p)}]^T$, $f(x) = [f_1(x) \dots f_p(x)]^T$,

$$G(x) = \begin{bmatrix} g_{11}(x) & \dots & g_{1p}(x) \\ \vdots & \ddots & \vdots \\ g_{p1}(x) & \dots & g_{pp}(x) \end{bmatrix}.$$

The objective is to design the control law $u(t)$ to force the output y tracking of a specified desired trajectory y_d , with ensuring the boundedness of all variables in the closed-loop system.

Throughout this paper we make the following assumptions:

2.2 Assumption 1

Suppose that the matrix $G(x)$ is symmetric strictly positive and it is limited by two positive constants g_0 and g_1 as $0 < g_0 I_p \leq G(x) < g_1 I_p$, where I_p is the $p \times p$ identity matrix.

2.3 Assumption 2

Each desired trajectory y_{di} ($i = 1, 2, \dots, p$) is a known bounded function of time with bounded known derivatives, and y_{di} is supposed r_i -times differentiable.

Let us define the tracking errors as

$$\begin{aligned} e_1(t) &= y_{d1}(t) - y_1(t) \\ &\vdots \\ e_p(t) &= y_{dp}(t) - y_p(t) \end{aligned} \tag{3}$$

and the filtered tracking errors as

$$\begin{aligned} s_1(t) &= \left(\frac{d}{dt} + \lambda_1 \right)^{r_1-1} e_1(t), \lambda_1 > 0 \\ &\vdots \\ s_p(t) &= \left(\frac{d}{dt} + \lambda_p \right)^{r_p-1} e_p(t), \lambda_p > 0. \end{aligned} \tag{4}$$

Since the equality $s_i(t) = 0$ means that the tracking error $e_i(t)$ and all its derivatives decrease exponentially to zero (Slotine and Li 1991), it is sufficient to design a control law that ensures $s_i(t) \rightarrow 0, i = 1, \dots, p$.

The time derivative of the filtered tracking errors can be written as follows:

$$\begin{aligned} \dot{s}_1 &= v_1 - f_1(x) - \sum_{j=1}^p g_{1j}(x)N_j(u_j) - \delta_1(t) \\ &\vdots \\ \dot{s}_p &= v_p - f_p(x) - \sum_{j=1}^p g_{pj}(x)N_j(u_j) - \delta_p(t) \end{aligned} \tag{5}$$

where

$$\begin{aligned} v_1 &= y_{d1}^{(r_1)} + \beta_{1,r_1-1} e_1^{(r_1-1)} + \dots + \beta_{1,1} \dot{e}_1 \\ &\vdots \\ v_p &= y_{dp}^{(r_p)} + \beta_{p,r_p-1} e_p^{(r_p-1)} + \dots + \beta_{p,1} \dot{e}_p \end{aligned} \tag{6}$$

with $\beta_{i,j} = \frac{(r_i-1)!}{(r_i-j)!(j-1)!} \lambda_i^{r_i-j}, i = 1, \dots, p, j = 1, \dots, r_i - 1$.

Let us denote

$$s = [s_1 \dots s_p]^T, v = [v_1 \dots v_p]^T.$$

By substituting in Eq. (6) we find

$$\dot{s} = v - f(x) - G(x)N(u) - \delta(t). \tag{7}$$

2.4 Actuator nonlinearities

The output of the each dead-zone nonlinearity can be expressed as follows (Wang et al. 2004; Su et al. 2003):

$$N_i(u_i) = a_i u_i + b_i(t), \text{ for } i = 1, 2, \dots, p, \tag{8}$$

where a_i is a positive constant gain, and $b_i(t)$ is a nonlinear function bounded by a positive constant b_i^* ($|b_i(t)| \leq b_i^*$).

Now, we denote

$$b(t) = [b_1(t), b_2(t), \dots, b_p(t)],$$

$$b^* = [b_1^*, b_2^*, \dots, b_p^*],$$

$$A = \text{diag}[a_{11}, a_{22}, \dots, a_{pp}].$$

From this notation the actuator nonlinearity vector $N(u)$ can be written as

$$N(u) = Au + b(t), \tag{9}$$

where the diagonal matrix A is positively defined.

We note that $b(t)$ is treated here as bounded disturbances.

2.5 Ideal control law

By using (9) the dynamic of the system can be rewritten as

$$\dot{s} = v - f(x) - G(x)Au - G(x)b(t) - \delta(t) \tag{10}$$

If the nonlinear functions $f(x)$ and $G(x)$ are known and the tow bounded function $b(t)$ and $\delta(t)$ exist and also known, the following nonlinear ideal control law u^*

$$u^* = (G_A(x))^{-1} \left(-f(x) + v + ks + k_0 \tanh\left(\frac{s}{\varepsilon_0}\right) - d(x, t) \right) \tag{11}$$

can achieve the control goal, where $G_A(x) = G(x)A$, $d(x, t) = G(x)b(t) + \delta(t)$, $k = \text{diag}[k_1, \dots, k_p]$, $k_0 = \text{diag}[k_{01}, \dots, k_{0p}]$ and $\tanh\left(\frac{s}{\varepsilon_0}\right) = \left[\tanh\left(\frac{s_1}{\varepsilon_0}\right), \dots, \tanh\left(\frac{s_p}{\varepsilon_0}\right)\right]^T$ with k_i and k_{0i} are positive constants and ε_0 is a small positive constant.

To analyze the closed loop stability dynamics, we apply the ideal control law (11) to (10) where we obtain

$$\dot{s} = -ks - k_0 \tanh\left(\frac{s}{\varepsilon_0}\right). \tag{12}$$

From the Eq. (12), one can conclude that $s_i \rightarrow 0$ ($i = 1, 2, \dots, p$) when $t \rightarrow \infty$; this implies that e_i ($i = 1, 2, \dots, p$) and all its derivatives up to $r_i - 1$ converge to zero in finite time.

But unfortunately, the ideal control (11) is not feasible because the nonlinear functions $d(x, t)$, $f(x)$ and $G(x)$ are supposed unknown.

In order to overcome this problem, in this work one propose to approximate the ideal control (11) by a decentralized universal PID control law, where the control gains are adjusted online by mean of a fuzzy system.

3 Adaptive fuzzy PID control scheme

3.1 Control law

As we have up mentioned, when $f(x)$, $G(x)$ and $d(x, t)$ are unknown, we assume that each element of the ideal control vector $u^* = [u_1^*, \dots, u_p^*]$ can be approximated by a fuzzy PID controller given by

$$u_i = u_{PID_i} = K_{Pi}e_i(t) + K_{Ii} \int_0^t e_i(\tau)d\tau + K_{Di} \frac{de_i(t)}{dt}, \quad i = 1, 2, \dots, p. \tag{13}$$

where K_{Pi} is proportional gain, K_{Ii} is integral gain and K_{Di} is derivative gain. $e_i(t) = y_{di} - y_i$ is the tracking error, $\frac{de_i(t)}{dt}$ is the differential tracking error and $\int_0^t e_i(\tau)d\tau$ is the integral tracking error.

These control inputs can also be written in a compact form as follows:

$$u_{PID_i} = E_i^T K_{PID_i}, \tag{14}$$

where $E_i = [e_{i1}, e_{i2}, e_{i3}]^T = [e_i, \int_0^t e_i(\tau)d\tau, \frac{de_i}{dt}]^T$ and $K_{PID_i} = [K_{Pi}, K_{Ii}, K_{Di}]^T$. Or, equivalently

$$u_{PID} = E^T K_{PID}, \tag{15}$$

where $u_{PID} = [u_{PID_1}, u_{PID_2}, \dots, u_{PID_p}]^T$, $E^T = \text{diag}[E_1^T, E_2^T, \dots, E_p^T]$ and $K_{PID} = [K_{PID_1}, K_{PID_2}, \dots, K_{PID_p}]$.

Each gains vector K_{PID_i} of the PID control u_{PID_i} is identified by a zero order Takagi–Sugeno (TS) fuzzy system. The fuzzy system inputs are the tracking error $e_{i1} = e_i$, the integral error $e_{i2} = \int_0^t e_i(\tau)d\tau$ and the derivative error $e_{i3} = \frac{de_i(t)}{dt}$, and the output is the gains' vector K_{PID_i} . We define M_k fuzzy sets F_{ij}^k , for each input e_{ij} ($i = 1, 2, \dots, p, j = 1, 2, 3, k = 1, \dots, M_{ij}$). The fuzzy

system rule base is constructed by the collection of the IF-THEN rules R_i^l of the form

$$R_i^l: \text{IF } e_{i1} \text{ is } G_{i1}^l \text{ and } e_{i2} \text{ is } G_{i2}^l \text{ and } e_{i3} \text{ is } G_{i3}^l \\ \text{THEN } K_{Pi} \text{ is } c_{Pi}^l \text{ and } K_{Ii} \text{ is } c_{Ii}^l \text{ and } K_{Di} \text{ is } c_{Di}^l,$$

is c_{Di}^l ,

where $G_{ij}^l \in \{F_{ij}^1, \dots, F_{ij}^{M_{ij}}\}$, $l = 1, \dots, N$. c_{Pi}^l, c_{Ii}^l and c_{Di}^l are the crisp outputs of the l -th rule.

By using the algebraic product implication and the average sum inference method, the fuzzy system outputs, namely the PID control parameters are calculated by

$$K_{Pi} = \frac{\sum_{l=1}^N \mu_i^l c_{Pi}^l}{\sum_{l=1}^N \mu_i^l} \\ K_{Ii} = \frac{\sum_{l=1}^N \mu_i^l c_{Ii}^l}{\sum_{l=1}^N \mu_i^l} \\ K_{Di} = \frac{\sum_{l=1}^N \mu_i^l c_{Di}^l}{\sum_{l=1}^N \mu_i^l}, \tag{16}$$

where $\mu_i^l = \prod_{j=1}^3 \mu_{G_{ij}^l}(e_{ij})$, $\mu_{G_{ij}^l} \in \{\mu_{F_{ij}^1}, \dots, \mu_{F_{ij}^{M_{ij}}}\}$ and $\mu_{F_{ij}^k}(\cdot)$ is the membership function of the fuzzy set F_{ij}^k .

By using the following notation

$$w_i^l = \frac{\mu_i^l}{\sum_{l=1}^N \mu_i^l}, l = 1, 2, \dots, N$$

$$w_i = [w_i^1, \dots, w_i^N]^T; c_{Pi} = [c_{Pi}^1, \dots, c_{Pi}^N]^T; c_{Ii} = [c_{Ii}^1, \dots, c_{Ii}^N]^T; c_{Di} = [c_{Di}^1, \dots, c_{Di}^N]^T.$$

The fuzzy system (16) can be written in the following matrix form:

$$\begin{cases} K_{Pi} = w_i^T c_{Pi} \\ K_{Ii} = w_i^T c_{Ii} \\ K_{Di} = w_i^T c_{Di} \end{cases} \tag{17}$$

Or equivalently

$$K_{PIDi} = \begin{bmatrix} K_{Pi} \\ K_{Ii} \\ K_{Di} \end{bmatrix} = W_i^T c_i, \tag{18}$$

where $c_i = [c_{Pi} \ c_{Ii} \ c_{Di}]^T$, and $W_i = \text{diag}[w_i, w_i, w_i]$.

In this paper, the proposed method assumes that the structure of the TS fuzzy system is specified in advance by the user. The user needs to specify the universe of discourse of each input variable, the number and type of membership functions for each input variable. However, the parameter vector c_i of the conclusion part of TS fuzzy system should be calculated online by an adaptation law in order to meet the desired specifications.

By replacing the gains vector (18) in the PID controller (14) we get

$$u_{PIDi} = E_i^T W_i^T c_i, \tag{19}$$

which we call fuzzy PID controller.

Let us now denote $u_{PID} = [u_{PID_1}, u_{PID_2}, \dots, u_{PID_p}]$, $E^T = \text{diag}[E_1^T, \dots, E_p^T]$, $W = \text{diag}[W_1^T, \dots, W_p^T]$ and $c = [c_1, \dots, c_p]^T$ is the matrix of the adjustable parameters.

Thus, the final MIMO PID control law that is applied to the system (1) is

$$u = u_{PID} = E^T Wc \tag{20}$$

Unlike (Shen et al. 2014; Boubakir et al. 2011), in this work, based on the universal approximation property of fuzzy systems (Su et al. 2003), the MIMO fuzzy PID control u is able to approximate the unknown ideal control u^* , with a certain approximation error ε limited by a positive constant ε_0 ($|\varepsilon| < \varepsilon_0$); therefore, the restrictive assumption about this error in (Shen et al. 2014; Boubakir et al. 2011) is removed.

Therefore, the unknown ideal control u^* can be written as

$$u^* = E^T Wc^* + \varepsilon, \tag{21}$$

where $\varepsilon = [\varepsilon_1, \dots, \varepsilon_p]^T$ is the approximation error and $c^* = [c_1^*, \dots, c_p^*]^T$ is the unknown optimal values of c .

3.2 Adaptive law of the fuzzy PID control

Recall that the goal is to approximate the unknown ideal control (21) to achieve the control system desired performance. To this end, the fuzzy PID control (20) is used to estimate this ideal control, where consequent parameters vector c of the fuzzy system is estimated online using an adaptation law. In this work, the gradient descent method is used; this method allows generating the vector c by decreasing the error between the unknown ideal control (21) and the fuzzy PID control (20), which is defined as follows:

$$e_u = u^* - u \tag{22}$$

Using (20) and (21), (22) becomes

$$e_u = u^* - E^T Wc = E^T W\tilde{c} + \varepsilon, \tag{23}$$

where $\tilde{c} = c^* - c$ is the parameters' estimation error vector.

Adding and subtracting $G_A(x)u^*$ to the right-hand side of (10), we obtain the error equation governing the closed-loop system

$$\dot{s} = v - f(x) - G_A(x)u - d(x, t) + G_A(x)u^* - G_A(x)u^* \tag{24}$$

Using (11) and (23), (24) becomes



$$\dot{s} = -ks - k_0 \tanh\left(\frac{s}{\varepsilon_0}\right) + G_A(x)e_u \quad (25)$$

To obtain a suitable adaptive law for the parameter c , one considers the minimization of the quadratic cost function (Shen et al. 2014; Wang et al. 2004) given by

$$J(c) = \frac{1}{2} (u^* - E^T Wc)^T G_A(x) (u^* - E^T Wc) \quad (26)$$

By applying the gradient descent method for the cost function (26), we obtain

$$\dot{c} = -\eta \nabla_c J(c), \quad (27)$$

where the gradient of $J(c)$ is given by

$$\nabla_c J(c) = \frac{\partial J(c)}{\partial c} = -W^T E G_A(x) e_u \quad (28)$$

Therefore, Eq. (27) becomes

$$\dot{c} = \eta W^T E G_A(x) e_u \quad (29)$$

By extracting the value of the vector $G_A(x)e_u$ from (25), we get

$$\dot{c} = \eta W^T E \left(\dot{s} + ks + k_0 \tanh\left(\frac{s}{\varepsilon_0}\right) \right) \quad (30)$$

In order to improve the performance of robustness in the presence of approximation errors, one needs to modify the adaptation law (29). Therefore, first as Shen et al. (2014) and Boubakir et al. (2011), we modify it by using the σ -modification concept initially developed by Ioannou and Kokotovic (Ioannou and Sun 1996; Ioannou and Kokotovic 1983) as follows:

$$\dot{c} = \eta W^T E G_A(x) e_u - \eta \sigma c, \quad (31)$$

where σ is a design positive constant.

Unfortunately, there are some performance-related disadvantages to using the σ -modification term, when the error e_u becomes very small, and the adaptive law (31) becomes approximately as $\dot{c} \approx -\eta \sigma c$. Hence, the parameters have a tendency to return to the origin, that is, they “unlearn” the gain values that caused the tracking error to become small, and also the parameters estimation error \tilde{c} do not converge to zero.

As shown in the simulation results below, in the presence of unexpected and unmatched disturbances, the adaptation PID control gains based on σ -modification diverge and go away from their ideal values (absence the disturbances).

Second, in order to overcome these drawbacks, one proposes to use the e -modification concept proposed by Narendra and Annaswamy (1987). The principal idea of this method's is to replace the constant gain σ in (31) by a certain term linearly proportional to the error, such as $|\mathbf{v}^T G_A(x) e_u|$. The wisdom of using this term is that it

converges to zero when the error e_u converges to zero. The adaptation law (29) with e -modification becomes

$$\dot{c} = \eta W^T E G_A(x) e_u - \eta |\mathbf{v}^T G_A(x) e_u| c, \quad (32)$$

where $G_A(x)e_u = \dot{s} + ks + k_0 \tanh\left(\frac{s}{\varepsilon_0}\right)$ and $\mathbf{v} = [\sigma, \dots, \sigma]^T$ is the constant vector of dimension n .

Figure 1 shows the block diagram of the proposed adaptive fuzzy PID control system.

To verify the effectiveness of this control law, in the next section, one analyzes the stability of closed-loop system.

3.3 Stability analysis

The goal of this section was to demonstrate that the control law (20) with adaptation laws (32) guarantees the boundedness of all the signals in the closed-loop system and the convergence of the tracking error to an adjustable region, by using the Lyapunov method.

Theorem 1 Consider the system given by (1) and the fuzzy PID control law defined by (20). Suppose that Assumptions 1 and 2 hold, and the fuzzy system parameters c are updated using the adaptation law (32). Then, the estimation error $\tilde{c} \in L_\infty$, and the error e_u is of order of $\|\mathbf{v}\|^2$ and ε_0 in the mean square sense.

Proof Let us consider the following positive function:

$$V_1 = \frac{1}{2\eta} \tilde{c}^T \tilde{c} \quad (33)$$

its time derivative is written

$$\dot{V}_1 = -\frac{1}{\eta} \tilde{c}^T \dot{\tilde{c}} \quad (34)$$

Substituting (32) into (34), get that

$$\dot{V}_1 = -\tilde{c}^T (W^T E G_A(x) e_u - c |\mathbf{v}^T G_A(x) e_u|), \quad (35)$$

$$\dot{V}_1 = -(e_u^T - \varepsilon^T) G_A(x) e_u + \tilde{c}^T c |\mathbf{v}^T G_A(x) e_u|. \quad (36)$$

By using the inequality


$$\tilde{c}^T c \leq -\frac{1}{2} \|\tilde{c}\|^2 + \frac{1}{2} \|c^*\|^2, \quad (37)$$

Equation (36) becomes

$$\begin{aligned} \dot{V}_1 \leq & -(e_u^T - \varepsilon^T) G_A(x) e_u - \frac{1}{2} \|\tilde{c}\|^2 |\mathbf{v}^T G_A(x) e_u| \\ & + \frac{1}{2} \|c^*\|^2 |\mathbf{v}^T G_A(x) e_u|. \end{aligned} \quad (38)$$

Because ε is bounded, it is obvious that there exists a certain constant ε_1 that can achieve the inequality

Fig. 1 Block diagram of the fuzzy adaptive PID control



$|\varepsilon^T G_A(x)e_u| \leq |\varepsilon_1 \mathbf{v}^T G_A(x)e_u| = |\varepsilon_1| |\mathbf{v}^T G_A(x)e_u|$; therefore, (38) can be rewritten as

$$\dot{V}_1 \leq -e_u^T G_A(x)e_u - \left(-|\varepsilon_1| + \frac{1}{2} \|\tilde{c}\|^2 - \frac{1}{2} \|c^*\|^2 \right) |\mathbf{v}^T G_A(x)e_u|. \quad (39)$$

It is clear that for $\frac{1}{2} \|\tilde{c}\|^2 \geq \frac{1}{2} \|c^*\|^2 + |\varepsilon_1|$, or $\frac{1}{2\eta} \|\tilde{c}\|^2 \geq \frac{1}{2\eta} \|c^*\|^2 + \frac{1}{\eta} |\varepsilon_1|$, i.e., for $V_1 \geq V_0 \triangleq \frac{1}{\eta} \left(\frac{1}{2} \|c^*\|^2 + |\varepsilon_1| \right)$, we have $\dot{V}_1 \leq 0$, which shows the boundedness of V_1 , that means also the boundedness of the parameters' estimation error vector \tilde{c} , i.e., $\tilde{c} \in L_\infty$.

Let us now examine the estimation error $\|e_u\|$.

The inequality (38) can be written as follows:

$$\dot{V}_1 \leq -e_u^T G_A(x)e_u + \varepsilon(x)^T G_A(x)e_u - \frac{1}{2} \|\tilde{c}\|^2 |\mathbf{v}^T G_A(x)e_u| + \frac{1}{2} \|c^*\|^2 |\mathbf{v}^T G_A(x)e_u|. \quad (40)$$

One can easily prove the following inequalities:

$$-e_u^T G_A(x)e_u + \frac{1}{2} \|c^*\|^2 |\mathbf{v}^T G_A(x)e_u| \leq -\frac{1}{2} e_u^T G_A(x)e_u + \frac{1}{8} \|c^*\|^4 |\mathbf{v}^T G_A(x)\mathbf{v}|, \quad (41)$$

$$\varepsilon^T G_A(x)e_u \leq \frac{1}{4} e_u^T G_A(x)e_u + \varepsilon^T G_A(x)\varepsilon \quad (42)$$

Applying (41), (42) into (40) gives

$$\dot{V}_1 \leq -\frac{1}{4} e_u^T G_A(x)e_u - \frac{1}{2} \|\tilde{c}\|^2 |\mathbf{v}^T G_A(x)e_u| + \frac{1}{8} \|c^*\|^4 |\mathbf{v}^T G_A(x)\mathbf{v}| + \varepsilon^T G_A(x)\varepsilon. \quad (43)$$

Since c^* is assumed bounded here and $\|\varepsilon\| \leq \varepsilon_0$, we can define a positive constant $M\psi$ as

$$M\psi = \sup \left(\frac{1}{8} \|c^*\|^4 |\mathbf{v}^T G_A(x)\mathbf{v}| + \varepsilon^T G_A(x)\varepsilon \right). \quad (44)$$

By replacing $M\psi$ defined in (44), and by defining a positive constant a_N such that $a_N = \|A\|$, (43) can be rewritten as

$$\dot{V}_1 \leq -\frac{a_N g_0}{4} \|e_u\|^2 + M\psi. \quad (45)$$

Because $V_1 \in L_\infty$, we can integrate both sides of (45) as follows:

$$\int_t^{t+T} \|e_u\|^2 dt \leq \frac{4}{a_N g_0} M\psi T + \frac{4}{a_N g_0} (V_1(t) - V_1(t+T)). \quad (46)$$

On pose $m_1 = \frac{4}{a_N g_0} \max \left(\frac{a_N g_1}{8} \|c^*\|^4, a_N g_1 \right)$ and $m_2 = \frac{4}{a_N g_0} \sup_t (V_1(t) - V_1(t+T))$, therefore, (46) becomes

$$\int_t^{t+T} \|e_u\|^2 dt \leq m_1 \left(\|\mathbf{v}\|^2 + \varepsilon_0^2 \right) T + m_2, \quad (47)$$

Equation (47) implies that $\|e_u\| \in S \left(\|\mathbf{v}\|^2 + \varepsilon_0^2 \right)$.

Theorem 2: Consider the system (1) and suppose that the assumptions 1–2 are satisfied; then, the control law

defined by (20) and (32) guarantees the following properties:

- (i) The solution of the closed-loop error system decreases exponentially to an adjustable region.
- (ii) When the approximation error converges to zero (ε disappears), by setting $\sigma = 0$, one can prove that $\lim_{t \rightarrow \infty} \|s\|(t) = 0$, i.e., $e_i(t) \rightarrow 0$ as $t \rightarrow \infty$, for $i = 1, \dots, p$.

Proof (i) Let us analyze the stability by choosing the following Lyapunov function:

$$V = \frac{1}{2} s^T s + \frac{1}{2\eta} \tilde{c}^T \tilde{c} = \frac{1}{2} s^T s + V_1. \tag{48}$$

Its time derivative is

$$\dot{V} = s^T \dot{s} + \dot{V}_1. \tag{49}$$

Substituting (25) into (49), we get

$$\dot{V} = -s^T k s - s^T k_0 \tanh\left(\frac{s}{\varepsilon_0}\right) + s^T G_A(x) e_u + \dot{V}_1 \tag{50}$$

Using the following inequality

$$s^T G_A(x) e_u \leq \frac{1}{4} e_u^T G_A(x) e_u + s^T G_A(x) s \tag{51}$$

allows to write (50) in the following form:

$$\begin{aligned} \dot{V} = & -s^T k s - s^T k_0 \tanh\left(\frac{s}{\varepsilon_0}\right) + \frac{1}{4} e_u^T G_A(x) e_u + s^T G_A(x) s \\ & + \dot{V}_1 \end{aligned} \tag{52}$$

By using the inequality \dot{V}_1 represented by (43) into (52) we get

$$\begin{aligned} \dot{V} \leq & -s^T (k - G_A(x)) s - s^T k_0 \tanh\left(\frac{s}{\varepsilon_0}\right) \\ & - \frac{1}{2} \|\tilde{c}\|^2 |v^T G_A(x) e_u| \\ & + \frac{1}{8} \|c^*\|^4 |v^T G_A(x) v + \varepsilon^T G_A(x) \varepsilon|. \end{aligned} \tag{53}$$

Assuming that the gains k_i are chosen such that $k_i > g_1 a_N, i = 1, \dots, p$, and setting $\gamma = 2 \min_{1 \leq i \leq p} (k_i - g_1 a_N)$; therefore, (53) can be written as

$$\dot{V} \leq -\frac{1}{2} s^T \gamma s + M\psi \tag{54}$$

We can conclude that $\dot{V} \leq 0$ if $\frac{1}{2} \|s(t)\|^2 \geq \frac{1}{\gamma} M\psi$, or equivalently $V \geq \frac{1}{\gamma} M\psi + V_1$ since V_1 is bounded, therefore, according to a standard Lyapunov theorem we conclude that the signals s and \tilde{c} in the closed-loop system are bounded and V is also bounded.

By integrating both sides of (54), we obtain

$$\int_t^{t+T} \|s\|^2 dt \leq \frac{2}{\gamma} M\psi T + \frac{2}{\gamma} (V(t) - V(t+T)). \tag{55}$$

Because $V \in L_\infty$, the filtered tracking error s will converge exponentially to the residual set $\Omega_s = \{s | s \leq \sqrt{\frac{2}{\gamma} M\psi}\}$, i.e., $|s_i|$ converges to $\sqrt{\frac{2}{\gamma} M\psi}$ as $t \rightarrow \infty$.

So, it is enough to choose the appropriate values of k_i, σ, η , to make $\sqrt{\frac{2}{\gamma} M\psi}$ small as possible. Status $w = \sqrt{\frac{2}{\gamma} M\psi}$ exists T such that $\|s(t)\| \leq w$ for $t > T$; this implies that $\|e_i^j(t)\| \leq 2^j \lambda_i^{j-r_i+1} w, j = 0, \dots, r_i - 1, i = 1, \dots, p$, we can conclude that all drives of the tracking error converge to an adjustable region.

Proof (ii):

When $\varepsilon = 0$ and by assuming that $\sigma = 0, |v^T G_A(x) e_u| = 0$, (52) can be written as

$$\dot{V} = -s^T k s - s^T k_0 \tanh\left(\frac{s}{\varepsilon_0}\right) + s^T G_A(x) s. \tag{56}$$

Using the expression of γ we get

$$\dot{V} \leq -\frac{1}{2} s^T \gamma s. \tag{57}$$

Integrating both sides of (57) yields

$$V(t+T) - V(t) \leq -\frac{\gamma}{2} \int_t^{t+T} \|s\|^2 dt. \tag{58}$$

Equation (58) can be rewritten as

$$\int_t^{t+T} \|s\|^2 dt \leq \frac{2}{\gamma} (V(t) - V(t+T)). \tag{59}$$

Because $V(t) \in L_\infty$, it follows that $s \in L_2$, we have $\dot{s} \in L_\infty$ (all the variables of (25) are bounded); consequently $s \in L_2 \cap L_\infty$ and $\dot{s} \in L_\infty$. By using Barbalat's Lemma (Khalil 1996), we conclude that $\lim_{t \rightarrow \infty} \|s_i(t)\| = 0$, which implies that $\lim_{t \rightarrow \infty} e_i = 0$.

Remark It is clear that the control law is PID type, without any robustifying term. However, the term $k_0 \tanh\left(\frac{s}{\varepsilon_0}\right)$ in the adaptive law (32) plays the role of a robustifying term.

4 Simulation results

In order to test the effectiveness of the proposed MIMO adaptive fuzzy PID control law, we have taken care to choose two simulation examples which present a big



challenge for the control community: a two-link rigid robot manipulator and a quadrotor. For both systems, the proposed approach is tested with and without the presence of the disturbances and dead-zone inputs' nonlinearities. Moreover, a comparative study is carried out to illustrate the superiority in terms of robustness of the proposed approach with the e -modification adaptation law over the proposed approach with σ -modification adaptation law, on the one hand, and over the adaptive fuzzy control proposed developed in (Cui et al. 2017) on the other hand.

4.1 Example 1: two-link rigid robot manipulator

The dynamical model of the two-link rigid robot manipulator is given by (Eslami et al. 2006; Tamura and Ohmori 2007):

$$\begin{bmatrix} P_{11} & P_{12} \\ P_{21} & P_{22} \end{bmatrix} \begin{bmatrix} \ddot{q}_1 \\ \ddot{q}_2 \end{bmatrix} + \begin{bmatrix} -h\dot{q}_2 & -h(\dot{q}_1 + \dot{q}_2) \\ h\dot{q}_1 & 0 \end{bmatrix} \begin{bmatrix} \dot{q}_1 \\ \dot{q}_2 \end{bmatrix} = \begin{bmatrix} u_1 \\ u_2 \end{bmatrix}, \tag{60}$$

where

$$\begin{aligned} P_{11} &= a_1 + 2a_3 \cos(q_2) + 2a_4 \sin(q_2), \\ P_{12} = P_{21} &= a_2 + a_3 \cos(q_2) + a_4 \sin(q_2), \\ P_{22} &= a_2, \quad h = a_3 \sin(q_2) - a_4 \cos(q_2), \end{aligned}$$

with

$$\begin{aligned} a_1 &= I_1 + m_1 l_{c1}^2 + I_e + m_e l_{ce}^2 + m_e l_1^2, \quad a_2 = I_e + m_e l_{ce}^2, \\ a_3 &= m_e I_1 l_{ce} \cos \delta_e, \quad a_4 = m_e I_1 l_{ce} \sin \delta_e. \end{aligned}$$

In this simulation, we use the flowing parameter values:

$$m_1 = 1, m_e = 2, I_1 = 1, I_{c1} = 0.5, I_{ce} = 0.6, I_1 = 0.12, I_e = 0.25, \delta_e = 30^\circ.$$

$$\text{Let } y = [q_1, q_3]^T, \quad u = [u_1, u_2]^T, \quad x = [q_1, q_2, q_3, q_4]^T$$

$$\text{and } f(x) = \begin{bmatrix} f_1(x) \\ f_2(x) \end{bmatrix} = -P^{-1} \begin{bmatrix} -h\dot{q}_2 & -h(\dot{q}_1 + \dot{q}_2) \\ h\dot{q}_1 & 0 \end{bmatrix} \begin{bmatrix} \dot{q}_1 \\ \dot{q}_2 \end{bmatrix},$$

$$G(x) = \begin{bmatrix} g_{11} & g_{12} \\ g_{21} & g_{22} \end{bmatrix} = P^{-1} = \begin{bmatrix} P_{11} & P_{12} \\ P_{21} & P_{22} \end{bmatrix}^{-1}.$$

With the matrix P is positive definite, this leads to the matrix $G(x)$ defined by $G(x) = P^{-1}$ is also positive definite.

Then, the system (60) can be written as

$$\ddot{y} = f(x) + G(x)N(u). \tag{61}$$

The control goal is to force the robot manipulator to track the following desired references $y_{d1}(t) = \sin(t)$ and $y_{d2}(t) = \cos(t)$.

For that, we use two adaptive fuzzy PID controllers u_1 and u_2 . The gains of each PID controller are approximated

by a fuzzy system as presented in Sect. 2. For the each input one uses three membership functions (shown in Fig. 2) defined by

$$\begin{aligned} \mu_{F_{ij}^1} &= \begin{cases} 1 & \text{if } e_{ij} > \varepsilon_{ij} \\ \left| \cos\left(\frac{\pi}{2\varepsilon_{ij}} e_{ij} + \frac{\pi}{2}\right) \right| & \text{if } 0 \leq e_{ij} \leq \varepsilon_{ij} \\ 0 & \text{if } e_{ij} < 0 \end{cases} \\ \mu_{F_{ij}^2} &= \begin{cases} 0 & \text{if } e_{ij} < -\varepsilon_{ij} \\ \left| \cos\left(\frac{\pi}{2\varepsilon_{ij}} e_{ij}\right) \right| & \text{if } -\varepsilon_{ij} \leq e_{ij} \leq \varepsilon_{ij} \\ 0 & \text{if } e_{ij} > \varepsilon_{ij} \end{cases} \\ \mu_{F_{ij}^3} &= \begin{cases} 1 & \text{if } e_{ij} < -\varepsilon_{ij} \\ \left| \cos\left(\frac{\pi}{2\varepsilon_{ij}} e_{ij} + \frac{\pi}{2}\right) \right| & \text{if } -\varepsilon_{ij} \leq e_{ij} \leq 0, \\ 0 & \text{if } e_{ij} > 0 \end{cases} \end{aligned}$$

where $i = 1, 2, j = 1, 2, 3$. $\varepsilon_{11} = 1, \varepsilon_{12} = 0.5, \varepsilon_{13} = 1.5$. $\varepsilon_{21} = 1, \varepsilon_{22} = 0.5, \varepsilon_{23} = 1.5$.

In the simulation, we use $\lambda_1 = 2, \lambda_2 = 2, k = \text{diag}[7, 7]$, $k_0 = \text{diag}[10, 10]$, $\sigma = 0.01, \varepsilon_0 = 0.01, \eta = 8$.

The dead-zone used here is presented as (Wang et al. 2004)

$$N(u_i) = \begin{cases} m_{ri}(u_i - b_{ri}) & \text{for } u_i \geq b_{ri} \\ 0 & \text{for } b_{li} < u_i < b_{ri} \\ m_{li}(u_i - b_{li}) & \text{for } u_i \leq b_{li} \end{cases}$$

For the two inputs we consider similar dead zones with the following parameters: $m_{ri} = m_{li} = 1$, $b_{li} = -3.5$ and $b_{ri} = 3.5$. ($i = 1, 2$). The robot initial conditions are $x(0) = [-0.25 \ 0 \ 0.25 \ 0]^T$ and $\dot{x}(0) = [0 \ 0 \ 0 \ 0]^T$. The nonlinear functions $f(x)$ and $G(x)$ are supposed completely unknown. All the initial parameters of the fuzzy system are set to zero.

The first case: The simulations results are done without adding the disturbances and dead-zone inputs' nonlinearities. The results are illustrated by Figs. 3, 4, 5, 6, 7, 8.

From Figs. 3 and 4, we can see that the actual trajectories quickly converge to the desired trajectories. Figures 5 and 6 illustrate the effectiveness of the used method; the PID control gains reach their true values very rapidly compared to the adaptive method. Figures 7 and 8 show the ideal control signals and the proposed PID control signals without adding $\delta_i(t)$ and dead-zone inputs' nonlinearities; we find that the error between them is small, thanks to universal approximation of fuzzy systems.

The second case: The simulations are done in the presence of the disturbances and dead-zone inputs' nonlinearities which are defined above. A Gaussian noise with variance 0.002 and mean zero is added to all the states' measurements. The simulations are done using alternatively the σ -modification and the e -modification robustification terms in adaptive law. The results are presented by Figs. 9, 10, 11, 12, 13, 14.

Fig. 2 The membership function





Fig. 3 The position of link 1




Fig. 4 The position of link 2




Fig. 5 Evolution of the PID control gains u_1 (K_{P1}, K_{D1}, K_{I1})




Fig. 6 Evolution of the PID control gains u_2 (K_{P2}, K_{D2}, K_{I2})

Figures 9 and 10 show clearly that using the both conceptions (σ -modification and e -modification) in the adaptive law leads to adequate tracking until the presence of disturbances and dead-zone. However, as we can see in Figs. 11, 12, 13, 14, unlike the σ -modification conception, the e -modification keeps the adaptation parameters of the

PID control uniformly bounded and force them to stay nearly their ideal values shown in Figs. 5 and 6. And also, the e -modification can relatively reduce the oscillations induced by the presence of disturbances.




Fig. 7 Control signals u_1 and u_1^*




Fig. 8 Control signals u_2 and u_2^*




Fig. 9 The position of link 1 in presence the disturbances and the dead-zone inputs' nonlinearities

Tables 1 and 2 present a quantitative comparative study between our approach and the designed adaptive fuzzy control law in (Cui et al. 2017) with and without presence of disturbances, respectively. The results show the superiority of our approach (the fuzzy PID control with e -modification) against the criteria IAE (Integral Absolute Error), ISE (Integral Squared Error) and IAU (Integral Absolute Input).

Example 2: Stabilization of a quadrotor

The quadrotor is a small Unmanned Aerial Vehicle (UAV) with four propellers actuated by DC motors mounted on the end of two perpendicular arms. A basic diagram is shown in Fig. 15.




Fig. 10 The position of link 2 in the presence of disturbances and dead-zone inputs' nonlinearities




Fig. 11 Evolution of the PID control gains u_1 with the e -modification




Fig. 12 Evolution of the PID control gains u_2 with the e -modification




Fig. 13 Evolution of the PID control gains u_1 with the σ -modification




Fig. 14 Evolution of the PID control gains u_2 with the σ -modification

Table 1 IAE, ISE and IAU of the proposed method and that of (Zhang et al. 2002) without the presence of disturbances and dead-zone inputs' nonlinearities

Control method	IAE	ISE	IAU
The fuzzy PID control with e -modification	0.5193	01501	78.79
The fuzzy PID control with σ -modification	0.6558	0.1768	41.02
The control law of (Zhang et al. 2002)	0.6361	0.1335	141.6

Table 2 IAE, ISE and IAU of the proposed method and that of (Zhang et al. 2002) with the presence of the disturbances

Control method	IAE	ISE	IAU
The fuzzy PID control with e -modification	0.6231	0.1105	115.7
The fuzzy PID control with σ -modification	1.454	0.377	240.2
The control law of (Zhang et al. 2002)	0.6861	0.1325	148.5

Each rotors pair of the same arm rotates in same direction: one pair rotates clockwise, while the other rotates counter clockwise. The quadrotor moves by adjusting the angular velocity of each rotor.

One considers the dynamical model of quadrotor in (Bouabdallah 2007) given by

$$\begin{aligned} \dot{x}_1 &= x_2 \\ \dot{x}_2 &= x_4 x_6 a_1 - x_4 a_2 \Omega_r + b_1 u_1 \\ \dot{x}_3 &= x_4 \\ \dot{x}_4 &= x_2 x_6 a_3 + x_2 a_4 \Omega_r + b_2 u_2 \\ \dot{x}_5 &= x_6 \\ \dot{x}_6 &= x_2 x_4 a_5 + b_3 u_3 \\ \dot{x}_7 &= x_8 \\ \dot{x}_8 &= (\cos(x_1) \sin(x_3) \cos(x_5) + \sin(x_1) \sin(x_5)) b_4 u_4 \\ \dot{x}_9 &= x_{10} \end{aligned}$$




Fig. 15 Quadrotor configuration

Table 3 The quadrotor model parameters

Parameter	Optimal value
l	0.23 m
d	7.5×10^{-7} N m s ²
b	3.13×10^{-5} N s ²
m	0.65 Kg
g	9.806 m/s ²
I_x	7.5×10^{-3} Kg m ²
I_y	7.5×10^{-3} Kg m ²
I_z	1.3×10^{-3} Kg m ²
J_R	6×10^{-5} Kg m ²

$$\dot{x}_{10} = (\cos(x_1) \sin(x_3) \cos(x_5) - \sin(x_1) \cos(x_5)) b_4 u_4$$

$$\dot{x}_{11} = x_{12}$$

$$\dot{x}_{12} = -g + \cos(x_3) \cos(x_1) b_4 u_4,$$

where $x_1 = \phi$ and $x_2 = \dot{\phi}$ are, respectively, the roll angle and corresponding angular velocity; $x_3 = \theta$ and $x_4 = \dot{\theta}$ are, respectively, the pitch angle and corresponding angular velocity; $x_5 = \psi$ and $x_6 = \dot{\psi}$ are, respectively, the yaw angle and corresponding angular velocity; $x_7 = X$, $x_9 = Y$, and $x_{11} = Z$ are the Cartesian position coordinates and $x_8 = \dot{X}$, $x_{10} = \dot{Y}$, and $x_{12} = \dot{Z}$ are the corresponding velocities, respectively.

$$\begin{bmatrix} u_1 \\ u_2 \\ u_3 \\ u_4 \end{bmatrix} = \begin{bmatrix} 0 & -b & 0 & b \\ b & 0 & -b & 0 \\ -d & d & -d & d \\ b & b & b & b \end{bmatrix} \begin{bmatrix} \Omega_1^2 \\ \Omega_2^2 \\ \Omega_3^2 \\ \Omega_4^2 \end{bmatrix}$$

$\Omega_r = -\Omega_1 + \Omega_2 - \Omega_3 + \Omega_4$ is the sum of rotor angular velocities.




Fig. 16 The simulation results without the presence of disturbances and dead-zone inputs' nonlinearities **a** the roll angle: **b** the pitch angle: **c** the yaw angle: **d** the height

$$a_1 = \frac{I_y - I_z}{I_x}; a_2 = \frac{J_r}{I_x}; a_3 = \frac{I_z - I_x}{I_y}; a_4 = \frac{J_r}{I_y}; a_5 = \frac{I_x - I_y}{I_z}; b_1 = \frac{l}{I_x}; b_2 = \frac{l}{I_y}; b_3 = \frac{1}{I_z}; b_4 = \frac{1}{m}.$$

The values of the parameters in the state space model are given by Table 3 (Bouabdallah 2007).

The control objective here is to stabilize angles and height of the quadrotor. That is, four decentralized fuzzy adaptive PID controllers which have the same structure of controller used in the first example. However, the structural parameters are chosen as follows: $\lambda_1 = 4, \lambda_2 = 3, \lambda_3 = 3, \lambda_4 = 2, k = \text{diag}[5, 7, 7, 7], k_0 = \text{diag}[20, 10, 11, 10], \sigma = 0.01, \varepsilon_0 = 0.01, \eta = 8.$

And the fuzzy system parameters are $\varepsilon_{11} = 1, \varepsilon_{12} = 0.5, \varepsilon_{13} = 1.5, \varepsilon_{21} = 1, \varepsilon_{22} = 0.5, \varepsilon_{23} = 1.5, \varepsilon_{31} = 1, \varepsilon_{32} = 0.5, \varepsilon_{33} = 1.5, \varepsilon_{41} = 1, \varepsilon_{42} = 0.5, \varepsilon_{43} = 1.5.$

We consider similar dead zones for the four inputs which have the same structure as the first example with the following parameters: $m_{ri} = m_{li} = 1, b_{li} = -2.5$ and $b_{ri} = 2.5. (i = 1, 2, \dots, 4).$

The initial states of the quadrotor are $\varphi(0) = 0.5\text{rad}, \theta(0) = -0.5\text{rad}, \psi(0) = -0.5\text{rad}, Z(0) = 0\text{m}.$

The desired angles and height $\varphi_d = 0\text{rad}, \theta_d = 0\text{rad}, \psi_d = 0\text{rad},$ and $Z_d = 10\text{m}.$

The simulation results with and without the disturbances and the dead-zone inputs' nonlinearities are illustrated by Figs. 16, 17, 18, 19 and 20.




Fig. 17 Evolution of the PID control gains. **a** The control u_1 : **b** the control u_2 : **c** the control u_3 : **d** the control u_4

Figures 16, 17 show, respectively, the system outputs and the evolution of the corresponding PID control gains in the nominal system (without disturbances and without inputs nonlinearities) while Fig. 18 shows the system outputs in the presence of disturbances (a Gaussian noise with variance 0.002 and mean zero is added to all the states' measurements) with both the adaptation laws and Figs. 19, 20 show the evolution of the corresponding PID control gains.

One sees clearly that the outputs' trajectories converge quickly to the desired values even with presence of the disturbances and inputs' nonlinearities. As in the previous example, the results illustrate the effectiveness and

the advantages of the control law using e -modification adaptation law compared to the control law using σ -modification adaptation law, namely the PID control gains are bounded and go to their ideal values, and the oscillations induced by the presence of disturbances are reduced.

5 Conclusion

In this work, we have proposed an adaptive fuzzy PID control scheme for a class of MIMO unknown nonlinear systems. An adaptive fuzzy system has been used to approximate the parameters of the PID control. A gradient




Fig. 18 Simulation results with the presence of disturbances and dead-zone inputs' nonlinearities: **a** the roll angle. **b** the pitch angle. **c** the yaw angle. **d** the height

decent adaptation law, augmented by introducing the e -modification robustification term, is used to minimize the error between the PID control and the unknown ideal control. The Lyapunov stability analysis proves the convergence of the tracking error to acceptable region in the

neighborhood of zero and the boundedness of all signals in the closed-loop system. The simulations of the proposed control scheme, performed on a two-link manipulator robot model, show the effectiveness of the method.




Fig. 19 Evolution of the PID control gains with the e -modification. **a** The control u_1 : **b** the control u_2 : **c** the control u_3 : **d** the control u_4

6 Future recommendation

As in the most previous works, although the stated objectives of this research have been achieved, this work can be improved and extended to deal with other control

problems. So the proposed future recommendations are as follows:

- (i) Developing this control law for uncertain under-actuated mechanical systems (UMS) with dead-zone input.




Fig. 20 Evolution of the PID control gains with the σ -modification. **a** The control u_1 : **b** the control u_2 : **c** the control u_3 : **d** the control u_4

- (ii) Developing this control law for uncertain under-actuated mechanical systems (UMS) with unknown control direction.
- (iii) Introducing an observer for this control law to overcome the unavailability problem of state variables.

References

- Akhtar S, Bernstein DS (2005) Lyapunov-stable discrete-time model reference adaptive control. *Int J Adapt Control Signal Process* 19:745–767
- Al-zohairy TA, Salem KS (2016a) Adaptive control for MIMO nonlinear systems based on PID neural networks. *Int J Eng Comput Sci* 5:1–6
- Al-zohairy TA, Salem KS (2016) Model following control of SISO nonlinear systems using PID neural networks. *Int J Comput Appl* 140:12–17
- Andromeda T, Yahya A, Khamis NHH, Baharom A, Rahim MAA (2012) PID controller tuning by particle swarm optimization on electrical discharge machining servo control system. In: *Intelligent and Advanced Systems (ICIAS) 2012*, pp 51–55
- Astrom KJ, Hagglund T, Controllers PID (1995) Theory design and tuning. Instrument Society of America, North Carolina
- Babaei N, Salamci MU (2014) State dependent riccati equation based model reference adaptive stabilization of nonlinear systems with application to cancer treatment. *IFAC Proc Vol* 47:1296–1301
- Babulu K, Kumar K (2012) Fuzzy self-adaptive PID controller design for electric heating furnace. *Int J Eng Invent* 1:10–21

- Bernard T, Kuntze HB (1999) Multi-objective optimization of building climate control systems using fuzzy-logic. In: European control conference (ECC), Germany, Karlsruhe, 1999, pp 2572–2577
- Bouabdallah S (2007) Design and control of quadrotors with application to autonomous flyin, Ph.D. dissertation, École Polytechnique Fédérale de Lausanne, 2007
- Boubakir A, Labiod S, Boudjema F (2011) A stable self-tuning proportional-integral-derivative controller for a class of multi-input multi-output nonlinear systems. *J Vib Control* 18:228–239
- Chiou JS, Tsai SH, Liu MT (2012) A PSO-based adaptive fuzzy PID-controllers. *Simul Model Pract Theory* 26:49–59
- Cui Y, Zhang H, Wang Y, Gao W (2017) Adaptive tracking control of uncertain MIMO nonlinear systems based on generalized fuzzy hyperbolic model. *Fuzzy Sets Syst* 306:105–117
- Der Chang W, Hwang RC, Hsieh JG (2003) A multivariable on-line adaptive PID controller using auto-tuning neurons. *Eng Appl Artif Intell* 16:57–63
- Ercin O, Coban R (2011) Comparison of the Artificial Bee Colony and the Bees Algorithm for PID Controller Tuning. In: Symp. innov. intell. syst. appl (INISTA), Turkey, Istanbul, 2011, pp 595–598
- Eslami P, Motlagh MRJ, Sarang R (2006) Disturbance rejection of distillation column using multiloop nonlinear adaptive PID controller. In: International conference on computational intelligence for modelling control and automation, and international conference on intelligent agents, web technologies and internet commerce (CIMCA-IAWTIC'06), Sydney, NSW, 2006, p 43
- Feki M (2003) An adaptive feedback controller for linearizable chaotic systems. *Chaos Solitons Fractals* 15:883–890
- Fu G, Ou L, Zhang W (2016) Robust adaptive tracking control of MIMO nonlinear systems in the presence of actuator hysteresis. *Int J Syst Sci* 47:2359–2369
- Ge SS, Hang CC, Lee TH, Zhang T (2001) Stable adaptive neural network control. Kluwer Academic Publisher, Boston
- Ghaffari V, Safavi AA, Naghavi S (2013) Robust model predictive control of a class of uncertain nonlinear systems with application to typical CSTR problems. *J Process Control* 23:493–499
- Gomez-Ortega J, Ramirez DR, Limon-Marruedo D, Camacho EF (2001) Genetic algorithms based predictive control for mobile robot navigation in changing environments. In: European control conference (ECC), Portugal, Porto, 2001, pp 3179–3184
- Guo SM, Tsai JSH, Lin YC, Tsai TJ, Chen CW (2009) Intelligent-based PID fault tolerant tracking control for unknown nonlinear MIMO systems. In: IEEE international conference on control and automation (ICCA), Zealand, Christchurch, 2009, pp 331–336
- Hanifah RA, Toha SF, Ahmad S (2013) PID-Ant Colony Optimization (ACO) control for Electric Power Assist Steering system for electric vehicle. In: IEEE international conference on smart instrumentation, measurement and applications (ICSIMA), Malaysia, Kuala Lumpur, 2013, pp 1–5
- Hua CC, Guan XP, Shi P (2005) Adaptive feedback control for a class of chaotic systems. *Chaos Solitons Fractals* 23:757–765
- Huang HP, Roan ML, Jeng JC (2002) On-line adaptive tuning for PID controllers. *Control Theory Appl* 149:60–67
- Ioannou PA, Kokotovic PV (1983) Adaptive systems with reduced models. Springer, New York
- Ioannou PA, Sun J (1996) Robust adaptive control. Prentice Hall, Englewood Cliffs
- Jovanovic M (2002) Nonlinear control of an electrohydraulic velocity servosystem. In: Proceedings of the American control conference, vol 1, pp 588–593
- Juang YT, Chang YT, Huang CP (2008) Design of fuzzy PID controllers using modified triangular membership functions. *Inf Sci* 178:1325–1333
- Kaddissi C, Kenné JP, Saad M (2005) Drive by wire control of an electro-hydraulic active suspension—a backstepping approach. In: 2005 IEEE international conference on control applications, Canada, Toronto, Ont, 2005, pp 1581–1587
- Khalil HK (1996) Nonlinear Systems, 2nd edn. Prentice-Hall, EnglewoodCliffs
- Khazaei M, Markazi AHD, Rizi ST, Seyfi B (2017) Adaptive fuzzy sliding mode control of input-delayed uncertain nonlinear systems through output-feedback. *Nonlinear Dyn* 87:1943–1956
- Knoop MKF, Pérez JAM (1994) Nonlinear PI-controller design for a continuous flow furnace via continuous gain scheduling. *J Process Control* 4:143–147
- Kumar U, Mahajan S, Sinha S, Kaur M (2016) Adaptive PID control system—a review. *Int J Eng Sci Comput* 6:2978–2980
- Lai JG, Zhou H, Hu WS, Lai J, Zhou H, Hu W (2016) A new adaptive fuzzy PID control method and its application in FCBTM. *Int J Comput Commun Control Issn* 11:394–404
- Lu D, Zhu L, Li X (2010) PID parameter optimization of shunting and winch control system in coal transportation based online adaptive genetic algorithm. In: Int. conf. e-product e-service e-entertainment, ICEEE2010, China, Henan, 2010, pp 4–7
- Ma XM (2009) Application of ant colony algorithm in PID parameter optimization for mining hoist direct torque control system. In: International conference on advanced computer control (ICACC), Singapore 2009, pp 632–636
- Majd VJ, Mobayen S (2015) An ISM-based CNF tracking controller design for uncertain MIMO linear systems with multiple time-delays and external disturbances. *Nonlinear Dyn* 80:591–613
- Mizumoto I, Hirahata T, Ohdaira S, Iwai Z (2009) Adaptive PID controller design based on output feedback passivity for discrete-time linear systems. In: American control conference, USA, St. Louis, MO, 2009, pp 4673–4679
- Mobayen S (2015a) Fast terminal sliding mode controller design for nonlinear second-order systems with time-varying uncertainties. *Complexity* 21:239–244
- Mobayen S (2015b) An adaptive chattering-free PID sliding mode control based on dynamic sliding manifolds for a class of uncertain nonlinear systems. *Nonlinear Dyn* 82:53–60
- Mobayen S (2015c) Design of a robust tracker and disturbance attenuator for uncertain systems with time delays. *Complexity* 21:340–348
- Mobayen S (2015d) An LMI-based robust tracker for uncertain linear systems with multiple-varying delays using optimal composite nonlinear feedback technique. *Nonlinear Dyn* 80:917–927
- Mobayen S, Tchier F (2016) Design of an adaptive chattering avoidance global sliding mode tracker for uncertain non-linear time-varying systems. *Trans Inst Meas Control* 39:1–12
- Narendra KS, Annaswamy AM (1987) A new adaptive law for robust adaptive control without persistency of excitation. *IEEE Trans Autom Control* 32:134–145
- Nejati A, Shahrokhi M, Mehrabani A (2012) Comparison between backstepping and input–output linearization techniques for pH process control. *J Process Control* 22:263–271
- Poursafar N, Taghirad HD, Haeri M (2010) Model predictive control of non-linear discrete time systems: a linear matrix inequality approach. *IET Control Theory Appl* 4:1922–1932
- Poursamad A, Markazi AHD (2009) Adaptive fuzzy sliding-mode control for multi-input multi-output chaotic systems. *Chaos Solitons Fractals* 42:3100–3109
- Seo J, Venugopal R, Kenné JP (2007) Feedback linearization based control of a rotational hydraulic drive. *Control Eng Pract* 15:1495–1507
- Shen D, Sun W, Sun Z (2014) Adaptive PID formation control of nonholonomic robots without leader's velocity information. *ISA Trans* 53:474–480



- Slotine JE, Li W (1991) Applied nonlinear control. Prentice Hall, Englewood Cliffs
- Soyguder S, Karakose M, Alli H (2009) Design and simulation of self-tuning PID-type fuzzy adaptive control for an expert HVAC system. *Expert Syst Appl* 36:4566–4573
- Srikanth S, Chandra GR (2012) Modeling and PID control of the brushless DC motor with the help of Genetic Algorithm. In: IEEE-international conference on advances in engineering, science and management (ICAESM), India, Nagapattinam, Tamil Nadu, 2012, 639–644
- Su CY, Oya M, Hong H (2003) Stable adaptive fuzzy control of nonlinear systems preceded by unknown backlash-like hysteresis. *IEEE Trans Fuzzy Syst* 11:1–8
- Tamura K, Ohmori H (2006) Auto-tuning method of expanded PID control for MIMO systems, International Joint Conference (SICE-ICASE). Busan, Bexco, pp 3270–3275
- Tamura K, Ohmori H (2007) Adaptive PID control for perfect tracking problem of MIMO systems, annual conference (SICE). Takamatsu, Japan, pp 446–453
- Wang LX (1994) Adaptive fuzzy systems and control: design and stability analysis. Prentice-Hall, Englewood Cliffs
- Wang XS, Su CY, Hong H (2004) Robust adaptive control of a class of nonlinear systems with unknown dead-zone. *Automatica* 40:407–413
- Yesil E, Guzelkaya M, Eksin I (2004) Internal model control based fuzzy gain scheduling technique of PID controllers. In: Automation congress.17, 2004, pp 501–506
- Yu WS (2006) Adaptive fuzzy PID control for nonlinear systems with H_∞ tracking performance. In: IEEE international conference on fuzzy systems, Canada, Vancouver, BC, 2006, pp 1010–1015
- Yu DL, Chang TK, Yu DW (2007) A stable self-learning PID control for multivariable time varying systems. *Control Eng Pract* 15:1577–1587
- Zhang W, Xi Y, Yang G, Xu X (2002) Design PID controllers for desired time-domain or frequency-domain response. *ISA Trans* 41:511–520
- Ziegler JG, Nichols NB (1942) Optimum settings for automatic controllers. *Trans ASME* 64:759–768

Reproduced with permission of copyright owner. Further reproduction prohibited without permission.