

12-1-2012

Investigating the Impacts of Conventional and Advanced Treatment Technologies on Energy Consumption at Satellite Water Reuse Plants

Jonathan Roy Bailey
University of Nevada, Las Vegas, ArcticWolf005@aol.com

Follow this and additional works at: <https://digitalscholarship.unlv.edu/thesesdissertations>



Part of the [Civil Engineering Commons](#), [Environmental Engineering Commons](#), [Oil, Gas, and Energy Commons](#), [Sustainability Commons](#), and the [Water Resource Management Commons](#)

Repository Citation

Bailey, Jonathan Roy, "Investigating the Impacts of Conventional and Advanced Treatment Technologies on Energy Consumption at Satellite Water Reuse Plants" (2012). *UNLV Theses, Dissertations, Professional Papers, and Capstones*. 1707.

<https://digitalscholarship.unlv.edu/thesesdissertations/1707>

This Thesis is protected by copyright and/or related rights. It has been brought to you by Digital Scholarship@UNLV with permission from the rights-holder(s). You are free to use this Thesis in any way that is permitted by the copyright and related rights legislation that applies to your use. For other uses you need to obtain permission from the rights-holder(s) directly, unless additional rights are indicated by a Creative Commons license in the record and/or on the work itself.

This Thesis has been accepted for inclusion in UNLV Theses, Dissertations, Professional Papers, and Capstones by an authorized administrator of Digital Scholarship@UNLV. For more information, please contact digitalscholarship@unlv.edu.

**INVESTIGATING THE IMPACTS OF CONVENTIONAL AND ADVANCED
TREATMENT TECHNOLOGIES ON ENERGY CONSUMPTION
AT SATELLITE WATER REUSE PLANTS**

By

Jonathan R Bailey

Bachelor of Science in Engineering, Civil Engineering
University of Nevada, Las Vegas
May 2010

A thesis submitted in partial fulfillment of
the requirement for the

Master of Science in Engineering, Civil and Environmental Engineering

**Department of Civil and Environmental Engineering and Construction
Howard R. Hughes College of Engineering
Graduate College**

**University of Nevada, Las Vegas
December 2012**

Copyright by Jonathan R Bailey, 2013

All Rights Reserved



THE GRADUATE COLLEGE

We recommend the thesis prepared under our supervision by

Jonathan R. Bailey

entitled

Investigating the Impacts of Conventional and Advanced Treatment Technologies on Energy Consumption at Satellite Water Reuse Plants

be accepted in partial fulfillment of the requirements for the degree of

Master of Science in Engineering

Department of Civil and Environmental Engineering

Jacimaria R. Batista, Ph.D., Committee Co-Chair

Sajjad Ahmad, Ph.D., Committee Co-Chair

Jose Christiano Machado, Ph.D., Committee Member

Yahia Baghzouz, Ph.D., Graduate College Representative

Tom Piechota, Ph.D., Interim Vice President for Research &
Dean of the Graduate College

December 2012

ABSTRACT

INVESTIGATING THE IMPACTS OF CONVENTIONAL AND ADVANCED TREATMENT TECHNOLOGIES ON ENERGY CONSUMPTION AT SATELLITE WATER REUSE PLANTS

by

Jonathan R Bailey

Dr. Jacimaria R. Batista, Examination Committee Co-Chair
Associate Professor
University of Nevada, Las Vegas

Dr. Sajjad Ahmad, Examination Committee Co-Chair
Associate Professor
University of Nevada, Las Vegas

With the ever increasing world population and the resulting increase in industrialization and agricultural practices, depletion of two of the world's most important natural resources, water and fossil fuels, is inevitable. Water reclamation and reuse is the key to protecting these natural resources. Water reclamation using smaller decentralized wastewater treatment plants, known as satellite water reuse plants (WRP), have become popular in the last decade. With stricter standards and regulations on effluent quality and requirements for a smaller land footprint (i.e. real estate area), additional treatment processes and advanced technologies are needed. This greatly increases the energy consumption of an already energy intensive process. With growing concerns over the use of nonrenewable energy sources and the resulting greenhouse gas (GHG) emissions, WRPs are in need of energy

evaluations. This research investigated the energy consumption of both conventional and advanced treatment processes in satellite WRPs with average flows varying from 1 to 11 MGD and was calculated using accepted industry design criteria and equations. The associated carbon footprint from energy consumption at these facilities was determined in carbon dioxide equivalents on a per MG treated basis. Renewable energy sources, solar and anaerobic digestion, were incorporated into the WRPs in an attempt to offset the energy consumption and GHGs emitted. Results of this research provide a means for engineers and operators to evaluate unit processes based on energy consumption and provide a foundation for decision making regarding sustainability of using advanced treatment technologies at the reuse facility.

ACKNOWLEDGEMENTS

I am very grateful to my parents, Debbie Bailey and Roy Wayne Bailey, my family, and my friends for their love and support throughout my life. I am also very thankful to my wonderful and beautiful wife, Lupe Gutierrez. If it was not for your love and support, especially during those long days and nights, this would never have been possible.

I would like to thank my advisors, Dr. Jacimaria Batista and Dr. Sajjad Ahmad, for all their advice, support, time, and tough love during my graduate career. If it was not for you two I would never have reached my full potential in my educational career.

I would also like to thank the great people at the Clark County Water Reclamation District for their support and knowledge during my graduate career. A special thanks is needed for LeAnna Risso and Jeff Mills. The internship you provided me at CCWRD has provided me with such vast knowledge and skills that I can use in all my future career endeavors.

Lastly, I would like to thank my committee members, Dr. Chris Machado and Dr. Yahia Baghzouz for their thorough and constructive reviews of my thesis.

This research was funded by the Clark County Water Reclamation District. Partial funding was also provided through the National Science Foundation (NSF) Award CMMI-0846952.

TABLE OF CONTENTS

ABSTRACT.....	iii
ACKNOWLEDGEMENTS	v
LIST OF TABLES	viii
LIST OF FIGURES	x
CHAPTER 1 INTRODUCTION.....	1
1. Objectives and Hypotheses	5
CHAPTER 2 ENERGY IMPACTS OF CONVENTIONAL AND ADVANCED TREATMENT TECHNOLOGIES AT SATELLITE WATER REUSE PLANTS AS A FUNCTION OF FLOW.....	6
1. Introduction	6
2. Methodology	12
2.1 Influent and Effluent Quality.....	14
2.2 Design Parameters and Considerations	14
3. Results and Analysis	26
4. Conclusion and Discussion	44
CHAPTER 3 IMPACTS OF ON-SITE RENEWABLE ENERGY GENERATION ON TOTAL ENERGY CONSUMPTION AND GREENHOUSE GAS EMISSIONS OF SATELLITE WATER REUSE PLANTS.....	47
1. Introduction	47
2. Methodology	52
2.1 Influent and Effluent Quality.....	55
2.2 Energy Consumption in Unit Processes of the Water Reuse Plant	55
2.3 Greenhouse Gas Production	56
2.4 Design Parameters and Considerations	57

3. Results and Analysis	60
4. Conclusion and Discussion	69
CHAPTER 4 CONCLUSIONS	72
APPENDIX A DESIGN PARAMETERS AND EQUATIONS FOR UNIT OPERATIONS AND ENERGY COMPUTATION EQUATIONS USED.....	77
REFERENCES	143
VITA.....	153

LIST OF TABLES

Table 1 – Plant Influent and Effluent Process Characteristics Used in the Design.....	14
Table 2 – WRP Design Parameters	16
Table 3 – Fine Screen Effective Open Areas and Removal Rates	19
Table 4 – Characteristics of Effluent from Fine Screening.....	20
Table 5 – Microbiological Parameters in Activated Sludge Process	20
Table 6 – Estimated Energy Consumption of Energy Driving Units in Water Reuse Plants of Varying Sizes.....	27
Table 7 – Energy Consumption of Each Unit Process per Unit Flow.....	38
Table 8 – Comparison of Energy Consumption per Unit Flow.....	38
Table 9 – Sensitivity Table of Low-End Combined Motor and Wire Efficiencies for Energy Driving Units at an 8.8 MGD Water Reuse Plant.....	41
Table 10 – Sensitivity Table of High-End Combined Motor and Wire Efficiencies for Energy Driving Units at an 8.8 MGD Water Reuse Plant.....	42
Table 11 – Plant Influent and Effluent Process Characteristics Found in the Water Reuse Plant	55
Table 12 – Energy Consumption per Unit Flow of Each Unit Process in a Satellite Reuse Plant.....	56
Table 13 – Photovoltaic Solar System and Anaerobic Digester Design Parameters	57

Table 14 – Estimated Energy Consumption and Generation of Anaerobic Digester and Photovoltaic Solar System in a Water Reuse Plant.....	61
Table 15 – Estimated Areas and System Size for PV Installation in Reuse Facilities with Advanced and Conventional Treatment Units.....	63
Table 16 – Energy Consumption and Generation per Unit Flow of the Anaerobic Digester and Photovoltaic Solar System	65
Table 17 – Cost Evaluation of Photovoltaic System and Anaerobic Digester with and without Incentives.....	66
Table 18 – Greenhouse Gas Emissions of Each Unit Process per Unit Flow	68

LIST OF FIGURES

Figure 1 – Population and Corresponding Number of Wastewater Treatment Facilities in the United States (U.S. EPA, 2008; U.S. EPA, 2004b).....	11
Figure 2 – Process Flow Diagram of the Water Reuse Plant for Which Energy Consumption is Evaluated.....	13
Figure 3 – Energy Consumption for Preliminary and Primary Unit Processes	29
Figure 4 – Energy Consumption for Secondary and Tertiary Unit Processes	33
Figure 5 – Energy Consumption for the Disinfection Unit Process	36
Figure 6 – Percentage of Total Energy Consumption of the Plant per Unit Process.....	43
Figure 7 – Process Flow Diagram of the Water Reuse Plant for Which Greenhouse Gas Emissions are Evaluated	54
Figure 8 – Energy Comparison of Advanced and Conventional Treatment Facilities with and without Incorporating Energy Generating Units	67
Figure 9 – Greenhouse Gas Emissions due to Electrical Energy Consumption with and without Energy Generating Units at 8.8 MGD.....	69

CHAPTER 1

INTRODUCTION

With the ever growing increase in the world's population and the resulting increase in industrialization and agricultural practices, the depletion of two of the world's most important natural resources, water and fossil fuels, is inevitable. Water is the most abundant resource in the world but with only one percent of the world's water resources being fresh water, this abundant resource needs to be protected (Urkiaga, et al., 2008). Water and wastewater collection, distribution, and treatment consumes two to four percent of the total power consumed in the United States (McMahon, et al., 2011; Daigger, 2009; U.S. EPA, 2010; Metcalf & Eddy, Inc, 2003; EPRI, 2002; WEF, 2010b); making the water and wastewater industry the third largest energy consumer, behind primary metals and chemicals. (McMahon, et al., 2011; EPRI, 2009). Thus, water and energy are intertwined resources. This current usage of energy requires between 100 and 123.45 billion kWh each year (U.S. EPA, 2010; EPRI, 2009) and emits roughly 116 billion lbs (52 million metric tonnes) of carbon dioxide (CO₂) into the atmosphere (McMahon, et al., 2011; NRDC, 2009). Due to the increase in population, higher levels of treatment mandated by regulations, and the employment of advanced technologies to treat to higher treatment levels, it has been estimated that during the next 15 years wastewater loads are expected to increase by 20% (U.S. EPA, 2008); resulting in an increase of 30 to 40% in energy consumption for wastewater treatment facilities during the next 20 to 30 years in the country (Metcalf & Eddy, Inc, 2003).

Ways to curb the large energy consumption in wastewater treatment plants (WWTP) has been an upcoming topic of interest. There are at least two ways to decrease energy use within an existing WWTP: (1) the increase of efficiencies in plant equipment; (2) and the optimization of plant processes and equipment. There is however a limit to how much energy within an existing plant can be curbed, because current design requires a minimum amount of energy to run installed processes and equipment. As a result, new approaches are needed to curb electrical energy consumption, not only for existing WWTPs but also for future planned plants.

Fossil fuels represent between 80-84% of the world's electrical energy supply today (Demirbas, 2009; Gude, et al., 2010). At this current consumption rate, known petroleum reserves are projected to be depleted in less than 50 years (Demirbas, 2009; Gude, et al., 2010). There are two main downsides for the use of fossil fuels as energy: all types of fossils fuels are finite resources; and the production of energy from fuels produce large amounts of greenhouse gas (GHG) emissions. In WWTPs, consumption of electric power accounts for about 90% of the total energy consumption in a plant (Mizuta, et al., 2010). Thus, the increasingly large amount of energy consumption from WWTPs greatly contributes to the production of GHG emissions. These emissions are subsequently resulting in crucial environmental problems worldwide, including acid rain and global warming (Gude, et al., 2010). One way to help curb GHG emissions is to conserve energy consumed in WWTPs, as mentioned. Additionally, GHG emissions can be minimized by implementing renewable energy resources in WWTPs.

Currently, renewable energy only represents a 14-16% total of the world's energy. This number has been projected to reach 48-50% by the year 2040 (Demirbas, 2009;

Gude, et al., 2010). There are a number of WWTPs that have integrated renewable energy sources (i.e. solar energy and biosolids digestion) as a part of their power grid (Bernier, et al., 2011; Gude, et al., 2010). Most of these plants incorporated these sources of energy as part of their renewable energy portfolio that was established by state regulations. To increase the percent of total energy that plants can use from renewable sources, energy considerations must be introduced during the design phase. With the cost and depletion of fossil fuels rapidly rising (Mizuta, et al., 2010; Brandt, et al., 2011), the need to conserve energy and transition from fossil fuels to renewable energy has now become a necessity not a luxury.

It is expected that by the year 2025, the percentage of the world population that lives in water short/stressed environments will increase by 45% (Daigger, 2009). Water reclamation and reuse is the key to protecting this natural resource. Water reclamation and reuse has been practiced in the form of wastewater treatment by the use of WWTPs. Reuse water can be used for a variety of applications including irrigation, recreational uses, groundwater recharge, nonpotable reuse, and potable reuse (Metcalf & Eddy, Inc, 2007; Tchobanoglous, et al., 2004; Metcalf & Eddy, Inc, 2003). WWTPs are generally centralized plants that treat wastewater collected from the entire community. Typically, wastewater treated in centralized facilities is discharged into a receiving water body (e.g. river or lake). In recent decades, smaller decentralized wastewater treatment plants, termed satellite water reuse plants (WRP) or scalping plants, have become very prevalent. WRPs are satellite treatment facilities that treat wastewater from a specific part of a community and reuse the effluent in or around the location where the wastewater was collected. This practice allows for conservation of freshwater because reuse water is

utilized instead. Because of the close proximity and/or potential direct contact of reclaimed water with the general public, regulations and effluent standards for reuse water are strict and are becoming stricter (Crook, 2011). To achieve these stricter standards on effluent quality and a smaller real estate area, additional treatment processes along with advanced technologies are needed (Bennett, 2007; EPRI, 2002; Brandt, et al., 2011; Urkiaga, et al., 2008).

The use of advanced treatment technologies to treat reuse water requires a large increase in energy consumption compared to conventional unit processes. In the past, energy consumption and GHG generation has not been a concern in reuse plant design. However, the current efforts to minimize GHG emissions and related energy footprint challenges the actual benefits of reuse plants. With the increase in WRPs and the use of advanced treatment technologies rising, energy consumption within these facilities must be evaluated. Research on energy consumption has been performed for many centralized WWTPs in specific sites (Sobhani, et al., 2011) and for whole regions (Mizuta, et al., 2010; Yang, et al., 2010). In addition, energy consumption research has been performed on specific individual unit processes and equipment (Messenger, et al., 2011; Pellegrin, et al., 2011; Brandt, et al., 2011). However, a complete evaluation of energy consumption in WRPs has not been reported to date, as compared to centralized plants. In this research, a typical WRP is designed and its associated energy consumption was estimated based on major energy consuming units. In addition, associated GHG emissions from electrical energy consumption and the renewable energy potential of the WRP is determined to evaluate the savings in GHG emissions.

1. Objectives and Hypotheses

The specific objectives and hypotheses of this research are:

1. To design a satellite WRP for varying flowrates and determine the associated energy consumption and carbon footprint for each individual unit process of the entire plant. To determine the impact on energy consumption when replacing advanced treatment processes with conventional treatment processes. It is expected that advanced treatment units will consume more energy; however, the magnitude of the difference remains to be determined.
2. To determine the associated renewable energy benefit from incorporating renewable energy sources (e.g. solar and biosolids digestion) into the previously designed WRPs. This involves incorporating renewable energy sources onto the existing real estate acreage of the WRP. WRPs are compact and do not have extensive space for photovoltaic (PV) solar system installation, however it is expected that at least some fraction of the energy consumption can be met by implementing renewable sources. Sludge digestion is also expected to contribute to meeting some of the energy consumption.
3. To compare energy footprint and associated real estate area needed of advanced treatment technologies versus conventional treatment technologies required for conventional activated sludge (CAS) and membrane bioreactor (MBR) as treatment processes in WRPs. Advanced treatment with MBRs are generally more compact, therefore savings in real estate area needed is expected.

CHAPTER 2

**ENERGY IMPACTS OF CONVENTIONAL AND ADVANCED TREATMENT
TECHNOLOGIES AT SATELLITE WATER REUSE PLANTS AS A FUNCTION
OF FLOW**

1. Introduction

The depletion of two of the world's most important natural resources, water and fossil fuels, has become difficult to control due to population growth that has resulted in increased industrialization and agricultural practices. Currently, with only one percent of the world's water resources being fresh water, this abundant resource needs to be protected (Urkiaga, et al., 2008). Water reclamation and reuse is the key to protecting this natural resource. Water reclamation has been practiced in the form of wastewater treatment plants (WWTP) using centralized treatment facilities located at low elevations to allow gravity collection of wastewater from the metropolitan area. In the United States, applications of water reuse in order of descending water volumes are: agricultural irrigation, industrial recycling and reuse, landscape irrigation, groundwater recharge, recreational and environmental uses, nonpotable urban uses, and finally potable reuse (Leverenz, et al., 2011; Metcalf & Eddy, Inc, 2007; Tchobanoglous, et al., 2004).

Direct potable reuse is not practiced in the United States, except for reuse after groundwater recharge. An example is Orange County, California, where treated wastewater effluent discharges into aquifer recharge basins into the county's groundwater basin that is used for potable purposes (Metcalf & Eddy, Inc, 2007; Orange County Water District, 2012; Tchobanoglous, et al., 2011). Internationally, water reuse is being

practiced in a similar fashion as in the United States, including in China (Yi, et al., 2011), Japan (Kazmi, 2005; Asano, et al., 1996), Europe (Bixio, et al., 2006; Angelakis, et al., 2008), and Africa (Ilemobade, et al., 2008).

Two areas leading the way in water reuse worldly are Singapore and Windhoek, Namibia. In Singapore, high-grade reclaimed water (NEWater), is used for several nonpotable reuse applications, but most importantly for planned indirect potable reuse (Public Utilities Board, 2012; Daigger, 2009). This is accomplished by mixing NEWater with raw water before sending through a drinking water treatment facility (Public Utilities Board, 2012; Onn, 2005). In Windhoek, Namibia direct potable reuse has been practiced since 1968, due to arid desert climate, lack of nearby rivers, and low groundwater (Metcalf & Eddy, Inc, 2007; Tchobanoglous, et al., 2011; du Pisani, 2006). The highly-treated reclaimed water is blended directly into the potable pipeline that feeds to the water distribution network of the city (Metcalf & Eddy, Inc, 2007; Tchobanoglous, et al., 2011). Windhoek is the only area in the world that operates and practices direct potable reuse of reclaimed wastewater (du Pisani, 2006; Metcalf & Eddy, Inc, 2007).

The reuse of water has been limited through time due to the lack of risk assessment, incentives, and public perception (Urkiaga, et al., 2008; Hartley, 2006). Public perception has been a major obstacle in the progression of water reuse, primarily because of the “yuck factor” (Hartley, 2006). The “yuck factor” can be avoided if reuse water does not come in direct contact with the public (Hartley, 2003; Toze, 2006). Thus, reuse applications today are limited to noncontact, non-potable use. Risk assessment has been a continuous research topic since the beginning of water reclamation, and especially recently with developing concerns over endocrine disrupting compounds and

pharmaceutically-active compounds (Toze, 2006; Salgot, et al., 2006; Cleary, et al., 2011; Huertas, et al., 2008). Through each study, new progress has been made requiring stricter standards (Crook, 2011) by governing bodies (e.g. World Health Organization (WHO) (WHO, 2006), United States Environmental Protection Agency (USEPA) (U.S. EPA, 2004a), and state regulatory agencies (U.S. EPA, 2004a)). To achieve these stricter standards of effluent quality, additional treatment processes along with new technologies are needed (Bennett, 2007; EPRI, 2002; Brandt, et al., 2011; Urkiaga, et al., 2008). This factor has led the use of high performance advanced treatment processes, which in turn drive up the energy consumption and price of reuse water.

In the last decade, to overcome the obstacle of cost, decentralized wastewater management (DWM) has become the norm. DWM is defined by Tchobanoglous, et al. (2004) as “the collection, treatment, and reuse of wastewater from individual homes, cluster of homes, subdivisions, and isolated commercial facilities at or near the point of waste generation”. By means of using DWM, development of small WWTPs known as water reuse plants (WRP) have become popular, especially in the last decade (Metcalf & Eddy, Inc, 2007). WRPs are satellite treatment facilities typically located near potential reuse applications in urban areas and integrated with a centralized treatment facility. This allows WRPs to be strategically placed throughout an urban community where reuse demand is needed (Daigger, 2009).

WRPs are small in stature as their effluent is treated to non-potable reclamation grade water and all solids/residuals produced during the biological treatment are discharged back into the collection system for processing at the centralized treatment facility (Metcalf & Eddy, Inc, 2007; Daigger, 2009; Tchobanoglous, et al., 2004).

Therefore, reuse plants do not include thickening and dewatering units for solids handling. An extraction type collection system can provide a steady state flow throughout a WRP (Metcalf & Eddy, Inc, 2007; Crites, et al., 1998; Daigger, 2009). This flow is obtained by diverting a specific amount of flow from an adjacent collection system. This is known as sewer mining (Daigger, 2009; Fane, et al., 2005; WEF, 2006). All these factors help keep the land footprint (i.e. real estate area) of WRPs as minimal as possible. As a result of these advantages of WRPs and the use of high performance advanced treatment technologies, many water-short urban communities worldwide have incorporated these facilities in their municipality.

For WRPs to achieve the strict effluent standards and regulations, as well as keeping the real estate area of the facility to a minimal, advanced treatment technologies are needed throughout the plant. These advanced technologies replace traditional treatment processes and are only a fraction of the size using a much smaller real estate area, but achieve the same, or higher, removal rates (Metcalf & Eddy, Inc, 2007; Metcalf & Eddy, Inc, 2003; Davis, 2010; WEF, 2008; WEF, 2006). With the use of DWM and the employment of high-performance treatment technologies, WRPs are helping to further the transition from large centralized WWTPs (Daigger, 2009).


In 2010, prime energy consumption in the world was 153 trillion kWh (522 quadrillion Btu) per year (U.S. EIA, 2011a). Of this consumption, the United States used 28.7 trillion kWh (97.8 quadrillion Btu) (U.S. EIA, 2011a), roughly 18.7% of the world's consumption. Electrical energy consumption in the United States accounted for 4.15 trillion kWh (U.S. EIA, 2011b), 14.5% of their total energy consumption. Two to four percent of this consumption, roughly 83 to 166 billion kWh, is processed through

collecting, distributing, and treating wastewater and drinking water (McMahon, et al., 2011; Daigger, 2009; U.S. EPA, 2010; Metcalf & Eddy, Inc, 2003; EPRI, 2002; WEF, 2010b). The combination of both municipal wastewater treatment and water supply systems makeup an average of 35% of the total energy consumed by municipalities (McMahon, et al., 2011; U.S. EPA, 2008; NRDC, 2009), but can be as much as 60% (WEF, 2010b). The USEPA reports that in 1996 the water and wastewater industry used 75 billion kWh of energy (U.S. EPA, 2008; U.S. EPA, 2010) and is estimated to consume between 100 and 123.45 billion kWh of energy in 2010 (U.S. EPA, 2010; EPRI, 2009). This consumption of energy currently emits roughly 116 billion lbs (52 million metric tonnes) of carbon dioxide (CO₂) into the atmosphere (McMahon, et al., 2011; NRDC, 2009). Current data show and supports this increase in energy consumption with the number of facilities and the percent of population served by secondary treatment are decreasing while the use of advanced wastewater treatment is increasing (Figure 1). Due to the increase in population, more stringent water quality regulations, and the development of advanced treatment technologies to treat to the desired level of treatment, it has been estimated that during the next 15 years wastewater loads are expected to increase by 20% (U.S. EPA, 2008) and during the next 20 to 30 years energy consumption for wastewater treatment facilities are expected to increase by 30 to 40% in the United States (Metcalf & Eddy, Inc, 2003).

The use of advanced treatment technologies to treat reuse water requires a large increase in energy consumption compared to conventional treatment. In the past, energy consumption has not been a concern in reuse plant design. However, the current efforts to minimize energy footprint challenge the actual benefits of reuse plants. With the

increase in WRPs and the use of advanced treatment technologies rising, energy consumption within these facilities must be evaluated. In this research, a typical WRP located in the Southwestern United States was designed and an evaluation of the facility's associated energy consumption was performed based on major energy consuming units for both advanced and conventional treatment processes. The plant produces reuse water that is used for golf course irrigation. In this research, the impacts of advanced treatment processes and varying wastewater flowrates on the energy consumption in a typical satellite water reuse plant were investigated.

Figure 1 – Population and Corresponding Number of Wastewater Treatment Facilities in the United States (U.S. EPA, 2008; U.S. EPA, 2004b)



*For 1972 and 1996, partial treatment facilities are included in less than secondary

2. Methodology

To estimate the potential energy consumed in the WRP, a typical satellite WRP in the Southwestern United States was designed with focus on the energy consuming units of each process. The process flow diagram of the WRP is shown in Figure 2 and includes, in order of treatment: coarse screen, aerated grit chambers, fine screen, bioreactor system, membranes, and UV disinfection. Since there are no solids processing on site, all screenings, grit, and biosolids are discharged back into the collection sewer trunk. In the design, a five-stage modified Bardenpho CAS system is provided for the removal of the nutrients phosphorous and nitrogen (WEF, 2012; WEF, 2011). The design provides for carbonaceous BOD removal, NH_3 oxidation, denitrification through endogenous respiration, and biological phosphorous removal through PAOs. For this reuse plant, stringent nutrient removal is required because during winter, when golf course irrigation needs are less, the effluent could be discharged into an environmentally sensitive lake, where algal blooms avoidance is a goal. The WRP was designed using design recommendations and WWTP design equations from various sources (Metcalf & Eddy, Inc, 2003; WEF, 2010a; Qasim, 1999; Davis, 2010; Lin, 2007; WEF, 2012). The size of each unit process was determined using Microsoft Excel spreadsheet for the various scenarios under consideration. Once designed, the energy consuming unit of every unit process was identified and the expected energy consumption for each unit was computed. Next, advanced treatment processes were replaced with more traditional unit processes to evaluate the changes in energy consumption. The MBR system was redesigned to include a traditional CAS bioreactor with secondary clarification and dual media filters. Then UV disinfection was replaced with traditional chlorination.




Figure 2 – Process Flow Diagram of the Water Reuse Plant for Which Energy Consumption is Evaluated

2.1 Influent and Effluent Quality

The influent characteristics and effluent requirements for the WRP are depicted in Table 1. The requirements are typical water reuse standards found in California and Florida (U.S. EPA, 2004a), with the exception for the need to remove nutrients.

Table 1 – Plant Influent and Effluent Process Characteristics Used in the Design

Parameter	Influent Characteristics	Effluent Requirements
BOD (mg/L)	250	30
TSS (mg/L)	309	30
TKN (mg/L as N)	42	–
NH ₃ (mg/L as N)	34	0.5
TN (mg/L as N)	–	10
TP (mg/L as P)	8	0.2
TC (MPN/100 mL)	–	2.2
TC, daily max (MPN/100 mL)	–	23
Minimum Temp (°C)	18.3	18.3

2.2 Design Parameters and Considerations

Typical design criteria used to size each unit process are shown in Table 2. Unit processes included reported in the table include those shown in the process diagram (Figure 2) and additional ones used for energy consumption comparison. Design values in the table are typical of values reported in the design literature. All process were designed taking peak flows into consideration, however, energy consumption computations are for monthly average flow conditions. A maximum day and peak hour factors of 1.09 and 1.49 were used in the design, respectively. Peak flows in the facility

are to allow for extra capacity during mid day when irrigation cycles happen more frequently. The designs for each unit process are discussed below. Complete design methodology and details are found in Appendix A.

Table 2 – WRP Design Parameters

	Parameter	Value	Unit	Reference(s)
<i>Coarse Screens</i>	Bar Width	0.375 (9.53)	in (mm)	1, 2, 3
	Bar Spacing	0.75 (19.05)	in (mm)	1, 2, 3
	Headloss at Peak Flow – Clean	0.15 (45.72)	ft (mm)	4
	Headloss at Peak Flow – Clogged	1.13 (344.42)	ft (mm)	4
<i>Grit Chamber</i>	HRT at Peak Flow	4.5	min	1, 2, 3, 4
	Air Supply per Unit Length	8 (0.74)	cfm/ft (m ³ /m/min)	1, 3, 4
<i>Fine Screens</i>	Perforation Size	7.87E-2 (2)	in (mm)	4, 5, 6
	Headloss at Peak Flow – Clean	2.17 (661.42)	ft (mm)	1, 4
<i>Activated Sludge</i>	Solids Retention Time	10	day	7
	Internal Mixed Liquor Recycle (IMLR)	200	%	4, 5, 8
<i>Membrane</i>	RAS Recycle Ratio	400	%	4, 5, 6
	Net Flux at Peak-day	13.5 (22.9)	gal/ft ² /day (L/m ² ·hr)	7
	Air Scour Flowrate at Peak-day	11.77 (20)	scf/min (Nm ³ /hr)	6
<i>Secondary Clarifiers</i>	Surface Overflow Rate at Average Flow	698 (1.19)	gpd/ft ² (m ³ /m ² ·hr)	1, 4, 9
	Solids Loading Rate at Average Flow	21.8 (106.4)	lb/day·ft ² (kg/m ² ·day)	1, 4, 9
<i>Dual Media Filters</i>	Dual Media Filtration Rate	5 (0.2)	gpm/ft ² (m ³ /m ² ·min)	10
	Dual Media Backwash Rate w/Air Scour	9.4 (0.38)	gpm/ft ² (m ³ /m ² ·min)	1, 4
	Dual Media Backwash Air Flow Rate	3.5 (1.07)	ft ³ /ft ² ·min (m ³ /m ² ·min)	1, 4
<i>UV Disinfection</i>	Minimum UV Dosage – Membrane Effluent	80	mW·s/cm ²	1, 4, 11, 12, 13
	Minimum UV Dosage – Filter Effluent	100	mW·s/cm ²	13
<i>Chlorination</i>	Minimum Chlorine Contact Time	450	mg·min/L	4
	HRT at Peak Flow	30	min	1

1 ~ (Metcalf & Eddy, Inc, 2003); 2 ~ (Davis, 2010); 3 ~ (Qasim, 1999); 4 ~ (WEF, 2010a); 5 ~ (WEF, 2006); 6 ~ (WEF, 2012); 7 ~ (Menniti, et al., 2011); 8 ~ (WEF, 2011); 9 ~ (WEF, 2005); 10 ~ (GLUMRB, 2004); 11 ~ (Metcalf & Eddy, Inc, 2007); 12 ~ (U.S. EPA, 2004a); 13 ~ (NWRI, 2012)

2.2.1 Influent Channel and Coarse Screens

The design of the rectangular open channel leading to the coarse screens was based on the Manning's equation, with a Manning's coefficient of 0.015 (Sturm, 2010). Velocity in the designed channel exceeds 1.3 ft/sec (0.4 m/s) during minimum flow to avoid grit deposition or 3 ft/sec (0.9 m/s) was maintained during peak flows to ensure resuspension of solids (WEF, 2010a). Key parameters used in the design of the coarse screens are shown in Table 2. The headloss through the screens was calculated using both the modified minor loss headloss equation and the Kirshmer's equation (Metcalf & Eddy, Inc, 2003; WEF, 2010a). The higher headloss value governed the design. Energy consumption for the coarse screens is driven by the size of the motor that powers the rake and the rake cleaning frequency. Based on channel and screen dimensions, a motor size for the rake was obtained using a graphical method provided by a screen manufacturer (Vulcan Industries, Inc, 2011).

2.2.2 Aerated Grit Chamber

Parameters used in the design of the aerated grit chamber can be found in Table 2. The hydraulic retention time (HRT) was determined for the desired peak flowrate with a depth, width-depth ratio, and length-width ratio chosen in the range of design criteria (Metcalf & Eddy, Inc, 2003; WEF, 2010a; Qasim, 1999). Energy consumption for the aerated grit chamber is driven by the air blower capacity used to maintain discrete particle sedimentation and can be estimated by the following equation (U.S. EPA, 1989):

$$BHP = [(4.28E - 4)q_s T_a / e]^* [(P_d / P_b)^{0.283} - 1] \quad (1)$$

where BHP = brake horsepower, hp; q_s = required flow rate, scfm; T_a = blower inlet air temperature, °R; e = blower and motor combined efficiency; P_d = blower discharge

pressure, psia (the addition of atmospheric pressure and the system head); and P_b = field atmospheric pressure, psia. System head was estimated as per (U.S. EPA, 1989) using headloss values for diffuser (0.70 psi; 4.826 kPa), piping (0.15 psi; 1.034 kPa), and inlet valve and filter headloss (0.30 psi; 2.068 kPa). Atmospheric pressure at 2,000 feet (609.6 meters) elevation was used and a combined blower and motor efficiency of 80% were assumed (Metcalf & Eddy, Inc, 2003; Davis, 2010).

2.2.3 Fine Screens

Design considerations for the open channel preceding the fine screens are the same as for the open channel before the coarse screens. Parameters used in the design for the fine screen can be found in Table 2. The headloss across the screen was determined using the modified orifice headloss equation (Metcalf & Eddy, Inc, 2003; WEF, 2010a). A blinding factor of up to 50% was applied to determined clogged screen headloss (WEF, 2010a). Typical effective open areas for fine screens and their corresponding solid removal rates are shown in Table 3. Energy consumption for the fine screens was computed using the same procedure as for the coarse screens, except that the raking is continuous.

Table 3 – Fine Screen Effective Open Areas and Removal Rates

Hole Spacing (mm)	Open Area (%)	Percent Solids Removal (%)	Reference(s)
9	55	–	(Davis, 2010)
6	40-51	73-81	(Davis, 2010; Cluin, 2011; Mackie, et al., 2007)
3	35-40	84-93	(Davis, 2010; Cluin, 2011; Mackie, et al., 2007)
2	30	–	(Cluin, 2011)
1	31	–	(Davis, 2010)

2.2.4 Activated Sludge

Both a CAS system and a MBR system were considered in this study. A five-stage modified Bardenpho CAS system is provided for nutrient removal of both phosphorous and nitrogen (WEF, 2012; WEF, 2011). The BOD and solids removal by the coarse and fine screens were based on data provided by manufacturers (Table 4) (Huber Technology, 2008; Mackie, et al., 2007). Design and biological treatment parameters used in the activated sludge design are depicted in Table 2 and Table 5, respectively. Design equations used for the activated sludge process are those provided by Rittmann, et al. (2001).

Table 4 – Characteristics of Effluent from Fine Screening

Parameter	Value	Unit
BOD	125	mg/L
BOD_L	187.5	mg/L
TSS	61.8	mg/L
Volatile portion of TSS	81	%
VFA	43	mg/L
TKN	42	mg/L as N
TP	4.68	mg/L as P

Table 5 – Microbiological Parameters in Activated Sludge Process

Parameter (Unit)	BOD Heterotrophic Microorganisms	Nitrification Microorganisms (Nitrosomonas)	Nitrification Microorganisms (Nitrobacter)	Denitrification Microorganisms (Pseudomonas)	Phosphorous Accumulating Organisms
K (mg BOD _L /L)	10 ¹	1 ¹	1.3 ¹	12.6 ²	1 ¹
Y (mg VSS/mg BOD _L)	0.45 ¹	0.33 ¹	0.083 ¹	0.26 ¹	0.3 ³
\hat{q} (mg BOD _L /mg VSS-day)	20 ¹	2.3 ¹	9.8 ¹	12 ¹	3.17 ¹
$\hat{\mu}$ (mg VSS/mg VSS-day)	9 ¹	0.76 ¹	0.81 ¹	3.12 ¹	0.95 ^{3, 4}
b (mg VSS/mg VSS-day)	0.15 ¹	0.11 ¹	0.11 ¹	0.05 ¹	0.04 ³
f_d (-)	0.8 ¹	0.8 ¹	0.8 ¹	0.8 ¹	0.8 ¹
$[\theta_x^{\min}]_{lim}$ (day)	0.11299	1.54083	1.42167	0.32573	1.09890

Parameters: K = concentration giving one-half the maximum rate; Y = true yield for cell synthesis; \hat{q} = maximum specific rate of substrate utilization; $\hat{\mu}$ = maximum specific growth rate; b = endogenous-decay coefficient; f_d = fraction of active biomass that is biodegradable; $[\theta_x^{\min}]_{lim}$ = absolute minimum SRT for steady-state biomass

References: 1 ~ (Rittmann, et al., 2001); 2 ~ (U.S. EPA, 1993); 3 ~ (WEF, 2011); 4 ~ (Metcalf & Eddy, Inc, 2003)

In an activated sludge MBR system, return activated sludge (RAS) rates are typically higher compared to CAS process. For a MBR system, RAS rates are typically 200 to 500% of the average influent flow, versus 50 to 100% in CAS systems (WEF, 2012; WEF, 2010a; WEF, 2006). These systems also require a higher MLSS concentration compared to CAS systems. For a MBR system, the MLSS concentration inside the bioreactor tank can be between 4,000 to 10,000 mg/L and inside the membrane tank 8,000 to 18,000 mg/L, versus 1,500 to 3,500 mg/L in CAS systems (WEF, 2012; WEF, 2006; WEF, 2010a). Due to these higher MLSS concentrations (Fabiyyi, et al., 2008), a decreased alpha factor, or oxygen transfer efficiency of diffused air, of 0.5 results for MBR facilities with MLSS concentrations around 10,000 mg/L (Germain, et al., 2007). For CAS facilities with nitrification and denitrification, an alpha factor of 0.7 was used (Rosso, et al., 2006). The alpha factor is not only affected by solid concentrations inside the basin but also the type of treatment, due to low molecular weight surfactant uptake in the anoxic zone (Rosso, et al., 2006). Energy consumption for the activated sludge process is driven by mixers used to maintain particles suspension in the anaerobic and anoxic zones of the biological nutrient removal system, and blowers used to provide oxygen and particle suspension in the aerated zones. In addition, energy is required to operate the IMLR pumps and RAS pumps. Mixer energy requirement was determined based on the basin volume and the type of mixer. For horizontal mixers the required energy used was 7 W/m^3 (WEF, 2010a). Blower energy was determined using equation 1 and a combined blower and motor efficiency of 80% (Metcalf & Eddy, Inc, 2003; Davis, 2010). Energy requirements for pumps after they have been sized were determined as (Jones, et al., 2008):

$$BHP = \frac{qH}{3960E_p} \quad (2)$$

where BHP = brake horsepower, hp; q = required flow rate, gal/min; H = total dynamic head, ft; and E_p = pump efficiency. Efficiencies for both the IMLR and RAS pumps were chosen in ranges from pump data and curves. A pump efficiency of 80% was used for both pumps (Goulds Pumps, 2012).

2.2.5 Membranes

Parameters used in the design of the membrane portion of the MBR system can be found in Table 2. MLSS concentration inside the membrane tank was determined as per (WEF, 2012). The required membrane area needed inside the tank was determined using the net flux concept (WEF, 2012). Typical membrane parameters including membrane area per small subunit, number of small subunits per large subunit, and volume required per large subunits (WEF, 2012). The air scour cycle rates during average and peak-day flowrates were 10 sec on/30 sec off and 10/10, respectively (WEF, 2012). An online factor of 95% percent was also used to allow for relaxation intervals and maintenance cleaning (WEF, 2012). Energy consumption for the membranes is driven by air scour blowers, permeate pumps, backpulse pumps, and WAS pumps. The consumption of energy was calculated for the blower and pumps using equations 1 and 2, respectively. The combined and pump efficiencies used for both the blower and WAS pumps, respectively, were 80% (Metcalf & Eddy, Inc, 2003; Davis, 2010), and the pump efficiencies used for permeate and backpulse pumps were 70% (Goulds Pumps, 2012).

2.2.6 Secondary Clarifier

The alternative biological process used to contrast a MBR system was a traditional CAS system. The biological portion of the design is the same as for the MBR

system, except for the MLSS concentration, RAS ratio, and alpha factor as discussed above. This would require a doubling in aeration volume compared to the MBR system's biological process. The membranes are replaced with secondary clarification and filtration to provide solid separation. Parameters used in the design of the secondary clarifier can be found in Table 2. The clarifier was sized using recommended overflow rates and solids loading rates as per (Metcalf & Eddy, Inc, 2003; WEF, 2010a; WEF, 2005). Design was performed for both peak and average flow, with the highest value governing the design. Weir loading was checked for both average and peak flows to ensure the loadings were under recommended limits (WEF, 2005; WEF, 2010a). Energy consumption for the secondary clarifier is driven by the size of the motor that provides the torque for the rake arm and the WAS pump. The required power to move the rake arm was calculated using (WEF, 2005):

$$P = T\omega \quad (3)$$

where P = power required by the motor, W; T = required torque, J, $T = Wr^2$ where W = rake arm loading, N/m and r = radius of rake arm, m; and ω = angular velocity, rad/s. A rake arm loading value of 95 N/m was used and fell within the recommended range for secondary sludge (WEF, 2005). The energy requirement for the WAS pump was determined using equation 2. A pump efficiency of 80% was used (Goulds Pumps, 2012).

2.2.7 Dual Media Filters

Parameters used in the design of the dual media filters can be found in Table 2. The number and size of the filters were determined using (WEF, 2010a) and the filtration rate (GLUMRB, 2004). Filter sizes were rounded to the nearest increment of 25 square feet to allow for ease of construction. The filters were designed with one filter out of

service for backwashing cycles. The cleanwater headlosses were determined to be 0.81 and 1.45 feet for average and peak filtration rates, respectively, using the Rose equation (Metcalf & Eddy, Inc, 2003). Backwash cycles were design to be 36 hours, determined using solids holding capacity for clogged headloss determination (Metcalf & Eddy, Inc, 2003; WEF, 2010a). Energy consumption for the dual media filters is driven by the backwash blower and backwash pump, equations 1 and 2. A combined blower and motor efficiency of 80% was used for the backwash blower (Metcalf & Eddy, Inc, 2003) and a pump efficiency of 78% was used for the backwash pump (Goulds Pumps, 2012).

2.2.8 UV Disinfection

The parameters used in the design of the UV disinfection process can be found in Table 2. Two UV disinfection system designs were considered, low and medium-pressure. When designing the UV disinfection system with low-pressure UV lamps, a graphical point-source-summation method was used to determine the water quality factor and the effluent coliform number, using suspended solids concentrations and UV dosage, respectively (WEF, 2010a; U.S. EPA, 1986). Low-pressure high intensity lamps were assumed to have a maximum input power of 260 W with an efficiency of 33% (Metcalf & Eddy, Inc, 2003; Trojan Technologies, 2008). The variable output (dimming) capabilities of this lamp are from 60 to 100% (Trojan Technologies, 2008). For medium-pressure UV lamps, an equation based point-source-summation was performed for estimating the UV intensity (U.S. EPA, 1986). The required UV dose was determined as per (WEF, 2010a). To determine the effluent coliform number after exposure, a variation of the Chick-Watson first-order model was used (Metcalf & Eddy, Inc, 2003; WEF, 2010a; U.S. EPA, 1986). Medium-pressure high intensity were assumed having a

maximum input power of 3,200 W with an efficiency of 12% (Metcalf & Eddy, Inc, 2003; Trojan Technologies, 2007). The variable output capabilities of this lamp are from 30 to 100% (Trojan Technologies, 2007). The headloss through the UV channel was determined using the energy equation from (Metcalf & Eddy, Inc, 2003; Qasim, 1999).

2.2.9 Chlorination

The alternative disinfection process used to contrast UV disinfection was chlorination. Chlorination would follow membranes in the MBR facility and the dual media filters in the CAS facility. Parameters used in the design of the chlorination contact basin are depicted in Table 2. The chlorine dosage was determined using a modification of the Collins-Selleck model found in (Metcalf & Eddy, Inc, 2003). Membrane effluent total coliform bacterium has a typical range of 10 to 1000 MPN/100mL (Metcalf & Eddy, Inc, 2003; DeCarolis Jr, et al., 2007) and filter effluent total coliform bacterium has a typical range of 10^4 to 10^6 MPN/100mL (Metcalf & Eddy, Inc, 2003). The design assumed a chlorine residual of 3 mg/L leaving the facility. Dechlorination was not considered in this design because water is to be used for golf course irrigation. With a design scheme layout of the chlorine contact basin determined and sized, proper dispersion was evaluated using the axial dispersion equations found in Metcalf & Eddy, Inc (2003). Energy consumption for chlorination is driven by the size of the diaphragm pump used to inject chlorine before the contact basin. This energy requirement can be calculated using equation 2. A pump efficiency of 70% was used (Goulds Pumps, 2012).

3. Results and Analysis

Estimated energy consumption for major energy driving units of each process and for varying WRP flowrates are shown in Table 6.

Table 6 – Estimated Energy Consumption of Energy Driving Units in Water Reuse Plants of Varying Sizes


	Energy Driving Units	1 MGD Plant (kWh/day)	2 MGD Plant (kWh/day)	4 MGD Plant (kWh/day)	6 MGD Plant (kWh/day)	8.8 MGD Plant (kWh/day)	11 MGD Plant (kWh/day)
<i>Coarse Screens</i>	Rake Motor	1.16	1.16	1.16	1.16	1.16	1.73
<i>Grit Chamber</i>	Air Blowers	107.42	125.36	179.04	214.85	250.66	268.56
<i>Fine Screens</i>	Screen Motor	35.81	35.81	35.81	35.81	35.81	53.71
<i>Bioreactor</i>	Mixers	69.78	143.93	287.85	431.78	680.38	850.48
	Air Blowers	1038.43	2076.86	4153.73	6230.59	9166.85	11458.56
	IMLR Pumps	196.94	393.89	787.78	1181.66	1790.40	2238.00
	RAS Pumps	286.46	572.93	1145.86	1718.78	2506.56	3133.20
	Total	1591.61	3187.61	6375.22	9562.81	14144.19	17680.24
<i>Membranes</i>	Air Scour Blowers	646.33	1292.67	2585.34	3878.01	5170.68	6463.34
	Permeate Pumps	238.12	476.25	952.49	1428.74	2041.06	2551.32
	Backpulse Pumps	15.22	30.44	60.87	91.31	136.07	170.09
	WAS Pumps	4.48	8.95	17.90	26.86	35.81	44.76
	Total	904.15	1808.31	3616.60	5424.92	7383.62	9229.51
<i>Conventional Activated Sludge</i>	Mixers	69.78	143.93	287.85	431.78	680.38	850.48
	Air Blowers	751.97	1486.03	2972.06	4458.10	6517.06	8146.32
	IMLR Pumps	196.94	393.89	787.78	1181.66	1790.40	2238.00
	RAS Pumps	161.14	304.37	608.74	913.10	1360.70	1700.88
	Total	1179.83	2328.22	4656.43	6984.65	10348.54	12935.68
<i>Secondary Clarifier</i>	Rake Arm Torque	4.48	4.48	8.95	13.43	17.90	22.38
	WAS Pumps	4.48	8.95	17.90	26.86	35.81	44.76
	Total	8.96	13.43	26.85	40.29	53.71	67.14
<i>Dual Media Filters</i>	Backwash Blower	1.46	2.92	4.38	5.84	8.22	10.28
	Backwash Pump	3.58	7.10	10.64	14.19	20.16	25.20
	Total	5.04	10.02	15.02	20.03	28.38	35.48
<i>UV Disinfection – Membrane Effluent</i>	Low-Pressure, High Intensity	98	210	404	584	839	1078
	Medium-Pressure, High Intensity	590	1181	2362	3542	5184	6480
<i>UV Disinfection – Filter Effluent</i>	Low-Pressure, High Intensity	138	276	539	832	1229	1475
	Medium-Pressure, High Intensity	960	1920	3816	5760	8496	10685
<i>Chlorination – Membrane Effluent</i>	Pump	4.48	4.48	4.48	4.48	4.48	4.48
<i>Chlorination – Filter Effluent</i>	Pump	4.48	4.48	4.48	4.48	4.48	4.48

Preliminary and Primary Treatment Units

Preliminary and primary treatment units include coarse screens, aerated grit chamber, and fine screens. The energy consumption by the fine screens in the reuse plants are about thirty-one times that consumed by the coarse screens, due to the fine screens being continuously run. However, the energy consumed by both screens is small relative to that consumed by other unit processes. On average, both screens together require 0.72% of the plant's total energy consumption. For flowrates varying from 1 to 8.8 MGD (Figure 3a), energy consumption for both processes are constant until a flowrate above 8.8 MGD is reached. This is the case because in order to remove large debris from screens a minimum motor size must be used, independent of the flowrate (Vulcan Industries, Inc, 2011). The Water Environment Federation (WEF, 2010b) reports energy consumption for coarse screens are equal to 2 kWh/d for flows between 1 to 10 MGD and increases at larger flows (WEF, 2010b). In this research, values of 1.16 to 1.73 kWh/day were found and are similar to the values and pattern reported by WEF, 2010b. Malcolm Pirnie (1995) reports that a 0.39 MGD facility uses 17.53 kWh/day for fine screens and 96.89 kWh/day for a 2.85 MGD facility. A value of 35.81 kWh/day was found in this research at 1 MGD, which is roughly two times the value found at the 0.39 MGD facility.

The energy consumption in the aerated grit chamber is a function of flowrate treated and it increases initially and tapers down resulting in a decreasing slope as flow increases (Figure 3b). This behavior occurs due to the chosen design depth used in the chamber. Design depth increases rapidly at lower flow ranges, 1 – 4 MGD, and begins to steady at flow ranges above 6 MGD; indicating depth is directly related to the energy

consumption. The increase in energy is directly proportional to the required air flowrate needed by the air blower and it reflects the amount of air supply needed per unit length of the grit chamber. It has been reported that energy consumption in aerated grit chambers is about 77.5 (WEF, 2010b) and 56.2 (Smith & Loveless, 2007) kWh/day at 4 MGD. In this research, the estimated consumption is 174.04 kWh/day, which is 2.2 to 3.1 times greater than the reported values. These differences can be due to variations in the amount of air supply per unit length used in the design. In this design, a recommended high air flowrate of 8 cfm/ft (0.74 m³/m/min) was used. If the system were designed for the recommended lower range of air flowrate (3 cfm/ft), the energy consumption would be 71.62 kWh/day, falling within the values reported above. There is no theoretical way to determine the exact blower output required thus, variations will be observed for different designs (WEF, 2010b).



*Flows through the screening and aerated grit chamber processes are 1 MGD higher than indicated in the text, as this flow is assumed to be wasted due to screenings and grit removal

Figure 3 – Energy Consumption for Preliminary and Primary Unit Processes: (a) Coarse and Fine Screen Energy Consumption Versus Flow; and (b) Aerated Grit Chamber Energy Consumption Versus Flow

Secondary and Tertiary Treatment Units

Secondary and tertiary treatment units include: bioreactor and membrane filters for a MBR facility; and CAS bioreactor process, secondary clarifier, and dual media filters for a CAS facility. The energy consumption for secondary and tertiary treatment unit processes are shown in Figure 4a to 3d. The air requirements in the basins were estimated as 1,038.43 kWh/day at 1 MGD for a MBR facility and 751.97 kWh/day for a CAS facility. At this same flowrate WEF (2010b) reports a value of 878 kWh/day, which is about 15.4% lower than the value estimated by this research for the MBR facility and 14.4% higher for the CAS facility. It is known that energy consumption in biological treatment units is affected by wastewater strength (i.e. BOD and ammonia loadings). However, in this research, the impacts of wastewater loading on energy consumption in the bioreactors were not evaluated. Therefore, comparisons with reported literature are based on flowrates only. For flowrates between 1 – 11 MGD, the energy consumption of the air blowers on average was 65.1% of the total biological process energy consumption for MBR facilities and 63.5% for CAS facilities. IMLR and RAS pumps required 12.5 and 17.9% of the total biological energy consumption for the MBR facilities and 17.0 and 13.2% for CAS facilities. Aerobic and anoxic mixers were on average 4.6% for MBR and 6.7% for CAS. In comparing the biological bioreactor process and CAS bioreactor process, the difference in energy consumptions relates mainly to the RAS pumps and air blowers. It was estimated that the RAS pumps required 2,506.56 and 1,360.70 kWh/day of energy for MBR and CAS facilities at 8.8 MGD, respectively (Table 6). The higher energy consumption for MBR facilities is due to the high recycle rates needed in the

MBR process. In CAS facilities, the high energy consumption is dependent of the TDH difference related to the position of the RAS pumps and the clarifiers; however, the impact of the recycle in the MBR process is much greater. For flowrates between 1 – 11 MGD, the MBR facilities were found on average to require 1.85 times more consumption of energy in RAS pumping. The air blowers at 8.8 MGD required 9,166.85 kWh/day for MBR facilities and 6,517.06 kWh/day for CAS facilities. This increase for MBR facilities was on average 1.4 times the amount of energy needed at CAS facilities. This is a result of a decreased alpha factor (oxygen transfer efficiency of diffused air) of 0.5 (Germain, et al., 2007) in MBR facilities, as compared to 0.7 (Rosso, et al., 2006) in CAS facilities. The different alpha factor is a result of the higher solids concentrations maintained in MBRs (Fabiyyi, et al., 2008).

Comparing the membrane with the secondary clarifier and dual media filter for secondary filtration, it can be observed that the membrane process requires a very large amount of energy (7,383.61 kWh/day), while the secondary clarifier and dual media filter processes requires less (82.09 kWh/day) at 8.8 MGD, which comprises about 1% of that consumed by the membrane process for flowrates between 1 – 11 MGD on average. The reason for this is due to the required pumping and blowers needed to run and maintain the membrane system (Figure 4b and 3d). Air scour blowers and permeate and backpulse pumps require 71.0 and 28.5%, respectively, of the total membrane energy consumption. WAS pumps only require a consumption of 0.5%. For secondary clarifier and dual media filter energy consumption, the largest contributor was the WAS pumps requiring an average of 40.8% of the total consumption across all flows. The secondary clarifier rake

arm and the dual media filter backwash pumps both require about 25% of the total energy consumption.

The overall energy consumption for each system train, MBR and CAS is depicted in Figure 4e. It is observed that the MBR process, on average for the flow ranges investigated, is 2.10 times more energy intensive than the traditional CAS process. Reports on MBR energy consumption say MBR energy may be twice that of CAS (WEF, 2010b; U.S. EPA, 2010) to as much as three times (Wallis-Lage, et al., 2011). As observed in Figure 4e, energy consumption is directly proportional to the influent flowrate for both MBR and CAS with secondary filtration processes. For instance at 2 MGD, energy consumption is 4,996 kWh/day while at 6 MGD the consumption of energy is 14,988 kWh/day, which is three times more energy intensive. The largest energy consuming unit in the MBR process is air scouring and it accounts for 23.7% of the total energy demand of the entire plant across all flows. This is contrasted to 35 to 40% found in (WEF, 2010b; U.S. EPA, 2010; DeCarolis, et al., 2008).








Figure 4 – Energy Consumption for Secondary and Tertiary Unit Processes: (a) Bioreactor Process Energy Consumption Versus Flow; (b) Membrane Energy Consumption Versus Flow; (c) CAS Bioreactor Process Energy Consumption Versus Flow; (d) Secondary Clarifier and Dual Media Filter Energy Consumption Versus Flow; and (e) MBR and CAS Energy Consumption Comparison Versus Flow

Disinfection Units

Disinfection methods considered include UV disinfection and chlorination. The energy consumption in terms of flowrate for the UV disinfection process for both low and medium pressure lamps is shown in Figure 5. For low and medium-pressure high intensity lamps, energy consumption increases with flowrate. This increase is directly proportional to the flow. Slight variations in energy consumption of both low and medium-pressure lamps is due to the number of lamps that can be in a module and the number of modules that can be in a bank per UV channel (Trojan Technologies, 2007; Trojan Technologies, 2008). Therefore, the exact dosage varied slightly at different flowrates. Studies have found that UV disinfection can take up approximately 10 to 25% of a facility's total energy consumption (U.S. EPA, 2010). In this research, it was found that UV disinfection for all flows had on average a 3.7 and 9.9% total energy consumption for MBR and CAS treatment facilities with low pressure lamps, respectively; and 18.8 and 43.6% with medium pressure lamps. It is observed that filter effluent requires more energy for disinfection compared to membrane effluent due to the higher MPN and TSS levels in the filter effluent, as well as the higher dosage requirement. For instance at 6 MGD, membrane effluent requires 584 and 3,542 kWh/day for low-pressure and medium-pressure lamps, respectively, while the filter effluent requires 832 and 5,760 kWh/day. On average across all flows, filter effluent requires a 38.6% increase in energy consumption for low-pressure lamps and 63.0% increase for medium-pressure lamps.

In the research, results indicate that medium-pressure high intensity lamps required more energy to disinfect compared to low-pressure high intensity lamps. On

average for membrane effluent, medium-pressure lamps required a 5.96 times increase in energy consumption compared to low-pressure. For filter effluent, a 7.01 times increase is also observed. These results are consistent with reports on low-pressure lamps requiring less energy to deliver the same UV dose compared to medium-pressure lamps (WEF, 2010b). As energy consumption is directly proportional to the flowrate being treated, the energy gap between the low and medium pressure lamps stays constant as flows change. URS (2004) reports that at a 18 MGD facility, low-pressure high intensity lamps require 1,080 kWh/day and medium-pressure high intensity lamps require 4,560 kWh/day; resulting in an energy gap of 4.22 times between low and medium-pressure lamps. For this reason, in this study total facility energy calculations incorporate low-pressure lamps. It is well known that UV disinfection is an energy intensive process, especially when compared to chlorination (WEF, 2010b; Metcalf & Eddy, Inc, 2003). Chlorination energy consumption stayed constant for both MBR and CAS facility flows. This occurs because the pump motor size used stayed the same (0.25 hp) to allow sufficient power to overcome greater pressure heads at higher flows. This additional power allows for sufficient mixing energy. Chlorination on average was only 1% of the total energy consumed when compared to UV disinfection.




Figure 5 – Energy Consumption for the Disinfection Unit Process: (a) UV Disinfection of Membrane Effluent Energy Consumption Versus Flow; (b) UV Disinfection of Dual Media Filter Effluent Energy Consumption Versus Flow; and (c) UV Disinfection Comparison of Membrane and Dual Media Filter Effluent

Unit Flow Energy Consumption

Table 7 summarizes the energy consumption of each unit process per unit flow in terms of kWh/MG. These values were derived by dividing the energy consumption per day (kWh/day) by the unit flow (MGD), resulting in energy consumption per million gallon (kWh/MG). The results show that as WRPs increase in the treatment capacity, energy consumption per million gallons treated decreases, as also seen in WEF (2010b). This decreasing in energy consumption can be directly related to cost savings. Assuming a commercial electrical energy rate of \$0.08 USD/kWh for low rates, \$0.10 USD/kWh for average rates, and \$0.12 USD/kWh for high rates at a CAS WRP, when flow is five

times as large compared to a 1 MGD facility, the savings in energy costs is \$7.44/MG treated at low rates, \$9.30/MG treated at average rates, and \$11.16/MG treated at high rates; and \$13.12/MG, \$16.40/MG, \$19.68/MG treated at ten times the flow for low, average, and high energy rates. Table 7 can be used in targeting unit processes that are in need of minimizing energy consumption. In addition, the table can be used as a basis for decision making regarding sustainability of using advanced treatment technologies in reuse plants.

The resulting values for the CAS and MBR facilities along with published values for energy consumption in WWTPs are shown in Table 8. For the 1 MGD CAS facility, the energy consumed was found to be 1,476 kWh/MG in this research. This value is 50.0% smaller than values for the same flowrate reported by EPRI (2002), 2,951 kWh/MG, and it is 12.8% greater than values reported by WEF (2010b), 1,308 kWh/MG. On average, energy consumption for the designed MBR facilities were determined to be 2,643 kWh/MG and is comparable to reported values for typical MBR facilities with an energy consumption of 3,000 kWh/MG (Livingston, 2010). This research found that the MBR WRP is on average 1.91 times more energy intensive than the CAS WRP.

Table 7 – Energy Consumption of Each Unit Process per Unit Flow

	Unit Process	Energy Consumption per Unit Flow (kWh/MG)					
		1 MGD	2 MGD	4 MGD	6 MGD	8.8 MGD	11 MGD
MBR Facility	<i>Coarse Screens</i>	1.156	0.578	0.289	0.193	0.131	0.158
	<i>Grit Chamber</i>	107.42	62.68	44.76	35.81	28.48	24.41
	<i>Fine Screens</i>	35.81	17.90	8.95	5.97	4.07	4.88
	<i>Bioreactor</i>	1591.6	1593.8	1593.8	1593.8	1607.3	1607.3
	<i>Membranes</i>	904.2	904.2	904.2	904.2	839.0	839.0
	<i>UV Disinfection</i>	98.0	105.0	101.0	97.3	95.3	98.0
	Total w/UV	2738	2684	2653	2637	2574	2574
	<i>Chlorination</i>	4.48	2.24	1.12	0.75	0.51	0.41
	Total w/Chlorination	2645	2581	2553	2541	2479	2476
CAS Facility	<i>Coarse Screens</i>	1.156	0.578	0.289	0.193	0.131	0.158
	<i>Grit Chamber</i>	107.42	62.68	44.76	35.81	28.48	24.41
	<i>Fine Screens</i>	35.81	17.90	8.95	5.97	4.07	4.88
	<i>CAS</i>	1179.8	1164.1	1164.1	1164.1	1176.0	1176.0
	<i>Secondary Clarifier</i>	8.95	6.71	6.71	6.71	6.10	6.10
	<i>Dual Media Filters</i>	5.04	5.01	3.75	3.34	3.23	3.23
	<i>UV Disinfection</i>	138.0	138.0	134.8	138.7	139.7	134.1
	Total w/UV	1476	1395	1363	1355	1358	1349
	<i>Chlorination</i>	4.48	2.24	1.12	0.75	0.51	0.41
	Total w/Chlorination	1342	1259	1229	1217	1219	1215

Table 8 – Comparison of Energy Consumption per Unit Flow

Water Reuse Plant Size	Energy Consumption per Unit Flow (kWh/MG)								
	CAS Facilities					MBR Facilities			
	This Study	(WEF, 2010b) ¹	(EPRI, 2002)	(Mizuta, et al., 2010)	(Yang, et al., 2010)	This Study	(Verrecht, et al., 2010)	(Yang, et al., 2010)	(Livings ton, 2010)
1 MGD	1476	1308	2951	–	–	2738	–	–	–
2 MGD	1395	1271.55 ²	2694.75 ²	–	–	2684	–	–	–
4 MGD	1363	1198.65 ²	2182.25 ²	–	–	2653	–	–	–
5 MGD	–	1162.20	1926	–	–	–	–	–	–
6 MGD	1355	1158.80 ²	1899 ²	–	–	2637	–	–	–
8.8 MGD	1358	1149.28 ²	1823.40 ²	–	–	2574	–	–	–
10 MGD	–	1145.20	1791	–	–	–	–	–	–
11 MGD	1349	1142.94 ²	1779.50 ²	–	–	2574	–	–	–
20 MGD	–	1122.60	1676	–	–	–	–	–	–
Average	1382.7	1204.87	2221.65	1135.62 – 7154.43	1010.71	2643.3	2271.25 – 7570.82	1249.19	3000

1: Total energy consumption was determined based off the addition of similar unit processes

2: Values were interpolated from corresponding reference literature

The efficiencies considered in the energy computations are a combined motor and equipment efficiency, also known in the water industry as ‘wire-to-water’ efficiency. This efficiency is affected by several factors including type and age of motors, age of equipment (e.g. belts, pulleys, and bearings), and operating conditions (e.g. partial load operation, valve and pipe maintenance, and equipment maintenance) (Kaya, et al., 2008). To evaluate the impact of efficiency on energy computations, a sensitivity analysis was performed to evaluate the impacts of efficiency variations on energy consumption. Table 9 and Table 10 provide the results of this analysis at 8.8 MGD for each energy consuming unit and their respective totals for low-end and high-end efficiencies, respectively. The pump efficiencies were increased by 3 and 5% for the high efficiency range as it has been reported that a 3 to 5% increase has been seen in efficiencies when converted from average to high efficiency motors (Liu, et al., 2005). A low efficiency range for pumps had a decrease of 3 and 5% as it was the mean of a range up to 10-12.5% decrease due to unmaintained pumps (Kaya, et al., 2008). For blowers, efficiencies were increased by 5 and 10% for the high efficiency range and decreased by 5 and 10% for the low efficiency range. These increments were chosen as they covered the typical range of blower efficiencies of 70 to 90% (Metcalf & Eddy, Inc, 2003; Davis, 2010). The sensitivity analysis found that when efficiencies are the lowest compared to average, a 10.9 and 11.3% increase in energy consumption occurs for MBR WRPs with UV radiation and MBR WRPs with chlorination, respectively. A 9.3 and 10.4% increase in energy consumption was found for CAS WRPs with UV radiation and chlorination, respectively. When the highest efficiencies are compared to average efficiencies, a 9.1 and 9.4% decrease in energy consumption occurs for MBR WRPs with UV radiation and

chlorination, respectively. An 8.1 and 9.0% decrease is observed for CAS WRPs with UV radiation and chlorination, respectively. Overall, this analysis has shown that even with a slight increase or decrease in efficiencies, the total energy consumption of the entire plant can be greatly affected, by as much as an 11.3% increase or 9.4% decrease.

Table 9 – Sensitivity Table of Low-End Combined Motor and Wire Efficiencies for Energy Driving Units at an 8.8 MGD Water Reuse Plant

	Energy Driving Units	Low Efficiency				Average Efficiency	
		Energy Consumption (kWh/day)	Efficiency; Pump -5, Blower -10 (%)	Energy Consumption (kWh/day)	Efficiency; Pump -3, Blower -5 (%)	Energy Consumption (kWh/day)	Efficiency (%)
<i>Coarse Screens</i>	Rake Motor	1.16	-	1.16	-	1.16	-
<i>Grit Chamber</i>	Air Blowers	286.46	70	268.56	75	250.66	80
<i>Fine Screens</i>	Screen Motor	35.81	-	35.81	-	35.81	-
<i>Bioreactor</i>	Mixers	680.38	-	680.38	-	680.38	-
	Air Blowers	10455.94	70	9739.78	75	9166.85	80
	IMLR Pumps	1862.02	75	1862.02	77	1790.40	80
	RAS Pumps	2721.41	75	2649.79	77	2506.56	80
	Total	15719.75	-	14931.97	-	14144.19	-
<i>Membranes</i>	Air Scour Blowers	5885.05	70	5510.85	75	5170.68	80
	Permeate Pumps	2177.13	65	2041.06	67	2041.06	70
	Backpulse Pumps	143.23	65	136.07	67	136.07	70
	WAS Pumps	35.81	75	35.81	77	35.81	80
	Total	8241.22	-	7723.79	-	7383.62	-
<i>Conventional Activated Sludge</i>	Mixers	680.38	-	680.38	-	680.38	-
	Air Blowers	7448.06	70	6946.75	75	6517.06	80
	IMLR Pumps	1862.02	75	1862.02	77	1790.40	80
	RAS Pumps	1432.32	75	1360.70	77	1360.70	80
	Total	11422.78	-	10849.85	-	10348.54	-
<i>Secondary Clarifier</i>	Rake Arm Torque	17.90	-	17.90	-	17.90	-
	WAS Pumps	35.81	75	35.81	77	35.81	80
	Total	53.71	-	53.71	-	53.71	-
<i>Dual Media Filters</i>	Backwash Blower	9.42	70	8.75	75	8.22	80
	Backwash Pump	21.62	73	20.95	75	20.16	78
	Total	31.04	-	29.70	-	28.38	-
<i>UV Disinfection – Membrane Effluent</i>	Low-Pressure	839	-	839	-	839	-
	Medium-Pressure	5184	-	5184	-	5184	-
<i>UV Disinfection – Filter Effluent</i>	Low-Pressure	1229	-	1229	-	1229	-
	Medium-Pressure	8496	-	8496	-	8496	-
<i>Chlorination – Membrane Effluent</i>	Pump	4.48	65	4.48	67	4.48	70
<i>Chlorination – Filter Effluent</i>	Pump	4.48	65	4.48	67	4.48	70
<i>MBR WRP</i>	With Low-Pressure UV Radiation	25123.40	-	23800.29	-	22654.44	-
	With Chlorination	24288.88	-	22965.77	-	21819.92	-
<i>CAS WRP</i>	With Low-Pressure UV Radiation	13059.96	-	12467.79	-	11947.26	-
	With Chlorination	11835.44	-	11243.27	-	10722.74	-

Table 10 – Sensitivity Table of High-End Combined Motor and Wire Efficiencies for Energy Driving Units at an 8.8 MGD Water Reuse Plant

	Energy Driving Units	Average Efficiency		High Efficiency			
		Energy Consumption (kWh/day)	Efficiency (%)	Energy Consumption (kWh/day)	Efficiency; Pump +3, Blower +5 (%)	Energy Consumption (kWh/day)	Efficiency; Pump +5, Blower +10 (%)
<i>Coarse Screens</i>	Rake Motor	1.16	-	1.16	-	1.16	-
<i>Grit Chamber</i>	Air Blowers	250.66	80	232.75	85	214.85	90
<i>Fine Screens</i>	Screen Motor	35.81	-	35.81	-	35.81	-
<i>Bioreactor</i>	Mixers	680.38	-	680.38	-	680.38	-
	Air Blowers	9166.85	80	8593.92	85	8164.22	90
	IMLR Pumps	1790.40	80	1718.78	83	1647.17	85
	RAS Pumps	2506.56	80	2434.94	83	2363.33	85
	Total	14144.19	-	13428.02	-	12855.10	-
<i>Membranes</i>	Air Scour Blowers	5170.68	80	4864.52	85	4592.38	90
	Permeate Pumps	2041.06	70	1904.99	73	1904.99	75
	Backpulse Pumps	136.07	70	128.91	73	121.75	75
	WAS Pumps	35.81	80	35.81	83	35.81	85
	Total	7383.62	-	6934.23	-	6654.93	-
<i>Conventional Activated Sludge</i>	Mixers	680.38	-	680.38	-	680.38	-
	Air Blowers	6517.06	80	6158.98	85	5800.90	90
	IMLR Pumps	1790.40	80	1790.40	83	1647.17	85
	RAS Pumps	1360.70	80	1360.70	83	1289.09	85
	Total	10348.54	-	9990.46	-	9417.54	-
<i>Secondary Clarifier</i>	Rake Arm Torque	17.90	-	17.90	-	17.90	-
	WAS Pumps	35.81	80	35.81	83	35.81	85
	Total	53.71	-	53.71	-	53.71	-
<i>Dual Media Filters</i>	Backwash Blower	8.22	80	7.82	85	7.29	90
	Backwash Pump	20.16	78	19.50	81	18.96	83
	Total	28.38	-	27.32	-	26.25	-
<i>UV Disinfection – Membrane Effluent</i>	Low-Pressure	839	-	839	-	839	-
	Medium-Pressure	5184	-	5184	-	5184	-
<i>UV Disinfection – Filter Effluent</i>	Low-Pressure	1229	-	1229	-	1229	-
	Medium-Pressure	8496	-	8496	-	8496	-
<i>Chlorination – Membrane Effluent</i>	Pump	4.48	70	4.48	73	4.48	75
<i>Chlorination – Filter Effluent</i>	Pump	4.48	70	4.48	73	4.48	75
<i>MBR WRP</i>	With Low-Pressure UV Radiation	22654.44	-	21470.97	-	20600.85	-
	With Chlorination	21819.92	-	20636.45	-	19766.33	-
<i>CAS WRP</i>	With Low-Pressure UV Radiation	11947.26	-	11570.21	-	10978.32	-
	With Chlorination	10722.74	-	10345.69	-	9753.80	-

Figure 6 aides in visualizing the breakdown of the percentage of energy consumption corresponding to each unit process of the 8.8 MGD WRPs found in this research. It should be noted that RAS pump energy is included in the Bioreactor/CAS energy, not the Membranes/Secondary Clarifier energy. The percentages for each unit process inside the CAS WRP correlates to percentages calculated using WEF (2010b) values. For instance using WEF (2010b) values, at 8.8 MGD the aerated grit chamber at a CAS facility uses 122.72 kWh/day and a total plant energy consumption of 10,113.66 kWh/day; resulting in the aerated grit chamber using 1.21% of the total plant’s energy consumption. This is comparable to the 1.84% at a CAS WRP found in this research. WEF (2010b) breaks down the energy consumption for each unit process per flow, therefore comparisons can be made with this research. However, comparisons with individual unit processes with EPRI (2002) is not possible because the report provides energy consumption of only the entire facility per flow.




Figure 6 – Percentage of Total Energy Consumption of the Plant per Unit Process: (a) Energy Consumption of 8.8 MGD MBR WRP; and (b) Energy Consumption of 8.8 MGD CAS WRP

4. Conclusion and Discussion

This research explored the energy consumption of conventional and advanced treatment processes used in reuse wastewater treatment inside satellite WRPs. Both conventional and advanced unit processes were chosen to provide the same treatment level so comparisons were equivalent. For conventional treatment with flowrates varying from 1 to 11 MGD, a CAS process with phosphorous and nitrogen removal averaged an energy footprint of 1382.7 kWh/MG. For advanced treatment, a MBR process with phosphorous and nitrogen removal averaged an energy footprint of 2643.3 kWh/MG. This demonstrates that MBR WRPs are 1.91 times more energy intensive than CAS WRPs, costing an additional \$126.06/MG treated at an average energy rate of \$0.10/kWh or 1260.6 kWh/MG. The higher cost of MBR systems is associated with air scouring of the membranes for cleaning, which consumes an average of 23.4% of the facility's total energy. In addition higher cost is also related to the higher blower requirements inside the bioreactor, as a result of a lower oxygen transfer efficiency associated with the high solids concentrations. Disinfection of reuse plant effluent using UV radiation was shown to be on average 100 times more energy intensive than chlorination. UV radiation was shown to have an increase of 38.6% in the consumption of energy for disinfection of filter effluent versus membrane effluent with low-pressure lamps, and 63.0% with medium-pressure. Based on these results, energy savings could be realized by: using chlorination as the disinfectant for membrane effluent, if land area permits, as MPN and TSS levels are already minimal; and UV disinfection with low-pressure lamps would still be advisable for filter effluent because higher concentration of microorganisms and TSS is observed. However, if chlorination were used for filter effluent, a 2.8 times increase in

sodium hypochlorite per day will be expected, compared to disinfection of membrane effluent.

The results of this study clearly show that advanced treatment processes, typically used in reuse facilities, have a significantly larger energy footprint compared to that of conventional processes. However, there are tradeoffs if conventional treatment processes were to be selected over advanced treatment processes to save energy. For example, if CAS was selected versus a MBR process a doubling in aeration volume and corresponding land area would be needed. Furthermore, more land would be needed for clarifiers and dual media filters to achieve comparable effluent quality. In addition, capital costs of material (e.g. concrete) to provide for additional conventional treatment units also need to be taken into consideration and compared to capital costs of the advanced treatment units (e.g. membranes and UV systems). Chlorination used in place of UV disinfection requires area for a chlorine contact basin and for chemical storage. Therefore overall, advanced treatment processes greatly reduce the real estate area needed but greatly increases the energy consumption of the facility.

The term 'energy hog' has been used for satellite WRPs to describe their high energy consumption. This research shows if satellite WRPs are designed using conventional treatment technologies their energy consumption is comparable to that of non-satellite WWTPs. However, when advanced treatment technologies are implemented in satellite WRPs, especially MBRs, 'energy hog' can be an adequate term. As of late, large improvements have been made at MBR facilities in energy consumption with the scheduling of air scour timings but more improvement is still needed. With the ever growing increase in satellite WRPs, evaluations on the consumption of energy in

these facilities need to be a part of the design process. In this matter, pros and cons of the increase in energy consumption associated with advanced treatment technologies can be evaluated to determine which treatment processes are more suitable for the facility.

CHAPTER 3

IMPACTS OF ON-SITE RENEWABLE ENERGY GENERATION ON TOTAL ENERGY CONSUMPTION AND GREENHOUSE GAS EMISSIONS OF SATELLITE WATER REUSE PLANTS

1. Introduction

In recent decades, smaller decentralized wastewater treatment plants (WWTP), termed satellite water reuse plants (WRP), have become very prevalent. WRPs are satellite treatment facilities that treat wastewater from a specific part of community and reuse the effluent in or around the location where the wastewater was collected. Due to the close proximity and/or potential direct contact of reclaimed water with the general public, regulations and effluent standards for reuse water are strict and are becoming stricter (Crook, 2011). To achieve these stricter standards on effluent quality and smaller land footprint (i.e. real estate area), additional treatment processes along with advanced technologies are needed (Bennett, 2007; EPRI, 2002; Brandt, et al., 2011; Urkiaga, et al., 2008). Despite the obvious benefits of water reuse and recycle, the application of advanced treatments technologies in WRPs coupled with stringent effluent discharge standards greater energy consumption is likely to result.

Wastewater treatment is a very energy intensive process; over recent years ways to curb this large consumption of energy has been pursued. Energy can be curbed within an existing WWTP by increase of efficiencies in plant equipment and the optimization of plant processes and equipment. To achieve this reduction in energy a WWTP can undergo a benchmarking evaluation, where energy usage for the whole plant and

individual processes can be computed and compared to published values (WEF, 2010b). Another way to implement energy saving measures is with the use of supervisory control and data acquisition (SCADA) systems. With a SCADA system, a plant can monitor their own facility's operational data and obtain useful energy measuring units (e.g. kW, kWh, kWh/gal, kWh/ft³, etc.) (WEF, 2010b). However, in order to perform such an evaluation, the necessary sensors must be installed in the plant for the unit operations of interest. For example, plants may choose to monitor air flowrate use in the plant and the respective energy use associated with the motors that fuel the air blowers for varying wastewater flowrates entering the plant. With this type of analysis, it has been found that pumping can represent up to 30% of energy consumption for wastewater treatment and 80% for clean water (Brandt, et al., 2011). To help curb this consumption the use of modern variable speed drives in pumps can result in 83% of energy savings (Brandt, et al., 2011). This is due to the included power factor management on these pumps, but this does require a 4 - 5% increase in rated motor power to control the variable speed (Brandt, et al., 2011). To assist the management of pump efficiency in WWTPs, effective screening must be maintained because grit, rags, debris, and other solids can contribute to higher wear rate (Brandt, et al., 2011). SCADA system energy analyses have shown that aeration typically represents 50 to 60% of the total energy consumption in WWTPs, however with a variety of measures, including checking control set-points, check rates with metered electrical input, equipment performance optimization, and overall routine maintenance, savings in energy can be up to 40% (Brandt, et al., 2011).

A ranking of energy consumption for treatment units has been developed in wastewater treatment. In order of low energy consumption to high: biological filters;

anaerobic membrane bioreactor; bio-aerated flooded filter; step fed activated sludge; nutrient removal activated sludge; and conventional membrane bioreactor (Brandt, et al., 2011). Potential savings in energy consumption in any WWTP will be system-specific and requires a site-specific analysis (Daigger, 2009). There is however a limit to how much energy use within an existing plant can be curbed, because current design requires a minimum amount of energy to run installed processes and equipment. As a result, new approaches are needed to curb (minimize) energy consumption, not only for existing WWTPs but also for future planned plants.

Fossil fuels, oil, coal, and gas, currently are providing over two-thirds of the world's energy (Demirbas, 2009). At this consumption, known petroleum reserves are projected to be depleted in less than 50 years (Demirbas, 2009; Gude, et al., 2010). With the world's energy growth rate of 2% a year and the resulting energy consumption doubling by the year 2035 relative to 1998 and tripling by 2055 (Demirbas, 2009), this depletion rate will only get worse. Thus, the use of these fuels produces enormous amounts of greenhouse gas (GHG) emissions, which are subsequently resulting in crucial environmental problems worldwide including acid rain and global warming (Gude, et al., 2010). To help maintain the reduction in GHG emissions protocols such as the Kyoto Protocol have been adopted by the United Nations Framework Convention on Climate Change. Kyoto Protocol was adopted by countries to help reduce GHG emissions by an average of 5%, against 1990 levels, over a period of five years, 2008 – 2012 (UNFCCC, 2012). But since levels of GHG emissions had increased by 25% since 1990 (The World Bank, 2010); the protocol has only had a slight effect on emissions. Even though the

protocol did not prove to be as successful as planned it contributes to the beginning of change.

In the United States, 2 - 4 % of the total energy consumed is for the collection, distribution, and treatment of wastewater and drinking water (McMahon, et al., 2011; Daigger, 2009; U.S. EPA, 2010; Metcalf & Eddy, Inc, 2003; EPRI, 2002; WEF, 2010b). In all WWTPs, consumption of electric power accounts for about 90% of the total energy consumption in a plant (Mizuta, et al., 2010). This current usage of energy translated to 75 billion kWh in 1996 (U.S. EPA, 2008; U.S. EPA, 2010) and was estimated to increase to 100 - 123.45 billion kWh in 2010 (U.S. EPA, 2010; EPRI, 2009). This consumption emits roughly 116 billion lbs (52 million metric tonnes) of carbon dioxide (CO₂) into the atmosphere (McMahon, et al., 2011; NRDC, 2009). In order to decrease this production of GHG emissions and dependency on fossil fuels, the use of renewable energy in wastewater treatment has become popular in replacing grid connect as a supply for energy. In addition, efforts have been spent towards wastewater treatment generating some of the energy they consumed via methane generation from anaerobic sludge digestion and the installation of photovoltaic (PV) solar panels throughout or around the plant (Palmer, 2009; Seeta, et al., 2011).

Anaerobic sludge digestion, is generally not found in satellite WRPs, due to the lack of solids handling at the facility to achieve a smaller real estate area. However, introduction of membrane bioreactors (MBR) into satellite reuse plants is expected to significantly reduce land acreage needed. Therefore, application of anaerobic digesters at these facilities should now be re-evaluated. With the increase of pretreatment requirements before the use of a MBR, solids screening removal has become more

stringent; thus a richer thicker primary sludge is obtained that can be processed directly in a digester without the need for thickening. For this reason, only one additional unit process is needed to have an energy producing unit at the facility, the digester itself.

In using digesters at a WRP, only primary (screened) sludge can be selected to be diverted to the digester to allow for more energy production and less energy consumption. This is because if even a small amount of waste activated sludge (WAS) were to be blended into the process, the rate of biological reaction in the digester would decrease (Metcalf & Eddy, Inc, 2003). With the WAS being directly discharged back into the collection trunk without processing through the digester, the volume and the overall acreage of the digester will be smaller. Using a single-stage high-rate mesophilic anaerobic digester also provides a small acreage for the digester. With the digestion of the primary sludge, odors can be greatly reduced when compared to discharging undigested primary sludge back into the collection system for further processing.

The use of renewable energy in industry as a whole has had a slow start. Renewable energy only represents a 14-16% total of the world's energy (Demirbas, 2009; Gude, et al., 2010). This number has been projected to reach 48-50% by the year 2040 (Demirbas, 2009; Gude, et al., 2010). This projection has been paralleled with the recent growth rate in renewable energy application such as wind and solar energy during 2009 - 2010 (Trabish, 2012). With the development of new technology, renewable energy has become more cost effective, comparable to grid connect using fossil fuels. Renewable energies, geothermal, solar, and wind, cost 0.07, 0.05-0.09, and 0.05/kWh, respectively; while grid connected electricity costs 0.05-0.09/kWh (Gude, et al., 2010). With the cost of fossil fuels rapidly rising (Mizuta, et al., 2010; Brandt, et al., 2011), the need to

conserve energy and transition from fossil fuels to renewable energy has now become a necessity over a luxury.

The use of advanced treatment technologies to treat reuse water requires a large increase in energy consumption compared to conventional unit processes (Chapter 2). In the past, energy consumption and GHG generation has not been a concern in WWTP design and especially in reuse plant design. However, the current efforts to minimize GHG emissions and related energy footprint challenges the actual benefits of reuse plants with advanced treatment. Previous work has been done on the energy consumption in satellite WRPs and was found that with advanced treatment technologies, such as a MBR, requires on average a 1.67 increase in energy consumption compared to a conventional activated sludge system (CAS) (Chapter 2). However, a complete evaluation on GHG emissions and the renewable energy potential of a WRP have not been investigated to date. In this research, a WRP was evaluated to determine the GHG emissions associated with conventional and advanced treatment units. In addition, the renewable energy potential inside the plant was investigated based on acreage available from basin and membrane/clarifier area for a PV solar system, and from biosolids digestion from fine screened (primary) sludge.

2. Methodology

The flow diagram for the WRP considered in this study is presented in Figure 7. In order of treatment, the unit processes include: coarse screen, aerated grit chambers, fine screen, conventional activated sludge (CAS) system, membranes, and UV disinfection. When comparing conventional versus advanced unit processes, the

membranes were replaced by the combination of secondary clarification and dual media filtration, and UV disinfection by chlorination.




Figure 7 – Process Flow Diagram of the Water Reuse Plant for Which Greenhouse Gas Emissions are Evaluated

2.1 Influent and Effluent Quality

The influent characteristics and effluent requirements for the WRP are presented in Table 11. The requirements are typical water reuse standards found in California and Florida, with the exception for the need to remove nutrients. A five-stage modified Bardenpho CAS system is provided at the facility for the removal of the nutrients phosphorous and nitrogen (WEF, 2012; WEF, 2011).

Table 11 – Plant Influent and Effluent Process Characteristics Found in the Water Reuse Plant

Parameter	Influent Characteristics	Effluent Requirements
BOD (mg/L)	250	30
TSS (mg/L)	309	30
TKN (mg/L as N)	42	–
NH ₃ (mg/L as N)	34	0.5
TN (mg/L as N)	–	10
TP (mg/L as P)	8	0.2
TC (MPN/100 mL)	–	2.2
TC, daily max (MPN/100 mL)	–	23
Minimum Temp (°C)	18.3	18.3

2.2 Energy Consumption in Unit Processes of the Water Reuse Plant

To determine the energy consumption associated with the reuse plant, the energy driving unit from each process was identified and the energy associated with it was computed (computations shown in Chapter 2). These computations were done using typical design equations available in reference literature (Metcalf & Eddy, Inc, 2003; WEF, 2010a; Qasim, 1999; Davis, 2010; Lin, 2007; WEF, 2012). Energy consumption

levels for advanced treatment processes and comparable conventional treatment processes in the satellite WRPs were computed. The energy consumption levels obtained are found in Chapter 2 and are repeated in Table 12 for convenience.

Table 12 – Energy Consumption per Unit Flow of Each Unit Process in a Satellite Reuse Plant

	Unit Process	Energy Consumption per Unit Flow (kWh/MG)					
		1 MGD	2 MGD	4 MGD	6 MGD	8.8 MGD	11 MGD
MBR Facility	<i>Coarse Screens</i>	1.156	0.578	0.289	0.193	0.131	0.158
	<i>Grit Chamber</i>	107.42	62.68	44.76	35.81	28.48	24.41
	<i>Fine Screens</i>	35.81	17.90	8.95	5.97	4.07	4.88
	<i>Bioreactor</i>	1591.6	1593.8	1593.8	1593.8	1607.3	1607.3
	<i>Membranes</i>	904.2	904.2	904.2	904.2	839.0	839.0
	<i>UV Disinfection</i>	98.0	105.0	101.0	97.3	95.3	98.0
	Total	2738	2684	2653	2637	2574	2574
CAS Facility	<i>Coarse Screens</i>	1.156	0.578	0.289	0.193	0.131	0.158
	<i>Grit Chamber</i>	107.42	62.68	44.76	35.81	28.48	24.41
	<i>Fine Screens</i>	35.81	17.90	8.95	5.97	4.07	4.88
	<i>CAS</i>	1179.8	1164.1	1164.1	1164.1	1176.0	1176.0
	<i>Secondary Clarifier</i>	8.95	6.71	6.71	6.71	6.10	6.10
	<i>Dual Media Filters</i>	5.04	5.01	3.75	3.34	3.23	3.23
	<i>UV Disinfection</i>	138.0	138.0	134.8	138.7	139.7	134.1
	Total	1476	1395	1363	1355	1358	1349

2.3 Greenhouse Gas Production

To compute the GHG production, equivalent carbon dioxide generation potential was used. Carbon dioxide equivalent (CO₂e) is the conversion of all GHG (most contributing: carbon dioxide, methane, nitrous oxide, and fluorinated gases) into a common unit for ease of computing and reporting. The GHG emitted from energy consumption in the unit processes was determined based on fuel type from an average of three to eleven separate studies (Shrestha, et al., 2012; Shrestha, et al., 2011). An energy fuel mix found in the southwestern United States was used. The energy fuel mix

includes: 60% natural gas, 25% coal, 7% hydroelectric, 7% geothermal, and 1% solar (U.S. EIA, 2010). The emissions rates for these fuel types are as followed: natural gas = 605.9 g CO₂e/kWh; coal = 1022.9 g CO₂e/kWh; hydroelectric = 25.4 g CO₂e/kWh; geothermal = 66.7 g CO₂e/kWh; and solar = 70.8 g CO₂e/kWh (Shrestha, et al., 2012; Shrestha, et al., 2011). The resulting GHG emission rate used in this research for electrical energy is 626.4 g CO₂e/kWh consumed.

2.4 Design Parameters and Considerations

Typical design criteria used to size the PV solar systems and anaerobic digesters are shown in Table 13. Design values in the table are typical of values reported in the design literature. All energy consumption computations for the anaerobic digester are for monthly average flow conditions. Details of the design for each process are discussed below.

Table 13 – Photovoltaic Solar System and Anaerobic Digester Design Parameters

	Parameter	Value	Unit	Reference(s)
<i>Photovoltaic Solar System</i>	Average Solar Insolation	0.59 (6.31)	kWh/ft ² /day (kWh/m ² /day)	1, 2, 3
	Total Efficiency	70-80	%	2, 3, 4, 5
	Power Generated per Panel Area	10-16.7 (107.6-179.8)	W/ft ² (W/m ²)	5, 6, 7, 8, 9
<i>Anaerobic Digester</i>	Solids Retention Time (SRT)	15	day	10, 11
	Temperature	95 (35)	°F (°C)	10, 11, 12
	Methanogenic Bacterial Yield for Cell Synthesis	0.08	kg VSS/kg bCOD	10, 12
	Bacterial Endogenous Decay Coefficient	0.03	day ⁻¹	10, 12
	Waste Utilization Efficiency	70	%	10
	Percentage of Methane in Digester Gas	65	%	10, 11, 12

1 ~ (NREL, 2011); 2 ~ (Energy Matters, 2012); 3 ~ (Find Solar, 2012); 4 ~ (Leonics, 2009); 5 ~ (California Energy Commission, 2001); 6 ~ (Dryden, et al., 1961); 7 ~ (Green, 2005); 8 ~ (Burkart, et al., 2012); 9 ~ (Mandalaki, et al., 2012); 10 ~ (Metcalf & Eddy, Inc, 2003); 11 ~ (WEF, 2010b); 12 ~ (Davis, 2010)

2.4.1 Anaerobic Digester

Key parameters used in the design of the single-stage high-rate mesophilic anaerobic digester can be found in Table 13. The HRT, equivalent to the SRT, was used in the determination of the volume required for the digester (Metcalf & Eddy, Inc, 2003). The amount of methane-forming volatile solids synthesized per day was determined using the complete-mix high-rate digester equation, followed by the calculation of the volume of methane gas using kinetic equations (Metcalf & Eddy, Inc, 2003; Davis, 2010). These were done taking into account the volume of methane gas at the operating temperature of 35°C. An egg-shaped digester was used in the design to provide a higher mixing efficiency, improved homogeneous biomass, and most importantly, a smaller real estate area in the WRP (Metcalf & Eddy, Inc, 2003; WEF, 2010b).

The anaerobic digestion process produces methane gas that can be used for energy generation; however, digestion itself consumes energy. Energy consumption for the anaerobic digester is driven by the mixers providing a homogeneous biomass mixture and by the heat-exchanger providing heating for the sludge and heat losses through the digester walls. Mixer energy requirements were determined based on the volume of the digester, using an average energy consumption of 6.5 W/m³ (WEF, 2010b). The energy requirement to heat the sludge was determined using (Metcalf & Eddy, Inc, 2003; Davis, 2010; WEF, 2010b):

$$q = M_s C_s (T - T_i) \quad (1)$$

where q = heat required, J/day; M_s = mass flow of sludge, kg/day; C_s = specific heat of sludge, J/kg·°C; T = digestion temperature, °C; and T_i = influent sludge temperature, °C.

For purposes of this research, 4200 J/kg·°C was used for the specific heat of sludge

(Metcalf & Eddy, Inc, 2003). The energy required to compensate for the loss of heat through the walls of the digester were determined as (Metcalf & Eddy, Inc, 2003; Davis, 2010; WEF, 2010b):

$$q = UA\Delta T \quad (2)$$

where q = heat loss, J/sec; U = overall coefficient of heat transfer, $J/m^2 \cdot sec \cdot ^\circ C$; A = cross-sectional area perpendicular to heat flow, m^2 ; and ΔT = change in temperature between digestion and surface in question. Coefficients of heat transfer used in the research are 0.68, 0.85, and 0.91 $W/m^2 \cdot ^\circ C$ for the walls, floor, and roof, respectively (Metcalf & Eddy, Inc, 2003; Davis, 2010; WEF, 2010b). Energy production from the combustion of digester gas was determined using:

$$E = HVe \quad (3)$$

where E = energy generated, kJ/day; H = heat of combustion, kJ/m^3 ; V = volume of gas produced per day, m^3/day ; and e = electrical efficiency. In this research, 37,000 kJ/m^3 was used for the heat of combustion of methane (WEF, 2010b). An electrical efficiency of 33% was used based off the efficiency for an internal combustion engine (ICE) (WEF, 2010b).

2.4.2 Photovoltaic Solar System

Parameters used in the design of the PV solar system can be found in Table 13. Real estate area available for the PV system was determined based off basin and membrane/clarifier area in the form of a shaded structure with tilt single-axis panels. The system size was determined by multiplying the available area by the amount of power that can be generated per solar area. In this research, a radiative efficiency (i.e. panel

efficiency) of 15% was used, which provides 13.9 W of power generated per square foot of solar paneling. The energy production from this system size was calculated using:

$$E = P_s I_s e / I_p \quad (4)$$

Where E = energy generated, kWh/day; P_s = PV system size, kW; I_s = solar insolation, kWh/m²/day; e = combined efficiency; and I_p = panel irradiance, kW/m². The combined efficiency takes into account manufacture rating, wiring and power point tracking losses, and the inverter efficiency (Energy Matters, 2012; California Energy Commission, 2001). A combined efficiency of 80% was used. A panel irradiance of 1000 W/m² was used for the PV systems per ASTM G173-03 (ASTM International, 2012).

A sensitivity analysis was performed on solar panel efficiency. If a low radiative efficiency of 10.8% (10 W/ft²) were used (California Energy Commission, 2001; Dryden, et al., 1961), this would be a reduction of 28.2% of the energy generated by the panels. If a high radiative efficiency of 18% (16.7 W/ft²) were used (Green, 2005), an increase in energy generation of 20.0% would result.

3. Results and Analysis

Estimated energy consumption of the major energy driving and producing units for the anaerobic digester and PV solar system for varying flowrates in the WRP are presented in Table 14. Overall net totals of the energy consumption and generation are also provided.

Table 14 – Estimated Energy Consumption and Generation of Anaerobic Digester and Photovoltaic Solar System in a Water Reuse Plant

	Energy Driving & Producing Equipment	1 MGD Plant (kWh/day)	2 MGD Plant (kWh/day)	4 MGD Plant (kWh/day)	6 MGD Plant (kWh/day)	8.8 MGD Plant (kWh/day)	11 MGD Plant (kWh/day)
<i>Anaerobic Digester</i>	Mixers	32.67	64.69	96.63	188.19	277.88	343.06
	Heat-Exchanger	252.09	478.34	708.41	1345.50	1944.15	2343.96
	Total Consumption	284.76	543.04	805.04	1533.69	2222.03	2687.02
	ICE – Generation	404.71	809.42	1214.13	2428.25	3561.44	4451.8
	Net Total	119.95	266.38	409.09	894.56	1339.41	1764.78
<i>Photovoltaic Solar System</i>	Panel Generation – MBR Plant	116.47	235.20	470.40	705.60	1028.58	1285.73
	Panel Generation – CAS Plant	347.46	630.46	1260.92	1891.38	2825.71	3532.14

For flowrates between 1 and 11 MGD, the heat-exchanger consumed on average 87.8% of the total energy consumed by the anaerobic digester for both MBR and CAS facilities. The mixers used to avoid stratification inside the digester only required on average 12.2% of the total energy consumption. Assuming a specific gravity of 1.01 for primary sludge, an average of 653 kWh/ton (0.72 kWh/kg) of sludge digested is generated by the anaerobic digester for both MBR and CAS facilities across all flows. This is the result for all flows as the volume of primary sludge increase proportionally to the flow. Energy consumption in the anaerobic digestion process was found to be higher than values found in WEF (2010b) and Malcolm Pirnie (1995). The energy consumption for an anaerobic digester of an 11 MGD facility was reported as 1850 (WEF, 2010b) and 236.35 (Malcolm Pirnie, 1995) kWh/day, compared to 2687.02 kWh/day found in this research. This difference can be due to the combination of primary and secondary sludge per WEF (2010b). At 11 MGD, the energy generated by the digester was 4451.8 kWh/day. WEF (2010b) reports a value of 3850 kWh/day. This is a 13.5% decrease in energy consumption compared to the value reported in this research. This difference can

be due to the type of energy generator used, as different generators have different efficiencies. If microturbines with an efficiency of 27% were used, the energy generated would be 3642.4 kWh/day, making a difference of only 5.4% less comparing to WEF (2010b). In addition, a pattern is seen in the anaerobic digester, as flow increases the fraction of energy generated over energy consumed by the digester increases by an average of 3.1% across all flows.

For flowrates between 1 and 11 MGD, energy generation of the PV solar system in CAS facilities was proven to be on average 2.75 times higher than MBR facilities due to the large real estate size. The real estate size is directly proportional to the amount of energy generated as CAS facilities were on average 2.75 higher in real estate area compared to MBR facilities. The real estate sizes and their corresponding PV system sizes can be found in Table 15. For both MBR and CAS facilities, 0.07 kWh/day is generated per square foot of solar paneling. Future improvements in PV solar cell performance will only make this energy generation even greater. Since 1954, PV solar cells have increased from a two percent radiative efficiency to percentages of twenty-five plus in laboratory settings (Green, 2005; Spanggaard, et al., 2004; Green, 2012; Hecht, 2010). This is compared to the average 15% radiative efficiency (13.9 W/ft^2) used in this research.

Table 15 – Estimated Areas and System Size for PV Installation in Reuse Facilities with Advanced and Conventional Treatment Units

	Parameter	1 MGD	2 MGD	4 MGD	6 MGD	8.8 MGD	11 MGD
MBR Facility	<i>Area (ft²)</i>	1655.78	3343.55	6687.10	10030.66	14622.21	18277.76
	<i>System size (kW)</i>	23.07	46.59	93.18	139.78	203.76	254.70
CAS Facility	<i>Area (ft²)</i>	4939.43	8962.55	17925.10	26887.64	40170.01	50212.51
	<i>System size (kW)</i>	68.83	124.89	249.79	374.68	559.77	699.71

Table 16 summarizes energy generation from advanced and traditional treatment facilities incorporating anaerobic digestion and solar power individually and in conjunction per unit flow. These values were derived by dividing the energy consumption/generation per day (kWh/day) by the unit flow (MGD), resulting in energy consumption/generation per million gallon (kWh/MG). Energy consumption patterns are as expected, with the consumption of energy per million gallon decreasing as treatment capacity increases (WEF, 2010b). In addition, energy production patterns are also similar to WEF, 2010b as energy recovery in anaerobic digestion stays constant on a per million gallon basis. This is the result of primary sludge increasing proportionally as flow increases. For both MBR and CAS facilities at flowrates between 1 and 11MGD, an average net total of 136.19 kWh/MG is generated by the anaerobic digester. This correlates to an average of 5.2% of the MBR facility’s total energy consumption and 9.9% for the CAS facility. Assuming an average commercial electrical energy rate of \$0.10 USD/kWh, the savings in energy costs by the anaerobic digester is \$13.62/MG treated. PV solar energy however only generates 117 kWh/MG for MBR facilities and 323 kWh/MG for CAS facilities. This produces on average of 4.4% of the total energy consumption for MBR facilities and 23.3% for CAS facilities; resulting in a savings of

\$11.70/MG treated at MBR facilities and \$32.30/MG treated at CAS facilities, not including the capital costs of the anaerobic digester.

The low energy generation observed with solar energy is due to panels only being incorporated over basin and membrane/clarifier area. The solar energy generation can be greatly increased if panels were to be placed on top of building structures, parking shade structures, or around the facility itself. The size of the PV systems at WWTPs is not proportional to the treatment capacity of the facility. For instance an 819 kW PV system was installed at a 4.2 MGD facility (Drainville, et al., 2011) while 1000 kW PV systems were installed at 25 and 32 MGD facilities (Seeta, et al., 2011; City of Boulder, 2012). For this reason, comparing energy generation potential by PV systems at WWTPs is impracticable. In this research however, incorporating solar energy on structures was not evaluated because facility layout and design was not developed in this research. For MBR facilities, an average energy savings of 9.6% is accomplished when both anaerobic digestion and solar energy are incorporated in the WRP. While for CAS facilities, an average energy savings of 33.2% is obtained. This is a total savings of 253.36 kWh/MG (\$25.34/MG) for MBR facilities and 458.75 kWh/MG (\$45.88/MG) for CAS facilities, not including the capital costs of both the anaerobic digester and solar system. If 100% of the energy consumption were to be offset at each facility by solar generation, a 21.6 times increase of available real estate area on average would be required at the MBR facilities and 3.3 times increase at the CAS facilities. If 50% of the energy consumption were to be offset, a 10.3 times increase in available real estate area is required at MBR facilities and 1.1 times increase at CAS facilities.

Table 16 – Energy Consumption and Generation per Unit Flow of the Anaerobic Digester and Photovoltaic Solar System

	Unit Process	Energy Consumption per Unit Flow (kWh/MG)					
		1 MGD	2 MGD	4 MGD	6 MGD	8.8 MGD	11 MGD
MBR Facility	<i>Wastewater Treatment Total</i>	2738	2684	2653	2637	2574	2574
	<i>Anaerobic Digester</i>	284.8	271.5	201.3	255.6	252.5	244.3
	<i>Anaerobic Digester Generation</i>	405	405	304	405	405	405
	<i>Net Total w/Digester</i>	2618	2551	2551	2488	2422	2413
	<i>Photovoltaic System Generation</i>	116	118	118	118	117	117
	<i>Net Total w/PV</i>	2622	2567	2535	2520	2457	2457
	<i>Net Total w/Digester and PV</i>	2502	2433	2433	2371	2305	2296
CAS Facility	<i>Wastewater Treatment Total</i>	1476	1395	1363	1355	1358	1349
	<i>Anaerobic Digester</i>	284.8	271.5	201.3	255.6	252.5	244.3
	<i>Anaerobic Digester Generation</i>	405	405	304	405	405	405
	<i>Net Total w/Digester</i>	1356	1262	1261	1206	1206	1188
	<i>Photovoltaic System Generation</i>	347	315	315	315	321	321
	<i>Net Total w/PV</i>	1129	1080	1048	1040	1037	1028
	<i>Net Total w/Digester and PV</i>	1009	947	946	890	884	867

The costs for both anaerobic digesters and PV solar systems are only for operational energy consumption. Capital costs to install PV systems and digesters were evaluated based off current literature, but were not extensively explored. For PV solar systems, ranges vary widely based on the size and type of system, from \$1.99 - \$7.40/W generated (Barbose, et al., 2011; Goodrich, et al., 2012). In this research an average value of \$4.00/W was assumed. A wide range in capital costs was also found for anaerobic digesters, from \$2574 - \$7000/kWh generated (Navaratnasamy, et al., 2008; IRENA, 2012). An average value of \$5,000/kWh was assumed in this research. Table 17 shows the payback period in years for both energy generating systems. A low, medium, and high energy price as well as municipality and/or government incentives are

incorporated in the table. For all cases in the table, PV solar systems will take 40% longer to pay back compared to anaerobic digesters. However in recent decades due to the growth in technologies, capitals costs for PV systems have declined rapidly and PV system capacity has increased. For instance, capital costs for PV systems have decreased by a factor of six and the installed capacity has increased from 100 MW to 2,000 MW in 2000 (Gude, et al., 2010), to now over 5,700 MW in 2012 (SEIA, 2012). These benefits have resulted in a 30% growth in PV systems per year and are estimated to be the largest renewable energy source providing a production of 25.1% of the total global power generation by 2040 (Demirbas, 2009).

Table 17 – Cost Evaluation of Photovoltaic System and Anaerobic Digester with and without Incentives

	Energy Price (\$/kWh)	Payback (years)	Payback w/25% Incentive (years)	Payback w/50% incentive (years)
<i>Photovoltaic System</i>	0.08	27.1	20.4	13.6
	0.10	21.7	16.3	10.9
	0.12	18.1	13.6	9.0
<i>Anaerobic Digester</i>	0.08	19.4	14.5	9.7
	0.10	15.5	11.6	7.7
	0.12	12.9	9.7	6.5

Figure 8 helps visualize energy saving trends when comparing advanced and conventional treatment facilities with and without energy generating units. The MBR WRP with energy generating units is on average 2.59 times more energy intensive than the CAS WRP. This is an even greater increase in energy consumption difference compared to MBR WRPs being 1.91 times more energy intensive than CAS WRPs without energy generating units (Chapter 2).




Figure 8 – Energy Comparison of Advanced and Conventional Treatment Facilities with and without Incorporating Energy Generating Units

Table 18 summarizes the GHG emissions of each unit process per unit flow in terms of g CO₂/MG. Totals are also provided for each scenario with energy generating units. As with energy consumption, GHG emissions with MBRs are 1.91 and 2.59 times more intensive without and with energy generating units at the facilities, respectively, compared to CAS facilities. In MBR WRPs, an average decrease of 9.6% in emissions is observed when energy generating units are used; and 33.2% for CAS WRPs. Even with energy generating units at advanced and conventional treatment WRPs, GHG emissions are still relatively large. For instance at the 8.8 MGD MBR WRP, GHG emissions without energy generating units are 14,190 kg CO₂e/day and with energy generating units the emissions are 12,707 kg CO₂e/day, as shown in Figure 9. This however is a reduction of 1,483 kg CO₂e/day, which is equivalent to: the burning of 3.4 barrels of oil a day, the use of 106 passenger vehicles a day, or the electricity for 68 single-family homes a day (U.S. EPA, 2012).

Table 18 – Greenhouse Gas Emissions of Each Unit Process per Unit Flow

	Unit Process	GHG Emissions per Unit Flow (kg CO ₂ e/MG)					
		1 MGD	2 MGD	4 MGD	6 MGD	8.8 MGD	11 MGD
MBR Facility	<i>Coarse Screens</i>	0.72	0.36	0.18	0.12	0.08	0.10
	<i>Grit Chamber</i>	67.29	39.26	28.04	22.43	17.84	15.29
	<i>Fine Screens</i>	22.43	11.21	5.61	3.74	2.55	3.06
	<i>Bioreactor</i>	996.98	998.36	998.36	998.36	1006.81	1006.81
	<i>Membranes</i>	566.39	566.39	566.39	566.39	525.55	525.55
	<i>UV Disinfection</i>	61.39	65.77	63.27	60.95	59.70	61.39
	Total	1715.20	1681.36	1661.84	1651.99	1612.53	1612.20
	<i>Anaerobic Digester</i>	178.37	170.08	126.07	160.12	158.17	153.01
	<i>Anaerobic Digester GHG Savings</i>	253.51	253.51	190.13	253.51	253.51	253.51
	Net Total w/Digester	1640.06	1597.93	1597.78	1558.60	1517.19	1511.70
	<i>Photovoltaic System GHG Savings</i>	72.96	73.66	73.66	73.66	73.21	73.21
	Net Total w/PV	1642.24	1607.69	1588.17	1578.32	1539.32	1538.98
	Net Total w/Digester and PV	1567.11	1524.26	1524.11	1484.93	1443.97	1438.49
	CAS Facility	<i>Coarse Screens</i>	0.72	0.36	0.18	0.12	0.08
<i>Grit Chamber</i>		67.29	39.26	28.04	22.43	17.84	15.29
<i>Fine Screens</i>		22.43	11.21	5.61	3.74	2.55	3.06
<i>CAS</i>		739.03	729.19	729.19	729.19	736.65	736.65
<i>Secondary Clarifier</i>		5.61	4.20	4.20	4.20	3.82	3.82
<i>Dual Media Filters</i>		3.16	3.14	2.35	2.09	2.02	2.02
<i>UV Disinfection</i>		86.44	86.44	84.44	86.88	87.51	84.00
Total		924.68	873.81	854.01	848.66	850.47	844.94
<i>Anaerobic Digester</i>		178.37	170.08	126.07	160.12	158.17	153.01
<i>Anaerobic Digester GHG Savings</i>		253.51	253.51	190.13	253.51	253.51	253.51
Net Total w/Digester		849.54	790.38	789.94	755.27	755.13	744.44
<i>Photovoltaic System GHG Savings</i>		217.65	197.46	197.46	197.46	201.14	201.14
Net Total w/PV		707.03	676.35	656.55	651.20	649.33	643.80
Net Total w/Digester and PV		631.89	592.92	592.48	557.81	553.99	543.30

GHG Emissions due to Electrical Energy Consumption at 8.8 MGD




Figure 9 – Greenhouse Gas Emissions due to Electrical Energy Consumption with and without Energy Generating Units at 8.8 MGD

4. Conclusion and Discussion

This research explored the renewable energy generation potential of a satellite WRP with the addition of a PV solar system and anaerobic digestion. This was performed for two types of facilities: conventional (CAS bioreactor with secondary clarifiers and dual media filtration) and advanced (bioreactor with membrane filtration) treatment satellite WRPs. In addition, the associated GHG emissions for both conventional and advanced treatment processes were evaluated. For conventional treatment, it was found that 9.9% and 23.3% of the facility’s total energy consumption can be generated by anaerobic digestion and solar energy, respectively. For advanced treatment, 5.2% and 4.4% of the facility’s total energy consumption can be generated by anaerobic digestion and solar energy, respectively. It was observed that energy recovery generation for both anaerobic digestion and PV systems is constant on a per million

gallon basis. When both energy generating units are incorporated in satellite WRPs, an average energy savings of 33.2% is accomplished in a CAS facility and 9.6% in a MBR facility, resulting in MBR WRPs averaging 1.86 times more energy intensive than CAS WRPs. This translates to a cost savings in electricity of \$25.34/MG treated for MBR facilities and \$45.88/MG treated at CAS facilities using an average commercial energy rate of \$0.10/kWh. The payback periods for both anaerobic digestion and solar energy were investigated and it was found that no matter the energy rate or the incentive, solar energy requires on average 40% longer to pay back compared to anaerobic digestion.

Furthermore, the results of this research showed that in terms of GHG emissions, MBR WRPs without energy generating units are 1.91 times more intensive than CAS WRPs and 2.59 times more intensive with energy generating units. With or without energy generating units, GHG emissions are still very large at WRPs. For MBR WRPs, 1,656 kg CO₂e/MG treated is emitted without energy generating units at the facilities, while 1,497 kg CO₂e/MG treated is emitted at the facilities with energy generating units. For CAS WRPs, 866 kg CO₂e/MG treated is emitted at facilities without energy generating units, while 579 kg CO₂e/MG treated is emitted at facilities with energy generating units. This research has shown that with the addition of energy generating units the energy consumption of the facility can have the potential to be greatly decreased. Performing such energy analyses will provide a means for engineers and operators in the decision making process regarding sustainability of using advanced or conventional treatment technologies at a reuse facility. The term 'energy hog' is often used for satellite WRPs. With time, as more energy saving and producing measures are

implemented, satellite WRPs will have the prospective to be termed 'energy neutral' facilities, in replacement of 'energy hog'.

CHAPTER 4

CONCLUSIONS

Wastewater treatment is a very energy intensive process and with the continued increase in satellite water reuse plants (WRPs), and the associated advanced treatment processes with these plants, this energy consumption will only increase. In the arid southwestern United States where nutrient requirements must be met, along with the strict standards and regulations on reuse water, increased energy consumption is inevitable. This research investigated the intertwined resources of wastewater and energy, along with the associated greenhouse gas (GHG) emissions from the treatment of wastewater at satellite WRPs. With the growing concerns of GHG emissions and linked crucial environmental problems, implementation of renewable energy resources was used to minimize these emissions. Objectives of this research were: (1) to investigate the impact of conventional and advanced treatment technologies on energy consumption at satellite WRPs; (2) to evaluate the impact of renewable technologies implementation on energy consumption and associated GHG generation at satellite WRPs; and (3) to compare energy footprint and associated real estate area required for advanced and conventional treatment technologies. The conclusions of this research are as follows:

- When comparing advanced treatment processes, membrane bioreactor (MBR), with conventional treatment processes, conventional activated sludge (CAS) with secondary clarifiers and dual media filters, the MBR requires on average 2.10 times more energy to treat to the same effluent quality for flowrates between 1 and 11 MGD.

- Comparing advanced disinfection, ultraviolet (UV) radiation, with conventional disinfection, chlorination, resulted in UV disinfection being 100 times more energy intensive for both MBR and CAS WRPs. When comparing the energy consumption of disinfecting membrane effluent against filter effluent with UV disinfection, it was found that an increase of 38.6% in energy is required to treat filter effluent with low-pressure lamps, and 63.0% with medium-pressure. Comparing energy consumption with low-pressure lamps versus medium-pressure lamps, it was found that medium-pressure lamps required an increase of 5.96 and 7.01 times in energy consumption for MBR and CAS WRPs, respectively. When disinfecting with chlorination, CAS WRPs require 2.8 times the amount of sodium hypochlorite needed compared to MBR WRPs.
- For flowrates between 1 to 11 MGD, MBR and CAS WRPs with low-pressure UV disinfection required on average 2643.3 and 1382.7 kWh/MG, respectively. This demonstrates the MBR WRPs are 1.91 times more energy intensive than CAS WRPs, costing an additional \$126.06/MG treated in energy consumption using an average commercial energy rate of \$0.10/kWh.
- The highest energy consuming unit in the MBR WRP contributing to the large energy footprint is the air scour blowers; requiring on average 23.7% of the facility's total energy consumption.
- A sensitivity analysis on 'wire-to-water' efficiencies has shown that even with a slight increase or decrease in efficiencies ($\pm 5\%$ for pumps and $\pm 10\%$ for blowers), the total energy consumption of the entire plant can be greatly affected, by as much as an 11.3% increase or 9.4% decrease.

- Comparing basin real estate area between the MBR and CAS WRPs, it was found that the CAS WRPs required a doubling in aeration volume, resulting in a doubling in the acreage. Total real estate area (the addition of secondary treatment and filtration units) for MBR WRPs was on average 1666 ft²/MG, while CAS WRPs was 4585 ft²/MG. Comparing total real estate yields an increase of 2.75 times in acreage for CAS WRPs. This means it costs MBR WRPs an increase in energy consumption of 0.43 kWh/MG per square foot of real estate saved or \$21.50/MG per 500 ft² of real estate saved.
- Using the real estate area for photovoltaic (PV) solar systems, 4.4% of the facility's total energy consumption can be generated for MBR WRPs and 23.3% can be generated for CAS WRPs.
- If anaerobic digesters were to be added to a plant's unit processes for energy generation by primary sludge digestion, 5.2 and 9.9% of the total facility's energy consumption can be generated for MBR and CAS WRPs, respectively.
- When both PV solar systems and anaerobic digesters are incorporated at a WRP, savings in energy can be 9.6 and 33.2% of the total facilities energy consumption for MBR and CAS WRPs, respectively. This translates to a cost savings in electricity of \$25.34/MG treated for MBR facilities and \$45.88/MG treated at CAS facilities.
- With or without the use of energy generating units, GHG emissions due to electrical energy consumption are still very large at WRPs. Considering an energy fuel mix of 60% natural gas, 25% coal, 7% hydroelectric, 7% geothermal, and 1% solar, emissions for MBR WRPs are 1,656 kg CO₂e/MG treated without

energy generating units at the facilities, while 1,497 kg CO₂e/MG treated is emitted at the facilities with energy generating units. This is a reduction of 9.6%. For CAS WRPs, 866 kg CO₂e/MG treated is emitted at facilities without energy generating units, while 579 kg CO₂e/MG treated is emitted at facilities with energy generating units. Achieving a 33.2% reduction.

This research has shown that with the use of design criteria and equations for unit processes, along with their associated fundamental energy equations, engineers can determine a very accurate estimate of energy consumption for individual unit processes of an entire WRP. The values found closely match actual energy consumption reported by various literature. This approach highlights a means for engineers and operators to target unit processes that are candidates for reduction in energy consumption and provide a basis for decision making regarding sustainability of using advanced treatment technologies at a reuse facility. In addition, with the increase in satellite WRPs and the overall increase in advanced treatment technologies at wastewater treatment plants in general, evaluations on the consumption of energy at these facilities needs to be a part of the design process; providing pros and cons to determine the need for certain unit process and the overall sustainability of the facility.

This research has provided a beginning in the determination of energy consumption and the corresponding GHG emissions inside satellite WRPs. Both advanced and conventional treatment processes commonly used at these facilities have been evaluated in this study. Two forms of renewable energy generation were also evaluated to determine the energy savings and GHG reduction that can be achieved at

these facilities. However, this study is not comprehensive and much work remains to be performed. Below are suggestions for future research:

- To investigate the impact on energy consumption for different advanced and conventional treatment processes other than the ones investigated in this research.
- Investigate the potential energy generation for other renewable technologies.
- To design and evaluate a total facility layout for which actual drawings are available. In this matter a complete facility energy calculation can be done as pumping stations will now be included (e.g. influent pumping station, primary effluent pumping station, and filter influent pumping station).
- To evaluate renewable energy implementation in facilities for which actual drawings are available. This will provide a total acreage of the facility giving the ability to increase solar area to the tops of structures (e.g. rooftops and parking structures).
- To perform equipment energy audits as equipment ages to determine if energy consumption of the reuse facility increases with age.
- To perform life cycle analysis to compare GHG emissions of various unit processes.
- To evaluate total GHG emissions from WRPs, this includes emissions from the unit processes themselves (e.g. carbon dioxide, methane, and nitrous oxide from biological treatment with activated sludge).

APPENDIX A

DESIGN PARAMETERS AND EQUATIONS FOR UNIT OPERATIONS AND

ENERGY COMPUTATION EQUATIONS USED

A-1 Coarse Screens

The initial open channel leading into the coarse screens was designed using Manning's equation:

$$Q = \frac{K_n}{n} AR^{2/3} S^{1/2} \text{ (Sturm, 2010; Mays, 2010)}$$

where Q = flow rate; $K_n = 1.0$ with R in m and Q in m³/s, and 1.49 for R in ft and Q in ft³/s; n = Manning's coefficient; R = hydraulic radius; and S = bed slope. For purposes of this research, a value of 0.015 (Sturm, 2010; Mays, 2010) was used for the Manning's coefficient in determination of channel properties. Velocity in this channel should exceed 1.3 ft/sec (0.4 m/s) during minimum flows to ensure grit deposition is avoided (WEF, 2010a). If this is impossible due to diurnal flows, a velocity of 3 ft/sec (0.9 m/s) should be used during peak flows to ensure resuspension of solids (WEF, 2010a). The maximum approach velocity was in the desired range at 2.35 ft/sec (Metcalf & Eddy, Inc, 2003; Qasim, 1999; WEF, 2010a). Key parameters used in the design can be found in Table A 1.

Table A 1 – Coarse Screen Design Parameters

Parameter	Value	Unit	Reference(s)
Bar width	5-15	mm	(Metcalf & Eddy, Inc, 2003; Davis, 2010)
	8-10	mm	(Qasim, 1999)
Clear spacing between bars	10-50	mm	(Metcalf & Eddy, Inc, 2003)
	15-75	mm	(Qasim, 1999)
	6-75	mm	(Davis, 2010)
Bar angle from vertical	0-30	°	(Metcalf & Eddy, Inc, 2003; Davis, 2010)
	5-15	°	(Qasim, 1999)
Bar shape factor for sharp-edged rectangular bars	2.42	–	(Qasim, 1999; Lin, 2007; WEF, 2010a)
Maximum approach velocity	0.6-1.0	m/s	(Metcalf & Eddy, Inc, 2003; Qasim, 1999)
	0.6-1.2	m/s	(WEF, 2010a)
Minimum headloss	6	in	(WEF, 2010a)
Average headloss	2-24	in	(WEF, 2010a)
Maximum headloss	36	in	(WEF, 2010a)

To determine the headloss across the screen the following equations were used:

$$h_L = \frac{1}{C} \left(\frac{V^2 - v^2}{2g} \right) \text{ (Metcalf & Eddy, Inc, 2003; Qasim, 1999; Lin, 2007) or}$$

$$h_L = \frac{k(V^2 - v^2)}{2g} \text{ (Davis, 2010; WEF, 2010a); and}$$

$$h_L = \beta \left(\frac{W}{b} \right)^{4/3} h_v \sin \theta \text{ (Qasim, 1999; Lin, 2007; WEF, 2010a)}$$

where h_L = headloss; C = empirical discharge coefficient to account for turbulence and losses; k = friction coefficient; V = velocity of flow through the openings of the screen; v = approach velocity upstream of the screen; g = gravitational acceleration; β = bar shape factor; W = maximum cross-sectional width of screen in the direction facing the flow; b = minimum clear space of the screen; h_v = velocity head upstream of the screen; and θ = angle of bars from horizontal. The values for C are dependent on whether a headloss for clean or clogged screen is desired. For clean screens the value is typically

0.7 and for 50% clogged screens the value is 0.6 (Metcalf & Eddy, Inc, 2003; Qasim, 1999; Lin, 2007). The same goes for the values of k . For clean screens the value is typically 1.4 and for partially blinded screens the value is 1.7 (Davis, 2010; WEF, 2010a). For calculating the headloss including the coarse screen angle, a value of 70° (Metcalf & Eddy, Inc, 2003; Davis, 2010; Qasim, 1999) was used and a value of 2.42 (Qasim, 1999; Lin, 2007; WEF, 2010a) was used for the bar shape factor for sharp-edged rectangular bars. Both the modified minor loss headloss equation and the Kirshmer's equation were used to calculate headloss; the higher of the two governed for the design. Energy consumption for the coarse screens is driven by the size of the motor that powers the rake and the rake cleaning frequency. Based on channel and screen dimensions, a motor size for the rake was obtained using a graphical method provided by a screen manufacturer (Vulcan Industries, Inc, 2011). Using this motor size, energy consumption was determined for cleaning intervals 15, 20, and 30 minutes using a manufacture raking speed of 20 ft/min. Table A 2 shows the design for the coarse screens for the 8.8 MGD WRP facility.

Table A 2 – Coarse Screen Design at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Influent Channel Design Parameters		
Channel Width	4	ft
Channel Slope	0.05	%
Manning's Coefficient	0.015	
Influent Channel Calculations		
Average Flow Height	1.78	ft
Average Flow Velocity	2.13	ft/sec
Peak Flow Height	2.40	ft
Peak Flow Velocity	2.35	ft/sec
Coarse Screen Design Parameters		

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Bar Width	5-15	mm
	8-10	mm
Clear spacing between bars	10-50	mm
	15-75	mm
	6-75	mm
Bar angle for vertical	0-30	°
	5-15	°
Bar Shape Factor for sharp-edged rectangular bars	2.42	
Coarse Screen Calculations		
Bar Spacing	0.75	in
Bar Width	0.375	in
Bar Angle from horizontal	70	°
Number of bars	43	
Available space through bars	2.69	ft
Maximum cross section width	1.34	ft
Average Flow Velocity through bars	3.17	ft/sec
Peak Flow Velocity through bars	3.50	ft/sec
<i>Clean w/angle</i>		
Average Flow Headloss	0.063748	ft
Peak Flow Headloss	0.077624	ft
<i>Clean w/o angle</i>		
Average Flow Headloss	0.122633	ft
Peak Flow Headloss	0.149325	ft
<i>Clogged w/o angle</i>		
Average Flow Headloss	0.925478	ft
Peak Flow Headloss	1.126918	ft
Power Requirements - 15 min Interval		
Motor size	2	Hp
Motor size	1.492	kW
Rake speed	20	ft/min
Screen length	10	ft
Time to complete one rake	0.5	min
Time between cleanings	15	min
Number of cleanings	93	
Time spent cleaning	46.5	min/day
Total energy consumption	1.1563	kWh/day
Power Requirements - 20 min Interval		
Motor size	2	Hp
Motor size	1.492	kW

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Rake speed	20	ft/min
Screen length	10	ft
Time to complete one rake	0.5	min
Time between cleanings	20	min
Number of cleanings	71	
Time spent cleaning	35.5	min/day
Total energy consumption	0.882767	kWh/day
Power Requirements - 30 min Interval		
Motor size	2	Hp
Motor size	1.492	kW
Rake speed	20	ft/min
Screen length	10	ft
Time to complete one rake	0.5	min
Time between cleanings	30	min
Number of cleanings	48	
Time spent cleaning	24	min/day
Total energy consumption	0.5968	kWh/day

A-2 Aerated Grit Chamber

Parameters used in the design of the aerated grit chamber can be found in Table A 3.

Table A 3 – Aerated Grit Chamber Design Parameters

Parameter	Value	Unit	Reference(s)
Detention time at peak flow	2-5	min	(Metcalf & Eddy, Inc, 2003; Qasim, 1999; Davis, 2010)
	3-10	min	(WEF, 2010a)
Air supply per unit length	3-8	cfm/ft	(Metcalf & Eddy, Inc, 2003; Qasim, 1999; WEF, 2010a)
Depth	2-5	m	(Metcalf & Eddy, Inc, 2003; Qasim, 1999; Davis, 2010)
	3.7-5	m	(WEF, 2010a)
Length	7.5-20	m	(Metcalf & Eddy, Inc, 2003; Qasim, 1999)
	7.5-27.5	m	(Davis, 2010)
Width	2.5-7	m	(Metcalf & Eddy, Inc, 2003; Qasim, 1999; Davis, 2010)
Width-depth ratio	1:1-5:1	–	(Metcalf & Eddy, Inc, 2003; Qasim, 1999; Davis, 2010)
	0.8:1-1:1	–	(WEF, 2010a)
Length-width ratio	2.5:1-5:1	–	(Qasim, 1999; Davis, 2010)
	3:1-5:1	–	(Metcalf & Eddy, Inc, 2003)
	3:1-8:1	–	(WEF, 2010a)

To determine the hydraulic retention time (HRT) inside the aerated grit chamber the following equation was used:

$$\theta = \frac{V}{Q} \text{ (Metcalf \& Eddy, Inc, 2003; Davis, 2010; Qasim, 1999; WEF, 2010a)}$$

where θ = HRT; V = volume of the tank; and Q = flow rate flowing through the tank.

To determine the volume of the grit basin a depth of 10 feet (Metcalf & Eddy, Inc, 2003; Davis, 2010; Qasim, 1999), width-depth ratio of 1.6 (Metcalf & Eddy, Inc, 2003; Davis, 2010; Qasim, 1999), and a length-width ratio of 2.5 (Davis, 2010; Qasim, 1999) were chosen. Energy consumption for the aerated grit chamber is driven by the air blower

capacity used to maintain discrete particle sedimentation and can be estimated by the following equation:

$$BHP = [(4.28E - 4)q_s T_a / e]^* [(P_d / P_b)^{0.283} - 1] \quad (\text{U.S. EPA, 1989})$$

where BHP = brake horsepower, hp; q_s = required flow rate, scfm; T_a = blower inlet air temperature, °R; e = blower and motor combined efficiency; P_d = blower discharge pressure, psia (the addition of atmospheric pressure and the system head); and P_b = field atmospheric pressure, psia. System head was estimated as per (U.S. EPA, 1989) using headloss values for diffuser (0.70 psi; 4.826 kPa), piping (0.15 psi; 1.034 kPa), and inlet valve and filter headloss (0.30 psi; 2.068 kPa). Atmospheric pressure at 2,000 feet (609.6 meters) elevation was used and a combined blower and motor efficiency of 80% were assumed (Metcalf & Eddy, Inc, 2003; Davis, 2010). Table A 4 shows the design for the aerated grit chamber for the 8.8 MGD WRP facility.

Table A 4 – Aerated Grit Chamber Design at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
<i>Aerated Grit Chamber Design Parameters</i>		
Number of hoppers	3	
Detention time at peak flow	2-5	min
	3-10	min
Air supply per unit length	3-8	cfm/ft
<i>Dimensions</i>		
Depth	2-5	m
	3.7-5	m
Length	7.5-20	m
	7.5-27.5	m
Width	2.5-7	m
Width-depth ratio	1:1-5:1	
	0.8:1-1:1	
Length-width ratio	2.5:1-5:1	
	3:1-5:1	

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
	3:1-8:1	
Aerated Grit Chamber Calculations		
<i>Dimensions</i>		
Detention time required at peak flow	4.5	min
Volume required	6098	ft ³
Depth	10	ft
Width-depth ratio	1.6	:1
Width	16	ft
Length-width ratio	2.5	:1
Length	40	ft
Volume provided	6400	ft ³
Detention time provided	4.72	min
<i>Air Requirement</i>		
Air criteria requirement per unit length	8	cfm/ft
Air required	320	ft ³ /min
<i>Blower and Diffuser Design</i>		
Blower peaking capacity factor	1.5	
Blower capacity requirement	480	ft ³ /min
Diffuser Capacity	30	ft ³ /min
Number of diffusers	16	
Energy Requirement		
Static head	4.335	psi
Diffuser headloss	0.70	psi
Piping headloss	0.15	psi
Inlet valve and filter headloss	0.30	psi
System head	5.485	psig
Atmospheric pressure (2000 ft)	13.779	psia
Discharge pressure	19.264	psia
Efficiency (blower & motor combined)	0.8	
Brake horsepower	14	Hp
Motor size	10.444	kW
Total energy consumption	250.656	kWh/day

A-3 Fine Screens

Design and considerations for the open channel before the fine screens are the same as for the open channel before the coarse screens. Parameters used in the design for the fine screen can be found in Table A 5.

Table A 5 – Fine Screen Design Parameters

Parameter	Value	Unit	Reference
Perforation size	1-3	mm	(WEF, 2010a)
	2-24	in	(WEF, 2010a)
Average headloss	30-54	In	(Metcalf & Eddy, Inc, 2003)
Maximum headloss	≥36	in	(WEF, 2010a)

To determine the headloss across the screen the following equation was used

$$h_L = \frac{1}{2g} \left(\frac{v}{C} \right)^2 = \frac{1}{2g} \left(\frac{Q}{CA} \right)^2 \quad (\text{Metcalf \& Eddy, Inc, 2003; Davis, 2010; Lin, 2007; WEF, 2010a})$$

where h_L = headloss; v = approach velocity; C = discharge coefficient; g = gravitational acceleration; Q = discharge through screen; and A = effective open area of submerged screen. For the headloss of a clean screen, the value for C is 0.60 to 0.61 (Metcalf & Eddy, Inc, 2003; Qasim, 1999; Davis, 2010; WEF, 2010a). If headloss is desired for other than clean screens, a blinding factor of up to 50% can be applied by reducing the open area of the submerged screen by the same percentage (WEF, 2010a). Typical effective open areas for fine screens and their corresponding solid removal rates are shown in Table 3. Energy consumption for the fine screens was computed using the same procedure as for the coarse screens, except the motor for the screen is ran

continuously. Table A 6 shows the design for the fine screen for the 8.8 MGD WRP facility.

Table A 6 – Fine Screen Design at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Influent Channel Design Parameters		
Channel Width	2.5	ft
Channel Slope	0.05	%
Manning's Coefficient	0.015	
Influent Channel Calculations		
Average Flow Height	2.97	ft
Average Flow Velocity	2.04	ft/sec
Peak Flow Height	4.17	ft
Peak Flow Velocity	2.16	ft/sec
Fine Screen Design Parameters		
Perforation Size	2	mm
Effective Open Area	30	%
Coefficient of Discharge	0.61	
Fine Screen Calculations		
Average Flow Cross-sectional Area	7.43	ft ²
Peak Flow Cross-sectional Area	10.44	ft ²
<i>Clean</i>		
Average Flow Headloss	1.93	ft
Peak Flow Headloss	2.17	ft
Energy Requirement		
Motor size	2	Hp
Motor size	1.492	kW
Screen speed	18	ft/sec
Screen length	10	ft
Time to complete one band	0.555556	min
Time spent cleaning	1440	min/day
Total energy consumption	35.808	kWh/day

A-4 Activated Sludge (Bioreactor)

A five-stage modified Bardenpho CAS system is provided for nutrient removal of both phosphorous and nitrogen (WEF, 2012; WEF, 2011). The BOD and solids removal by

the coarse and fine screens were based on data provided by manufacturers (Table 4). Microbiological parameters of the activated sludge process can be found in Table 5. Key design parameters for the activated sludge system are found in Table A 7 and design equations are found in Table A 8.

Table A 7 – Activated Sludge Design Parameters

Parameter	Value	Unit	Reference
Solids Retention Time	10	day	(Menniti, et al., 2011)
Internal Mixed Liquor Recycle (IMLR)	200	%	(WEF, 2010a; WEF, 2006; WEF, 2011)
Return Activated Sludge (RAS) Recycle Ratio – MBR	400	%	(WEF, 2010a; WEF, 2006; WEF, 2012)
RAS Recycle Ratio – CAS	100	%	(WEF, 2010a; Metcalf & Eddy, Inc, 2003)
VFA	43	mg/L	

Table A 8 – Design Equations for Activated Sludge Process

Parameter	Equation	Reference
Hydraulic Retention Time (HRT)	$\theta_x = \frac{V}{Q^0} = \frac{V(1+R)}{Q}$	(Rittmann, et al., 2001)
HRT in Reactor	$\theta_r = \frac{1}{\hat{q}X_a} \left[K \ln \left(\frac{S^i}{S} \right) + (S^i - S) \right]$	(Rittmann, et al., 2001)
Solids retention time (SRT)	$\theta_x = \frac{X_a V}{X_a^e Q^e + X_a^w Q^w}$	(Rittmann, et al., 2001)
SRT at which microorganisms washout	$\theta_x^{\min} = \frac{K + S^0}{S^0(Y\hat{q} - b) - Kb} \quad S \rightarrow S^0$ $[\theta_x^{\min}]_{\lim} = \frac{1}{Y\hat{q} - b} \quad S \rightarrow \infty$	(Rittmann, et al., 2001)
Reactor substrate concentration	$S = K \frac{1 + b\theta_x}{\theta_x(Y\hat{q} - b) - 1}$	(Rittmann, et al., 2001)
Reactor minimum substrate concentration	$S_{\min} = K \frac{b}{Y\hat{q} - b} \quad \theta_x \rightarrow \infty$	(Rittmann, et al., 2001)

Parameter	Equation	Reference
Reactor active microorganism concentration	$X_a = \theta_x \frac{X(-r_{ut})}{1 + b\theta_x}$ $X_a = \frac{\theta_x Y(S^0 - S)}{\theta (1 + b\theta_x)}$	(Rittmann, et al., 2001)
Reactor inert microorganism concentration	$X_i = \frac{\theta_x}{\theta} [X_i^0 + X_a(1 - f_d)b\theta]$	(Rittmann, et al., 2001)
Reactor volatile suspended solids concentration	$X_v = X_i + X_a$ $X_v = \frac{\theta_x}{\theta} \left[X_i^0 + \frac{Y(S^0 - S)(1 + (1 - f_d)b\theta_x)}{1 + b\theta_x} \right]$	(Rittmann, et al., 2001)
Active biological sludge production rate	$r_{abp} = \frac{X_a V}{\theta_x}$	(Rittmann, et al., 2001)
Total biological solids production rate	$r_{tbp} = \frac{X_v V}{\theta_x}$	(Rittmann, et al., 2001)
Substrate-utilization-associated products	$UAP = -\frac{(\hat{q}_{UAP} X_a \theta + K_{UAP} + k_1 r_{ut} \theta)}{2} + \frac{\sqrt{(\hat{q}_{UAP} X_a \theta + K_{UAP} + k_1 r_{ut} \theta)^2 - 4K_{UAP} k_1 r_{ut} \theta}}{2}$	(Rittmann, et al., 2001)
Biomass-associated products	$BAP = -\frac{(K_{BAP} + (\hat{q}_{BAP} - k_2) X_a \theta)}{2} + \frac{\sqrt{(K_{BAP} + (\hat{q}_{BAP} - k_2) X_a \theta)^2 + 4K_{BAP} k_2 X_a \theta}}{2}$	(Rittmann, et al., 2001)
Soluble microbial products	$SMP = UAP + BAP$	(Rittmann, et al., 2001)

The internal mixed liquor recycle (IMLR) needed for denitrification is typically between 200 and 500% of the average influent flow for a five-stage modified Bardenpho CAS system (WEF, 2012; WEF, 2011; WEF, 2010a). For purposes of this research 200% was used. In an MBR system, return activated sludge (RAS) rates are required to be higher compared to CAS process. For a MBR system, RAS rates are typically 200 to 500% of

the average influent flow, versus 50 to 100% in CAS systems (WEF, 2012; WEF, 2006; WEF, 2010a). A MBR system also requires a higher MLSS concentration compared to CAS systems. For a MBR system, the MLSS concentration inside the bioreactor tank can be between 4,000 to 10,000 mg/L and inside the membrane tank 8,000 to 18,000 mg/L, versus 1,500 to 3,500 mg/L in CAS systems (WEF, 2012; WEF, 2006; WEF, 2010a). Energy consumption for the activated sludge process is driven by mixers used to maintain particles suspension in the anaerobic and anoxic zones of the biological nutrient removal system, and blowers used to provide oxygen and particle suspension in the aerated zones. In addition, energy is required to operate the IMLR pumps and RAS pumps. Mixer energy requirement was determined based on the basin volume and the type of mixer. For horizontal mixers the required energy used was 7 W/m³ (WEF, 2010a). Blower energy was determined using the blower equation and a combined blower and motor efficiency of 80% (Metcalf & Eddy, Inc, 2003; Davis, 2010). Energy requirements for pumps after they have been sized were determined as (Jones, et al., 2008):

$$BHP = \frac{qH}{3960E_p}$$

where *BHP* = brake horsepower, hp; *q* = required flow rate, gal/min; *H* = total dynamic head, ft; and *E_p* = pump efficiency. Efficiencies for both the IMLR and RAS pumps were chosen in ranges from pump data and curves. A pump efficiency of 80% was used for both pumps (Goulds Pumps, 2012). Table A 9, Table A 10, and Table A 11 show the design for the anaerobic, anoxic, and aerobic tanks for the 8.8 MGD MBR WRP facility, respectively. Table A 12, Table A 13, and Table A 14 show the design for the anaerobic, anoxic, and aerobic tanks for the 8.8 MGD CAS WRP facility, respectively.

Table A 9– Anaerobic Tank Design at 8.8 MGD for MBR WRP

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Flow Parameters		
Maximum Month	2.2	MGD
Maximum Month	3.4034	cfs
Flow Type	Complete Mix Assumed	
4 Trains		
Tank Sizing		
Length	24	ft
Width	26	ft
Depth	19.1	ft
Volume	11918.4	ft ³
Influent Parameters		
Assume 50% BOD Removal in Fine Screens	0.5	
Assume 80% TSS Removal in Fine Screens	0.8	
VFA	43	mg/L
TSS	61.8	mg/L
BOD	125	mg/L
BOD _L	187.5	mg/L
Acetate to COD Conversion	1.048	g COD/g Acetate
Microbiological Parameters – PAOs		
K	1	mg VFA/L
Y	0.3	g VSS/g VFA
\hat{q}	3.17	g VFA/g VSS-day
$\hat{\mu}$	0.95	g VSS/g VSS-day
b	0.04	g VSS/g VSS-day
f_d	0.8	
Anaerobic Zone Design		
SRT	10	days
HRT	0.041	days
HRT	58	minutes
S_{min}	0.044	mg VFA/L
S	-1.0400	mg VFA/L
X_a Generated In An Zone	9.2049	mg VSS/L
X_i Generated In An Zone	0.0104	mg VSS/L
VFAs Remaining	0.044	mg VFA/L

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
VFAs Remaining to BOD _L	0.046	mg BOD _L /L
VFAs Removed	42.956	mg VFA/L
VFAs Removed to BOD _L	45.02	mg BOD _L /L
BOD _L to Anoxic Zone	142	mg BOD _L /L

Table A 10 – Anoxic Tank Design at 8.8 MGD for MBR WRP

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Flow Parameters		
Maximum Month	2.2	MGD
Maximum Month	3.4034	cfs
Flow Regime	Complete Mix Assumed	
4 Trains		
Tank Sizing		
Length	24	ft
Width	26	ft
Depth	19.1	ft
Volume	11918.4	ft ³
Influent Parameters		
TSS	102	mg/L
BOD	95	mg/L
BOD _L	142	mg/L
Microbiological Parameters – Denitrifiers (Pseudomonas)		
K	12.6	mg BOD _L /L
Y	0.26	g VSS/g BOD _L
\hat{q}	12.00	g BOD _L /g VSS-day
$\hat{\mu}$	3.12	g VSS/g VSS-day
b	0.05	g VSS/g VSS-day
f_d	0.8	
Anoxic Zone Design		
S ^o	36	mg NO ₃ ⁻ -N/L
SRT	10	days
HRT	0.041	days
HRT	58	minutes
IR Actual	2	N/A
Estimated N _e For IR	4.95	mg NO ₃ ⁻ -N/L

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
IR Equation	2.17	N/A
X _b	1805.9	mg/L
Flow Rate to Anoxic Tank	49967	m ³ /day
NO ₃ Estimate for NO _x Feed	5.80	mg NO ₃ ⁻ -N/L
NO _x Feed	289811	g NO ₃ ⁻ -N/day
V _{nox}	337.49	m ³
F/M _b	1.30	g/g-day
Assumed rbCOD/COD	0.30	N/A
SDNR	0.34	g NO ₃ ⁻ -N/g VSS-day
SDNR _{adj}	0.32	g NO ₃ ⁻ -N/g VSS-day
NO _r	195303	g NO ₃ ⁻ -N/day
SDNR (MLSS)	0.20	g/g-day
BOD _L Consumed	110.0	mg/L
X _a	1343.8	mg VSS/L
X _i	134.4	mg VSS/L
X _v	1478.2	mg VSS/L
Δ $\bar{X}_V/\Delta t$	47.2	kg VSS/day
Oxygen Credit	708	kg/d
Oxygen Credit	29.5	kg/hour
Alkalinity Produced	106.1	mg/L as CaCO ₃
Phosphorous Removed	0.11	mg P/L

Table A 11 – Aerobic Tank Design at 8.8 MGD for MBR WRP

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Flow Parameters		
Maximum Month	2.2	MGD
Maximum Month	3.4034	cfs
Maximum Month	8328	m ³ /day
Flow Regime	Plug Flow Assumed	
4 Trains		
Tank Sizing		
Length	60	ft
Width	26	ft

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Depth	19.1	ft
Volume	29796	ft ³
Influent Parameters		
TSS	102	mg/L
Assumed Volatile Portion of TSS	0.81	NA
VSS	82.62	mg/L
BOD	95	mg/L
BOD _L	142	mg/L
TKN	42	mg/L
P	4.68	mg/L
BOD Microbiological Parameters – Heterotrophic Microorganisms		
K	10	mg BOD/L
Y	0.45	mg VSS/mg BOD _L
\hat{q}	20.00	mg BOD/mg VSS
$\hat{\mu}$	9	mg VSS/mg VSS-day
b	0.15	mg VSS/mg VSS-day
f_d	0.8	
$[\theta_x^{\min}]_{\text{lim}}$	0.113	day
Nitrification Microbiological Parameters – Nitrosomonas (Ammonia Donor)		
K	1	mg NH ₄ ⁺ -N/L
Y	0.33	g VSS/g NH ₄ ⁺ -N
\hat{q}	2.30	g NH ₄ ⁺ -N/g VSS-day
$\hat{\mu}$	0.76	g VSS/g VSS-day
b	0.11	g VSS/g VSS-day
f_d	0.8	
$[\theta_x^{\min}]_{\text{lim}}$	1.541	day
Nitrification Microbiological Parameters – Nitrobacter (Nitrite Donor)		
K	1.3	mg NO ₂ ⁻ -N/L
Y	0.083	g VSS/g NO ₂ ⁻ -N
\hat{q}	9.80	g NO ₂ ⁻ -N/g VSS-day
$\hat{\mu}$	0.81	g VSS /g VSS-day
b	0.11	g VSS/g VSS-day

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
f_d	0.8	
$[\theta_x^{\min}]_{\text{lim}}$	1.422	day
Effluent Criteria		
BOD	30	mg BOD/L
TSS	30	mg TSS/L
Ammonia	0.4	mg NH ₄ ⁺ -N/L
Total P	0.2	mg P/L
Total N	10	mg N/L
Operational Assumptions		
SRT	10	day
R ¹	4	N/A
θ	0.10	day
θ_r	0.02	day
$\theta_{\text{totalsystem}}$	0.14	day
BOD		
Left side of Equation 5.54, 5.55, 5.57	0.100	day ⁻¹
S	1.00E-200	mg BOD _L /L
e for Equation 5.55	2319.3	
Right Side of Equation 5.55	-0.10	day ⁻¹
Right Side of Equation 5.57	0.12	day ⁻¹
S _{min}	0.17	mg BOD _L /L
S ⁱ	29	mg BOD _L /L
\bar{X}_a	1805.9	mg VSS/L
Right Side of Equation 5.54	0.20	day ⁻¹
θ_r left side of Equation 5.53	0.02	day
Right side of Equation 5.53	0.13	day
\bar{X}_i	386.94	mg VSS/L
\bar{X}_v	2192.9	mg VSS/L
$\Delta\bar{X}_v/\Delta t$	277.3	kg VSS/day
Ammonia Removed by BOD Bacteria	4.1	mg NH ₄ ⁺ -N/L
Phosphorous removed by BOD Bacteria	0.67	mg P/L
Nitrosomonas		
S ⁰	37.9	mg NH ₄ ⁺ -N/L
Left side of Equation 5.54, 5.55, 5.57	0.100	day ⁻¹

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
S	1.00E-16	mg NH ₄ ⁺ -N/L
e for Equation 5.55	194.3	
Right Side of Equation 5.55	0.01	day ⁻¹
Right Side of Equation 5.57	0.23	day ⁻¹
S _{min}	0.17	mg NH ₄ ⁺ -N/L
S ⁱ	8	mg NH ₄ ⁺ -N/L
\bar{X}_a	417.7	mg VSS/L
Right Side of Equation 5.54	0.18	day ⁻¹
θ_r left side of Equation 5.53	0.02	day
Right side of Equation 5.53	0.05	day
\bar{X}_i	65.6	mg VSS/L
\bar{X}_v	483.3	mg VSS/L
$\Delta\bar{X}_v/\Delta t$	60.19	kg VSS/day
Nitrite Removed by Ammonia Bacteria	0.9	mg NO ₂ ⁻ -N/L
Phosphorous removed by Ammonia Bacteria	0.14	mg P/L
Nitrobacter		
S ⁰	37.0	mg NO ₂ ⁻ -N/L
Left side of Equation 5.54, 5.55, 5.57	0.100	day ⁻¹
S	1.00E-10	mg NO ₂ ⁻ -N/L
e for Equation 5.55	125.1	
Right Side of Equation 5.55	0.04	day ⁻¹
Right Side of Equation 5.57	0.31	day ⁻¹
S _{min}	0.20	mg BOD _L /L
S ⁱ	8	mg NO ₂ ⁻ -N/L
\bar{X}_a	102.5	mg VSS/L
Right Side of Equation 5.54	0.18	day ⁻¹
θ_r (left side of Equation 5.53)	0.02	day
Right side of Equation 5.53	0.04	day
\bar{X}_i	16.1	mg VSS/L
\bar{X}_v	118.6	mg VSS/L
$\Delta\bar{X}_v/\Delta t$	14.77	kg VSS/day
Nitrate Removed by Nitrite Bacteria	0.2	mg NO ₃ ⁻ -N/L
Phosphorous removed by Nitrite Bacteria	0.04	mg P/L
PAOs		

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
\bar{X}_a – aerobic zone due to recycle	649	mg VSS/L
\bar{X}_i – aerobic zone due to recycle	51.9	mg VSS/L
\bar{X}_v	700.9	mg VSS/L
$\Delta\bar{X}_v/\Delta t$	82.8	kg VSS/day
Phosphorous removed by PAO Bacteria	2.98	mg P/L
Nitrate Removed by PAO Bacteria	1.2	mg NO ₃ ⁻ -N/L
Effluent		
Phosphorous Effluent Estimated (Rittmann, et al., 2001)	0.74	mg P/L
Total Influent COD	250.00	mg COD/L
f_{us}	0.05	mg/mg COD
f_{up}	0.13	mg/mg COD
f_{cv}	1.48	mg COD/mg VSS
b_{hT}	0.24	g VSS/g VSS-day
SRT	10.00	days
Y_h	0.45	mg VSS/mg COD
γ	-0.21	mg P/mg VSS
P_f	2.70	
S_{bsa}	43.00	mg/L
f_{xa}	0.15	
f_p	0.015	mg P/mg VSS
f	0.2	mg/mg VSS
Part 1 of Equation 15.15 (WEF, 2010a)	-2.2E-02	
Part 2 of Equation 15.15	1.3E-03	
Phosphorous Removal Estimated by Equation 15.15	-5.10	mg P/L
Effluent P by Equation 15.15	0	mg P/L
P Removal by Figure 15.45 (WEF, 2010a)	0.017	mg P/mg COD
P Removal by Figure 15.45	4.250	mg P/L
Effluent P by Figure 15.45	0	mg P/L
Reactive Nitrate In Influent for P Reactor	1.208	mg/L
rbCOD/nitrate ratio	6.6	g rbCOD/g Nitrate
rbCOD (VFA)	43	mg/L
rbCOD Equivalent	7.98	mg/L
rbCOD available for P Removal	35.03	mg/L
rbCOD/P Ratio	10	g rbCOD/g P
Biological P Removal	3.50	mg/L
P Removal by other Bacteria	0.96	mg/L

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Total P Removal	4.46	mg/L
P in Effluent	0.22	mg P/L
Inert VSS pass through	19.38	mg VSS/L
Inert VSS Recycled pass through	1366	mg VSS/L
$\Delta\bar{X}_i/\Delta t$ pass through	161.4	kg VSSi/day
MLSS Total	6340.1	mg TSS/L
Oxygen Requirements		
Input O ₂ Requirements	3014	kg OD/day
Soluble Output O ₂ Equivalents	9.79	kg OD/day
Solid Output O ₂ Equivalents	926.7	kg OD/day
Oxygen Requirements	2077.71	kg OD/day
Oxygen Requirements	86.57	kg OD/hour
Oxygen Requirements w/Oxygen Credit		
Input O ₂ Requirements	2306	kg OD/day
Soluble Output O ₂ Equivalents	9.79	kg OD/day
Solid Output O ₂ Equivalents	926.7	kg OD/day
Oxygen Requirements	1369.80	kg OD/day
Oxygen Requirements	57.08	kg OD/hour
Fine Bubble Diffuser Design		
C ₂₀	9.08	mg/L
P _b /P _a	0.93	N/A
C _{s,T,H}	8.46	mg/L
P _{atm,H}	9.64	m
Diffuser Height From Bottom	0.610	m
Tank Height	5.82	m
Assumed Oxygen Transfer Efficiency	0.19	N/A
DO In Aeration Basin	2	mg/L
C _{s,T,H}	10.34	mg/L
α	0.5	N/A
β	0.95	N/A
F	0.9	N/A
SOTR	228.7	kg/hour
Assumed Efficiency	0.35	N/A
Air Density	1.204	kg/m ³
Air Flowrate	2419.6	m ³ /hour
Air Flowrate	40.3	m ³ /minute
Air Flowrate	1424	ft ³ /minute

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Required Blower Capacity Assuming 2 Safety Factor	2848.7	ft ³ /minute
Alkalinity Requirements		
Alkalinity Consumed	299.88	mg/L as CaCO ₃
Alkalinity Residual for pH 6.8-7	80	mg/L as CaCO ₃
Alkalinity Provided in CABI	271	mg/L as CaCO ₃
Alkalinity Required w/o Denitrification	108.88	mg/L as CaCO ₃
Alkalinity Required w/Denitrification	2.77	mg/L as CaCO ₃
Internal Recycle Pump Sizing		
Internal Recycle Pump Sizing	4.4	MGD
Internal Recycle Pump Sizing	3056	gpm
Total Dynamic Head	25	ft
Pump Efficiency	0.8	N/A
Brake Horsepower	25	Hp
Return Activated Sludge Pump Sizing		
Return Activated Sludge Pump Sizing	8.8	MGD
Return Activated Sludge Pump Sizing	6111	gpm
Total Dynamic Head	18	ft
Pump Efficiency	0.8	N/A
Brake Horsepower	35	Hp
Horizontal Mixer Sizing		
Energy Requirement per Mixer	7.0	W/m ³
Number of Mixers	3	N/A
Blower Sizing		
Required Blower Capacity	2848.7	ft ³ /min
Static Head	8.280	psi
Diffuser Headloss	0.70	psi
Piping Headloss	0.15	psi
Inlet Valve and Filter Headloss	0.30	psi
System Head	9.430	psig
Atmospheric Pressure (2000 ft)	13.779	psia
Discharge Pressure	23.209	psia
Efficiency (blower & motor)	0.8	N/A
Brake Horsepower	128	Hp
Energy Requirement		
Energy Required from Internal Recycle Pump	18.65	kW
	447.6	kWh/day
Energy Required from Return Activated Sludge Pump	26.11	kW
	626.64	kWh/day
Energy Required from Mixers	170.096	kWh/day

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Energy Required from Blower	95.488	kW
	2291.712	kWh/day
Total Energy Consumption	3536.048	kWh/day

Table A 12 – Anaerobic Tank Design at 8.8 MGD for CAS WRP

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Flow Parameters		
Maximum Month	2.2	MGD
Maximum Month	3.4034	cfs
Flow Type	Complete Mix Assumed	
4 Trains		
Tank Sizing		
Length	24	ft
Width	26	ft
Depth	19.1	ft
Volume	11918.4	ft ³
Influent Parameters		
Assume 50% BOD Removal in Fine Screens	0.5	
Assume 80% TSS Removal in Fine Screens	0.8	
VFA	43	mg/L
TSS	61.8	mg/L
BOD	125	mg/L
BOD _L	187.5	mg/L
Acetate to COD Conversion	1.048	g COD/g Acetate
Microbiological Parameters – PAOs		
K	1	mg VFA/L
Y	0.3	g VSS/g VFA
\hat{q}	3.17	g VFA/g VSS-day
$\hat{\mu}$	0.95	g VSS/g VSS-day
b	0.04	g VSS/g VSS-day
f_d \hat{q}	0.8	
Anaerobic Zone Design		
SRT	10	days
HRT	0.041	days
HRT	58	minutes

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
S_{min}	0.044	mg VFA/L
S	-1.0400	mg VFA/L
X_a Generated In An Zone	9.2049	mg VSS/L
X_i Generated In An Zone	0.0104	mg VSS/L
VFAs Remaining	0.044	mg VFA/L
VFAs Remaining to BOD_L	0.046	mg BOD_L /L
VFAs Removed	42.956	mg VFA/L
VFAs Removed to BOD_L	45.02	mg BOD_L /L
BOD_L to Anoxic Zone	142	mg BOD_L /L

Table A 13 – Anoxic Tank Design at 8.8 MGD for CAS WRP

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Flow Parameters		
Maximum Month	2.2	MGD
Maximum Month	3.4034	cfs
Flow Regime	Complete Mix Assumed	
4 Trains		
Tank Sizing		
Length	24	ft
Width	26	ft
Depth	19.1	ft
Volume	11918.4	ft ³
Influent Parameters		
TSS	102	mg/L
BOD	95	mg/L
BOD_L	142	mg/L
Microbiological Parameters – Denitrifiers (Pseudomonas)		
K	12.6	mg BOD_L /L
Y	0.26	g VSS/g BOD_L
\hat{q}	12.00	g BOD_L /g VSS-day
$\hat{\mu}$	3.12	g VSS/g VSS-day
b	0.05	g VSS/g VSS-day
f_d	0.8	
Anoxic Zone Design		
S^o	36	mg NO_3^- -N/L

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
SRT	10	days
HRT	0.041	days
HRT	58	minutes
IR Actual	2	N/A
Estimated N_e For IR	4.95	mg NO_3^- -N/L
IR Equation	5.17	N/A
X_b	1053.5	mg/L
Flow Rate to Anoxic Tank	24984	m ³ /day
NO_3 Estimate for NO_x Feed	5.80	mg NO_3^- -N/L
NO_x Feed	144906	g NO_3^- -N/day
V_{nox}	337.49	m ³
F/ M_b	2.22	g/g-day
Assumed rbCOD/COD	0.30	N/A
SDNR	0.34	g NO_3^- -N/g VSS-day
SDNR _{adj}	0.30	g NO_3^- -N/g VSS-day
NO_r	108375	g NO_3^- -N/day
SDNR (MLSS)	0.12	g/g-day
BOD _L Consumed	110.0	mg/L
X_a	783.9	mg VSS/L
X_i	78.4	mg VSS/L
X_v	862.3	mg VSS/L
$\Delta \bar{X}_v / \Delta t$	47.2	kg VSS/day
Oxygen Credit	708	kg/d
Oxygen Credit	29.5	kg/hour
Alkalinity Produced	106.1	mg/L as CaCO ₃
Phosphorous Removed	0.11	mg P/L

Table A 14 – Aerobic Tank Design at 8.8 MGD for CAS WRP

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Flow Parameters		
Maximum Month	2.2	MGD
Maximum Month	3.4034	cfs

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Maximum Month	8328	m ³ /day
Flow Regime	Plug Flow Assumed	
4 Trains		
Tank Sizing		
Length	120	ft
Width	26	ft
Depth	19.1	ft
Volume	59592	ft ³
Influent Parameters		
TSS	102	mg/L
Assumed Volatile Portion of TSS	0.81	NA
VSS	82.62	mg/L
BOD	95	mg/L
BOD _L	142	mg/L
TKN	42	mg/L
P	4.68	mg/L
BOD Microbiological Parameters – Heterotrophic Microorganisms		
K	10	mg BOD/L
Y	0.45	mg VSS/mg BOD _L
\hat{q}	20.00	mg BOD/mg VSS
$\hat{\mu}$	9	mg VSS/mg VSS-day
b	0.15	mg VSS/mg VSS-day
f_d	0.8	
$[\theta_x^{\min}]_{\text{lim}}$	0.113	day
Nitrification Microbiological Parameters – Nitrosomonas (Ammonia Donor)		
K	1	mg NH ₄ ⁺ -N/L
Y	0.33	g VSS/g NH ₄ ⁺ -N
\hat{q}	2.30	g NH ₄ ⁺ -N/g VSS-day
$\hat{\mu}$	0.76	g VSS/g VSS-day
b	0.11	g VSS/g VSS-day
f_d	0.8	
$[\theta_x^{\min}]_{\text{lim}}$	1.541	day
Nitrification Microbiological Parameters – Nitrobacter (Nitrite Donor)		

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
K	1.3	mg NO ₂ ⁻ -N/L
Y	0.083	g VSS/g NO ₂ ⁻ -N
\hat{q}	9.80	g NO ₂ ⁻ -N/g VSS-day
$\hat{\mu}$	0.81	g VSS /g VSS-day
b	0.11	g VSS/g VSS-day
f _d	0.8	
$[\theta_x^{\min}]_{\text{lim}}$	1.422	day
Effluent Criteria		
BOD	30	mg BOD/L
TSS	30	mg TSS/L
Ammonia	0.4	mg NH ₄ ⁺ -N/L
Total P	0.2	mg P/L
Total N	10	mg N/L
Operational Assumptions		
SRT	10	day
R ¹	1	N/A
θ	0.20	day
θ_r	0.10	day
$\theta_{\text{totalsystem}}$	0.24	day
BOD		
Left side of Equation 5.54, 5.55, 5.57	0.100	day ⁻¹
S	1.00E-200	mg BOD _L /L
e for Equation 5.55	929.6	
Right Side of Equation 5.55	-0.01	day ⁻¹
Right Side of Equation 5.57	0.12	day ⁻¹
S _{min}	0.17	mg BOD _L /L
S ⁱ	71	mg BOD _L /L
\bar{X}_a	1053.5	mg VSS/L
Right Side of Equation 5.54	0.15	day ⁻¹
θ_r left side of Equation 5.53	0.10	day
Right side of Equation 5.53	0.22	day
\bar{X}_i	263.36	mg VSS/L
\bar{X}_v	1316.9	mg VSS/L
$\Delta\bar{X}_v/\Delta t$	277.3	kg VSS/day

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Ammonia Removed by BOD Bacteria	4.1	mg NH ₄ ⁺ -N/L
Phosphorous removed by BOD Bacteria	0.67	mg P/L
Nitrosomonas		
S ⁰	37.9	mg NH ₄ ⁺ -N/L
Left side of Equation 5.54, 5.55, 5.57	0.100	day ⁻¹
S	1.00E-16	mg NH ₄ ⁺ -N/L
e for Equation 5.55	79.6	
Right Side of Equation 5.55	0.13	day ⁻¹
Right Side of Equation 5.57	0.23	day ⁻¹
S _{min}	0.17	mg NH ₄ ⁺ -N/L
S ⁱ	19	mg NH ₄ ⁺ -N/L
\bar{X}_a	243.7	mg VSS/L
Right Side of Equation 5.54	0.14	day ⁻¹
θ_r left side of Equation 5.53	0.10	day
Right side of Equation 5.53	0.10	day
\bar{X}_i	44.7	mg VSS/L
\bar{X}_v	288.3	mg VSS/L
$\Delta\bar{X}_v/\Delta t$	60.19	kg VSS/day
Nitrite Removed by Ammonia Bacteria	0.9	mg NO ₂ ⁻ -N/L
Phosphorous removed by Ammonia Bacteria	0.14	mg P/L
Nitrobacter		
S ⁰	37.0	mg NO ₂ ⁻ -N/L
Left side of Equation 5.54, 5.55, 5.57	0.100	day ⁻¹
S	1.00E-10	mg NO ₂ ⁻ -N/L
e for Equation 5.55	51.9	
Right Side of Equation 5.55	0.18	day ⁻¹
Right Side of Equation 5.57	0.31	day ⁻¹
S _{min}	0.20	mg BOD _L /L
S ⁱ	19	mg NO ₂ ⁻ -N/L
\bar{X}_a	59.8	mg VSS/L
Right Side of Equation 5.54	0.14	day ⁻¹
θ_r (left side of Equation 5.53)	0.10	day
Right side of Equation 5.53	0.09	day
\bar{X}_i	11.0	mg VSS/L

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
\bar{X}_v	70.7	mg VSS/L
$\Delta\bar{X}_v/\Delta t$	14.77	kg VSS/day
Nitrate Removed by Nitrite Bacteria	0.2	mg NO ₃ ⁻ -N/L
Phosphorous removed by Nitrite Bacteria	0.04	mg P/L
PAOs		
\bar{X}_a – aerobic zone due to recycle	379	mg VSS/L
\bar{X}_i – aerobic zone due to recycle	30.3	mg VSS/L
\bar{X}_v	408.9	mg VSS/L
$\Delta\bar{X}_v/\Delta t$	82.8	kg VSS/day
Phosphorous removed by PAO Bacteria	2.98	mg P/L
Nitrate Removed by PAO Bacteria	1.2	mg NO ₃ ⁻ -N/L
Effluent		
Phosphorous Effluent Estimated (Rittmann, et al., 2001)	0.74	mg P/L
Total Influent COD	250.00	mg COD/L
f_{us}	0.05	mg/mg COD
f_{up}	0.13	mg/mg COD
f_{cv}	1.48	mg COD/mg VSS
b_{hT}	0.24	g VSS/g VSS-day
SRT	10.00	days
Y_h	0.45	mg VSS/mg COD
γ	-0.21	mg P/mg VSS
P_f	2.70	
S_{bsa}	43.00	mg/L
f_{xa}	0.15	
f_p	0.015	mg P/mg VSS
f	0.2	mg/mg VSS
Part 1 of Equation 15.15 (WEF, 2010a)	-2.2E-02	
Part 2 of Equation 15.15	1.3E-03	
Phosphorous Removal Estimated by Equation 15.15	-5.10	mg P/L
Effluent P by Equation 15.15	0	mg P/L
P Removal by Figure 15.45 (WEF, 2010a)	0.017	mg P/mg COD
P Removal by Figure 15.45	4.250	mg P/L
Effluent P by Figure 15.45	0	mg P/L
Reactive Nitrate In Influent for P Reactor	1.208	mg/L
rbCOD/nitrate ratio	6.6	g rbCOD/g Nitrate
rbCOD (VFA)	43	mg/L

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
rbCOD Equivalent	7.98	mg/L
rbCOD available for P Removal	35.03	mg/L
rbCOD/P Ratio	10	g rbCOD/g P
Biological P Removal	3.50	mg/L
P Removal by other Bacteria	0.96	mg/L
Total P Removal	4.46	mg/L
P in Effluent	0.22	mg P/L
Inert VSS pass through	19.38	mg VSS/L
Inert VSS Recycled pass through	797	mg VSS/L
$\Delta\bar{X}_i/\Delta t$ pass through	161.4	kg VSSi/day
MLSS Total	3744.1	mg TSS/L
Oxygen Requirements		
Input O ₂ Requirements	3014	kg OD/day
Soluble Output O ₂ Equivalents	9.79	kg OD/day
Solid Output O ₂ Equivalents	926.7	kg OD/day
Oxygen Requirements	2077.71	kg OD/day
Oxygen Requirements	86.57	kg OD/hour
Oxygen Requirements w/Oxygen Credit		
Input O ₂ Requirements	2306	kg OD/day
Soluble Output O ₂ Equivalents	9.79	kg OD/day
Solid Output O ₂ Equivalents	926.7	kg OD/day
Oxygen Requirements	1369.80	kg OD/day
Oxygen Requirements	57.08	kg OD/hour
Fine Bubble Diffuser Design		
C ₂₀	9.08	mg/L
P _b /P _a	0.93	N/A
C _{s,T,H}	8.46	mg/L
P _{atm,H}	9.64	m
Diffuser Height From Bottom	0.610	m
Tank Height	5.82	m
Assumed Oxygen Transfer Efficiency	0.19	N/A
DO In Aeration Basin	2	mg/L
C _{s,T,H}	10.34	mg/L
α	0.7	N/A
β	0.95	N/A
F	0.9	N/A
SOTR	163.3	kg/hour
Assumed Efficiency	0.35	N/A

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Air Density	1.204	kg/m ³
Air Flowrate	1728.3	m ³ /hour
Air Flowrate	28.8	m ³ /minute
Air Flowrate	1017	ft ³ /minute
Required Blower Capacity Assuming 2 Safety Factor	2034.8	ft ³ /minute
Alkalinity Requirements		
Alkalinity Consumed	299.88	mg/L as CaCO ₃
Alkalinity Residual for pH 6.8-7	80	mg/L as CaCO ₃
Alkalinity Provided in CABI	271	mg/L as CaCO ₃
Alkalinity Required w/o Denitrification	108.88	mg/L as CaCO ₃
Alkalinity Required w/Denitrification	2.77	mg/L as CaCO ₃
Internal Recycle Pump Sizing		
Internal Recycle Pump Sizing	4.4	MGD
Internal Recycle Pump Sizing	3056	gpm
Total Dynamic Head	25	ft
Pump Efficiency	0.8	N/A
Brake Horsepower	25	Hp
Return Activated Sludge Pump Sizing		
Return Activated Sludge Pump Sizing	2.75	MGD
Return Activated Sludge Pump Sizing	1910	gpm
Total Dynamic Head	30	ft
Pump Efficiency	0.8	N/A
Brake Horsepower	19	Hp
Horizontal Mixer Sizing		
Energy Requirement per Mixer	7.0	W/m ³
Number of Mixers	3	N/A
Blower Sizing		
Required Blower Capacity	2034.8	ft ³ /min
Static Head	8.280	psi
Diffuser Headloss	0.70	psi
Piping Headloss	0.15	psi
Inlet Valve and Filter Headloss	0.30	psi
System Head	9.430	psig
Atmospheric Pressure (2000 ft)	13.779	psia
Discharge Pressure	23.209	psia
Efficiency (blower & motor)	0.8	N/A
Brake Horsepower	91	Hp
Energy Requirement		
Energy Required from Internal Recycle Pump	18.65	kW

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
	447.6	kWh/day
Energy Required from Return Activated Sludge Pump	14.17	kW
	340.18	kWh/day
Energy Required from Mixers	170.096	kWh/day
Energy Required from Blower	67.886	kW
	1629.264	kWh/day
Total Energy Consumption	2587.136	kWh/day

A-5 Membranes

Parameters used in the design of the membrane portion of the MBR system can be found in Table A 15.

Table A 15 – Membrane Filtration Design Parameters

Parameter	Value	Unit	Reference
RAS recycle ratio	400-500	%	(WEF, 2012)
MLSS_{membrane tank}	8,000-12,000	mg/L	(WEF, 2012)
Design peak-day flux	13.5	gal/ft ² /day	(Menniti, et al., 2011)
Design average-day flux	12.9	gal/ft ² /day	(Menniti, et al., 2011)
Spare membrane area ratio	10	%	(WEF, 2012)
Membrane area per small subunit	32	m ²	(WEF, 2012)
Number of small subunits per large membrane subunit	48	–	(WEF, 2012)
Volume required for each large subunit	20	m ³	(WEF, 2012)
Air scour rate at average-day flowrate	10/30	seconds on/ seconds off	(WEF, 2012)
Air scour rate at peak-day flowrate	10/10	seconds on/ seconds off	(WEF, 2012)
Online factor including relaxation interval and maintenance cleaning	95	%	(WEF, 2012)
Air scour flowrate at average-day per small subunit	10	Nm ³ /hr	(WEF, 2012)
Air scour flowrate at peak-day per small subunit	20	Nm ³ /hr	(WEF, 2012)

To determine the MLSS concentration inside the membrane tank the following equation was used

$$MLSS_{membrane\ tank} = (R+1) / R \times MLSS_{bioreactor} \quad (\text{WEF, 2012})$$

where $MLSS_{membrane\ tank}$ = TSS inside the membrane tank; R = RAS recycle ratio; and $MLSS_{bioreactor}$ = TSS inside the bioreactor tank. To determine the required membrane area the following equation was used

$$J = \frac{Q}{A} \quad (\text{WEF, 2012})$$

where J = design net flux; Q = influent flowrate; and A = membrane area. Typical membrane parameters including membrane area per small subunit, number of small subunits per large subunit, and volume required per large subunits were taken from (WEF, 2012). The air scour cycle rates during average and peak-day flowrates were 10 sec on/30 sec off and 10/10, respectively (WEF, 2012). An online factor of 95% percent was also used to include relaxation intervals and maintenance cleaning (WEF, 2012). Energy consumption for the membranes is driven by air scour blowers, permeate pumps, backpulse pumps, and WAS pumps. The consumption of energy was calculated using the blower and pump equations. The combined and pump efficiencies used for both the blower and WAS pumps, respectively, were 80% (Metcalf & Eddy, Inc, 2003; Davis, 2010), and the pump efficiencies used for permeate and backpulse pumps were 70% (Goulds Pumps, 2012). Table A 16 shows the design for membrane filtration for the 8.8 MGD MBR WRP facility.

Table A 16 – Membrane Filtration Design at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Membrane and Tank Design Parameters		
Peak-day flow	1.2	MGD/train
Number of trains	8	

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
MLSS _{bioreactor}	6340	mg TSS/L
RAS Recycle Ratio	400	%
Design net flux	13.5	gal/ft ² /day
Spare membrane area ratio	10	%
Membrane area per small subunit	32	m ²
Number of small subunits per large membrane subunit	48	
Volume required for each large subunit	20	m ³
Air scour rate at peak-day flowrate	10/10	sec on/sec off
Online factor	95	%
Air scour flowrate at peak-day per small subunit	20	Nm ³ /hr
Membrane and Tank Calculations		
MLSS _{membrane tank}	7925.09	mg TSS/L
Required membrane area	88889	ft ²
Number of small subunits	288	
Number of large subunits	6	
Actual spare membrane area	11.60	%
Membrane tank volume	4237.76	ft ³
Blower flowrate	5760	Nm ³ /hr
Blower Sizing		
Required blower capacity	3390	ft ³ /min
Static head	8.280	psi
Diffuser headloss	0.70	psi
Piping headloss	0.15	psi
Inlet valve and filter headloss	0.30	psi
System head	9.43	psig
Atmospheric pressure (2000 ft)	13.779	psia
Discharge pressure	23.209	psi
Efficiency (blower & motor)	0.8	
Brake horsepower	152	Hp
Permeate Pump Sizing		
Permeate pump sizing	1.145	MGD
Permeate pump sizing	795	gpm
Total dynamic head	50	ft
Pump efficiency	0.7	
Brake horsepower	15	Hp
Backpulse Pump Sizing		
Permeate pump sizing	2.4	MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Permeate pump sizing	1667	gpm
Total dynamic head	30	ft
Pump efficiency	0.7	
Brake horsepower	19	Hp
Waste Activated Sludge Pump Sizing		
Waste Activated Sludge Pump Sizing	0.051	MGD
Waste Activated Sludge Pump Sizing	36	gpm
Total Dynamic Head	15	ft
Pump Efficiency	0.8	
Brake Horsepower	0.25	Hp
Energy Requirement		
Energy required from blower	113.392	kW
	646.3344	kWh/day
Energy required from permeate pump	11.19	kW
	255.132	kWh/day
Energy required from backpulse pump	14.174	kW
	17.0088	kWh/day
Energy Required from WAS Pump	0.1865	kW
	4.476	kWh/day
Total Energy Consumption	922.9512	kWh/day

A-6 Secondary Clarifier

Parameters used in the design of the secondary clarifier can be found in Table A 17.

Table A 17 – Secondary Clarifier Design Parameters

Parameter	Value	Unit	Reference
Average overflow rate	400-700	gpd/ft ²	(WEF, 2005; Metcalf & Eddy, Inc, 2003; WEF, 2010a)
Peak overflow rate	1,000-1,600	gpd/ft ²	(WEF, 2005; Metcalf & Eddy, Inc, 2003; WEF, 2010a)
Average solids loading rate	20-30	lb/day·ft ²	(WEF, 2005; Metcalf & Eddy, Inc, 2003; WEF, 2010a)
Peak solid loading rate	40-50	lb/day·ft ²	(WEF, 2005; Metcalf & Eddy, Inc, 2003; WEF, 2010a)
Average weir loading	<15,000	gpd/ft	(WEF, 2005)
Peak weir loading	<30,000	gpd/ft	(WEF, 2010a)

To determine the sizing of the clarifier, the area is solved for using both overflow rate and solids loading rate. The overflow rate equation is as followed

$$SOR = \frac{Q + Q_R}{A} \text{ (Metcalf \& Eddy, Inc, 2003; WEF, 2005; WEF, 2010a)}$$

where SOR = surface over flow rate; Q = influent flowrate; Q_R = RAS flowrate; and A = clarifier cross-sectional area. The solids loading rate equation is as followed

$$SLR = \frac{(Q + Q_R)X}{A} \text{ (Metcalf \& Eddy, Inc, 2003; WEF, 2005; WEF, 2010a)}$$

where SLR = solids loading rate (solids flux); Q = influent flowrate; Q_R = RAS flowrate; X = MLSS concentration; and A = clarifier cross-sectional area. The two equations are used to solve for both average and peak-flow conditions. The highest value of the four governed the design. Weir loading was checked for during both average and peak flows to ensure the loadings were under legal limits (WEF, 2005; WEF, 2010a). Energy consumption for the secondary clarifier is driven by the size of the motor that provides the torque for the rake arm and the WAS pump. The required power to move the rake arm was calculated using (WEF, 2005):

$$P = T\omega$$

where P = power required by the motor, W; T = required torque, J, $T = Wr^2$ where W = rake arm loading, N/m and r = radius of rake arm, m; and ω = angular velocity, rad/s. A rake arm loading value of 95 N/m was used and fell within the recommended range for secondary sludge (WEF, 2005). The energy requirement for the WAS pump was determined using equation 2. A pump efficiency of 80% was used (Goulds Pumps, 2012). Table A 18 shows the design for secondary clarifier for the 8.8 MGD CAS WRP facility.

Table A 18 – Secondary Clarifier Design at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Clarifier Design Parameters		
Peak day flow	2.4	MGD/train
Number of trains	4	
MLSS _{bioreactor}	3744	mg TSS/L
Average overflow rate	400-700	gpd/ft ²
Peak overflow rate	1000-1600	gpd/ft ³
Average solids overflow rate	20-30	lb/day·ft ²
Peak solids overflow rate	40-50	lb/day·ft ²
Weir overflow rate	< 15000	gpd/ft
Clarifier Over Flow Calculations		
Peak		
Cross-sectional area (from OF _{flux})	2999	ft ²
Cross-sectional area (from OF)	3000	ft ²
Average		
Cross-sectional area (from OF _{flux})	4296	ft ²
Cross-sectional area (from OF)	5500	ft ²
Sizing Requirements		
Controlling coss-sectional area	5500	ft ²
Diameter	84	ft
Manufacturer diameter	85	ft
Depth	12	ft
Freeboard	2	ft
Solids Loading Calculations		
Solids loading rate - peak flow	0.85	lb/ft ² /hr
Solids loading rate - average flow	0.78	lb/ft ² /hr
Weir Design Calculations		
Center to center spacing	8	in
Individual weir length	6	in
Spacing between v-notch	2	in
Height of v-notch	3	in
Max wetted perimeter	8.49	in
Number of v-notches	401	
Weir length	283	ft
Weir loading - peak	8474	gal/day/ft
Weir loading - average	7767	gal/day/ft

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Rake Arm Calculations		
Torque K-value	95	N/m
Required torque	15940	J
Alarm torque	19128	J
Shut-off torque	22316	J
Failure torque	31880	J
Typical Peripheral Velocity	5.5	m/min
Typical Peripheral Velocity	18	ft/min
Typical Peripheral Velocity	0.30	ft/sec
Angular Velocity	0.0071	rad/sec
Time For one Revolution	14.7979	min
Required Motor Size	0.1128	kW
Required Motor Size	0.15	Hp
Motor Size Used	0.25	Hp
Waste Activated Sludge Pump Sizing		
Waste Activated Sludge Pump Sizing	0.103	MGD
Waste Activated Sludge Pump Sizing	71	gpm
Total Dynamic Head	15	ft
Pump Efficiency	0.8	
Brake Horsepower	0.5	Hp
Energy Requirement		
Energy required from rake arm	0.1865	kW
	4.476	kWh/day
Energy required from WAS pump	0.373	kW
	8.952	kWh/day
Total Energy Consumption	13.428	kWh/day

A-7 Dual Media Filters

Parameters used in the design of the dual media filters can be found in Table A 19.

Table A 19 – Dual Media Filter Design Parameters

Parameter	Value	Unit	Reference
Media Type	Anthracite and Sand	-	(Metcalf & Eddy, Inc, 2003)
Anthracite Depth	360-900	mm	(Metcalf & Eddy, Inc, 2003)
Anthracite Effective Size	0.8-2.0	mm	(Metcalf & Eddy, Inc, 2003)
Anthracite Uniformity Coefficient	1.3-1.6	-	(Metcalf & Eddy, Inc, 2003)
Sand Depth	180-360	mm	(Metcalf & Eddy, Inc, 2003)
Sand Effective Size	0.4-0.8	mm	(Metcalf & Eddy, Inc, 2003)
Sand Uniformity Coefficient	1.2-1.6	-	(Metcalf & Eddy, Inc, 2003)
Dual Media Filtration Rate	0.2	m ³ /m ² -min	(GLUMRB, 2004)
Dual Media Backwash Rate Needed to Fluidize Bed	0.8-1.2	m ³ /m ² -min	(Metcalf & Eddy, Inc, 2003)
Dual Media Backwash Rate w/Air Scour	0.38	m ³ /m ² -min	(Metcalf & Eddy, Inc, 2003; WEF, 2010a)
Dual Media Backwash Air Flow Rate	1.07	m ³ /m ² -min	(Metcalf & Eddy, Inc, 2003; WEF, 2010a)

The number and size of the filters were determined using (WEF, 2010a) and the filtration rate (GLUMRB, 2004). Filter sizes were rounded to the nearest increment of 25 square feet to allow for ease of construction. The filters were designed with one filter out of service for backwashing cycles. The cleanwater headlosses were determined to be 0.81 and 1.45 feet for average and peak filtration rates, respectively, using the Rose equation:

$$h_L = \frac{1.067}{\phi} \frac{Lv_s^2}{\alpha^4 g} \sum C_d \frac{P}{d_g^2} \quad (\text{Metcalf \& Eddy, Inc, 2003})$$

where h_L = headloss; ϕ = particle shape factor; L = depth of filter bed; v_s = superficial filtration velocity; α = porosity; g = gravitational acceleration; C_d = coefficient of drag; P = fraction of particles within adjacent sieve sizes; and d_g = geometric mean diameter between sieve sizes. Backwash cycles were design to be 36 hours, determined using solids holding capacity for clogged headloss determination, Figure 11-10 (Metcalf & Eddy, Inc, 2003; WEF, 2010a). Energy consumption for the dual media filters is driven by the backwash blower and backwash pump. A combined blower and motor efficiency of 80% was used for the backwash blower (Metcalf & Eddy, Inc, 2003) and a pump efficiency of 78% was used for the backwash pump (Goulds Pumps, 2012). Table A 20 shows the design for dual media filters for the 8.8 MGD CAS WRP facility.

Table A 20 – Dual Media Filter Design at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Flow Parameters		
Average Flow	8.8	MGD
Average Flow	13.62	ft ³ /sec
Peak Flow	9.6	MGD
Peak Flow	14.85	ft ³ /sec
Design Parameters		
Minimum number of filters using equation 11-17 of WEF 2010	3.72	
Minimum number of filters with one filter out of service	3.00	
Filtration Rate (10 States Standard) at peak flow	5	gpm/ft ²
Area per Filter Calculated	444	ft ²
Number of Filters Assumed	4	
Number of Filters Assumed with one Filter out of service	3	
Area per Filter Recalculated	444	ft ²
Area per Filter Assumed From Above	500	ft ²
Filter Saftey Factor	1.125	

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Anthracite Depth	0.56	m
Sand Depth	0.36	m
Calculated Filtration Rate at Average Flow	4.07	gpm/ft ²
Calculated Filtration Rate at Average Flow	10	m/h
Calculated Filtration Rate at Peak Flow	12	m/h
Cleanwater Headloss at Average Flow	0.81	ft
Cleanwater Headloss at Peak Flow	1.45	ft
Backwash Cycle w/Water		
Average Backwash Rate	1.05	m/min
Average Backwash Rate	25.8	gpm/ft ²
Maximum Backwash Rate	1.2	m/min
Maximum Backwash Rate	29.5	gpm/ft ²
Backwash Pump Sizing	14725	gpm
Backwash Cycle - WEF Operations	8	minutes
Backwash Cycle w/Water & Air		
Air Flow rate	3.5	ft ³ /ft ² ·min
Required Blower Sizing	1750	ft ³ /min
Backwash Rate With Air Scour	0.38	m/min
Backwash Rate With Air Scour	0.0064	m/s
Backwash Rate With Air Scour	9.4	gpm/ft ²
D60 Fluidization Flow - Amirtharajah	1.05	m/min
D60 Fluidization Flow	0.0175	m/s
Left Side of Equation for Amirtharajah	41.9	
Backwash Cycle for Air	4.0	min
Backwash Cycle for Water	8.0	min
Filter Recovery		
Filtration Rate (v_F)	4.07	gpm/ft ²
Duration of Filter Run (t_F)	28	hr
Duration of Filter Run (t_F)	1680	min
Unit Filter Run Volume (UFRV)	6844	gal/ft ²
Backwash Rate (v_{BW})	25.8	gpm/ft ²
Duration of Backwash Cycle (t_{BW})	8	min
Unit Backwash Volume (UBWV)	206	gal/ft ²
Duration of Filter-To-Waste Cycle (t_{BW})	15	min
Unit Filter-To-Waste Cycle (UFWV)	61	gal/ft ²
Recovery Rate (r) = (UFRV-UBWV-UFWV)/(UFRV) - MWH	96	%
Backwash Blower Sizing		

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Required Blower Capacity	1750.0	ft ³ /min
Static Head	1.309	psi
Diffuser Headloss	0.70	psi
Piping Headloss	0.15	psi
Inlet Valve and Filter Headloss	5.00	psi
System Head	7.159	psig
Atmospheric Pressure (2000 ft)	13.779	psia
Discharge Pressure	20.938	psia
Efficiency (blower & motor)	0.8	
Brake Horsepower	62	Hp
Backwash Pump Sizing		
Backwash Pump Sizing	4688	gpm
Total Dynamic Head	50	ft
Pump Efficiency	0.78	
Brake Horsepower	76	Hp
Energy Requirement		
Energy Required from Backwash Blower	46.252	kW
	8.22257778	kWh/day
Energy Required from Backwash Pump	56.696	kW
	20.1585778	kWh/day
Total Energy Consumption	28.3811556	kWh/day

A-8 UV Disinfection

Parameters used in the design of the UV disinfection system can be found in Table A 21.

Table A 21 – UV Disinfection Design Parameters

Parameter	Value		Unit	Reference(s)
	Low Pressure	Medium Pressure		
Lamp length	1.50	0.25	m	
Lamp and sleeve diameter	23	76	mm	
Lamp and sleeve area	4.15E-4	4.54E-3	m ²	
Lamp spacing (O.C.)	102	127	mm	
UV input/output range	60-100	30-100	%	(Trojan Technologies, 2007; Trojan Technologies, 2008)
Maximum UV input	260	3200	W	(Trojan Technologies, 2007; Trojan Technologies, 2008; Metcalf & Eddy, Inc, 2003)
Maximum UV output	85	384	W	
Minimum UV dosage required – Membrane Effluent		80	mW·s/cm ²	(U.S. EPA, 2004a; Metcalf & Eddy, Inc, 2007; WEF, 2010a; NWRI, 2012)
Minimum UV dosage required – Filter Effluent		100	mW·s/cm ²	(NWRI, 2012)

When designing the UV disinfection system with low-pressure UV lamps, a point-source-summation method was used to determine the water quality factor and effluent coliform number using suspended solids concentrations and UV dosage, respectively (U.S. EPA, 1986; WEF, 2010a). The low-pressure high intensity lamps have a maximum input power of 260 W with an efficiency of 33% (Metcalf & Eddy, Inc, 2003; Trojan Technologies, 2008). The variable output (dimming) capabilities of this lamp are from 60 to 100% (Trojan Technologies, 2008). When designing the UV disinfection system with medium-pressure UV lamps, a point-source-summation was also done. Point-

source-summation is a model used for estimating the UV intensity. The following equation is used for this model

$$I = \frac{S}{4\pi R^2} \text{ (U.S. EPA, 1986)}$$

where I = intensity at distance R ; S = power available from UV source; and R = distance of point-source. From here the UV dose can be determined by

$$D = I_{AVG} \theta \text{ (WEF, 2010a)}$$

where D = Average UV dose; I_{AVG} = array-averaged intensity from point-source-summation; and θ = average HRT within UV light. To determine the effluent coliform number after exposure, a variation of the Chick-Watson first-order model was developed.

The following equation is this variation

$$\ln\left(\frac{N}{N_o}\right) = -kI_{AVG}t \Rightarrow N = N_o e^{-kI_{AVG}t} \text{ (Metcalf & Eddy, Inc, 2003; U.S. EPA, 1986; Qasim, 1999; Lin, 2007; WEF, 2010a)}$$

1999; Lin, 2007; WEF, 2010a)

where N = total number of surviving disperse coliform bacteria; N_o = total number of disperse coliform bacteria prior to UV light; k = inactivation rate coefficient; I = average intensity of UV light; and t = exposure time. The medium-pressure high intensity lamps have a maximum input power of 3,200 W with an efficiency of 12% (Metcalf & Eddy, Inc, 2003; Trojan Technologies, 2007). The variable output capabilities of this lamp are from 30 to 100% (Trojan Technologies, 2007). To determine the headloss through the UV channel the following equation is used

$$h_L = 1.8 \frac{v^2}{2g} \text{ (Metcalf & Eddy, Inc, 2003; Qasim, 1999)}$$

where h_L = headloss; v = approach velocity; and g = gravitational acceleration. Table A 22 and Table A 23 shows the design for UV disinfection of membrane effluent with low-pressure high intensity lamps and medium-pressure high intensity lamps for the 8.8 MGD WRP facilities, respectively. Table A 24 and Table A 25 shows the design for UV disinfection of filter effluent with low-pressure high intensity lamps and medium-pressure high intensity lamps for the 8.8 MGD WRP facilities, respectively.

Table A 22 – UV Disinfection Design of Membrane Effluent with Low-Pressure High Intensity Lamps at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Flow Parameters		
Average Flow	8.8	MGD
Average Flow	13.62	ft ³ /sec
Average Flow	23133	L/min
Peak Flow	9.6	MGD
Peak Flow	14.85	ft ³ /sec
Peak Flow	25236	L/min
Lamp Parameters		
Lamp Length	1.50	m
Lamp Length	4.922	ft
Lamp and Sleeve Diameter	23	mm
Lamp and Sleeve Diameter	0.906	in
Lamp and Sleeve Area	4.15E-04	m ²
Lamp and Sleeve Area	4.47E-03	ft ²
Lamp Spacing (O.C.)	102	mm
Lamp Spacing (O.C.)	4.02	in
Lamps Per Module	8	
Modules Per Bank	14	
Banks Per Channel	2	
Standby Banks Per Channel	1	
Lamps Per Channel Not Including Standby	224	
Lamps Per Channel Including Standby	336	
UV Input/Output Range	60-100	%
Maximum UV Input	260	W
Minimum UV Input	156.00	W

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Maximum UV Output	85	W
Minimum UV Output	51.00	W
Minimum UV Dosage According To Ten States Standards	80.00	mW·s/cm ²
Initial Coliform Bacteria		
Initial Coliform Bacteria Count	1E+03	MPN/100 mL
Effluent Coliform Bacteria Count Requirement	2.2	MPN/100 mL
Effluent Coliform Bacterial Count Goal	2	MPN/100 mL
Reactor Design (EPA Method) Check Assuming Maximum Output		
Required Width of Channel	4.7	ft
Required Depth of Channel	2.7	ft
Freeboard	2	ft
Required Area of Channel	12.5	ft ²
Cross Sectional Area of Channel	12.0	ft ²
Volume of Liquid Per Lamp (V _v)	15.0	L
UV Density	5.7	W/L
Assumed Transmittance	80	%
au/cm from Equation 12-72 (Metcalf & Eddy, Inc, 2003)	0.095	au/cm
Right Side of Equation 12-72	80	%
Absorbance coefficient (α)	0.22	1/cm
Nominal Average Intensity (I _{avg}) From Figure 7-28 of EPA 1986	23	mW/cm ²
Adjusted Average Intensity (I _{avg})	12.88	mW/cm ²
Collins-Selleck b	4	mJ/cm ²
Collins-Selleck Λ_{CS}	26	
Average Flow Contact Time Per Bank	4.35	sec
Average Flow Contact Time Per Channel	8.71	sec
Peak Flow Contact Time Per Bank	3.99	sec
Peak Flow Contact Time Per Channel	7.98	sec
Dosage at Average Flow	112.1	mW·s/cm ²
Dosage at Peak Flow	102.8	mW·s/cm ²
$\Lambda_{CS}[\ln(I_t)-\ln(b)]$ at Average Flow	-37.6	
$\Lambda_{CS}[\ln(I_t)-\ln(b)]$ at Peak Flow	-36.7	
Effluent Coliform Bacteria at Average Flow Collins-Selleck	2E-35	MPN/100 mL
Effluent Coliform Bacteria at Peak Flow Collins-Selleck	1.20E-13	MPN/100 mL

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
E-Coli First Order Inactivation Constant From WEF 1998	0.72	cm ² /mW·s
kI _{avg} t at average flow	-80.7	
kI _{avg} t at peak flow	-74.0	
Effluent Coliform Bacteria at Average Flow WEF 1998	9E-33	MPN/100 mL
Effluent Coliform Bacteria at Peak Flow WEF 1998	7.27E-30	MPN/100 mL
Emerick Darby Water Quality Factor (f) From Figure 19.36 of WEF 2010 Assuming 5 mg/L TSS	2.00E+04	
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Average Flow	2	MPN/100 mL
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Peak Flow	2	MPN/100 mL
Headloss		
Velocity at Average	0.34	m/s
Velocity at Average	34.47	cm/s
Headloss at Average (Metcalf & Eddy, Inc, 2003)	0.03	m
Headloss at Average	0.11	ft
Velocity at Peak	0.38	m/s
Velocity at Peak	37.60	cm/s
Headloss at Peak (Metcalf & Eddy, Inc, 2003)	0.04	m
Headloss at Peak	0.13	ft
Average Flow Actual Dosage		
UV Input Required	156	W
UV Output Required	51.0	W
Percent Illuminated	60.0	%
UV Density	3.4	W/L
Nominal Average Intensity (I _{avg}) From Figure 7-28 of EPA 1986	17	mW/cm ²
Adjusted Average Intensity (I _{avg})	9.52	mW/cm ²
Dosage at Average Flow	82.9	mW·s/cm ²
Λ _{CS} [ln(It)-ln(b)] at Average Flow	-34.2	
Effluent Coliform Bacteria at Average Flow Collins-Selleck	6E-32	MPN/100 mL
kI _{avg} t at average flow	-59.67	
Effluent Coliform Bacteria at Average Flow WEF 1998	1E-23	MPN/100 mL

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Average Flow	2	MPN/100 mL
Energy Per Channel At Average Flow	34.94	kW
Energy Per Channel Per Day at Average Flow	839	kWh/day
Peak Flow Dosage		
UV Input Required	168	W
UV Output Required	54.9	W
Percent Illuminated	64.6	%
UV Density	3.7	W/L
Nominal Average Intensity (I_{avg}) From Figure 7-28 of EPA 1986	18.5	mW/cm ²
Adjusted Average Intensity (I_{avg})	10.36	mW/cm ²
Dosage at Peak Flow	82.7	mW·s/cm ²
$\Lambda_{CS}[\ln(I_t) - \ln(b)]$ at Peak Flow	-34.2	
Effluent Coliform Bacteria at Peak Flow Collins-Selleck	1.41E-12	MPN/100 mL
$kI_{avg}t$ at average flow	-59.52	
Effluent Coliform Bacteria at Average Flow WEF 1998	1E-23	MPN/100 mL
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Average Flow	2	MPN/100 mL
Energy Per Channel At Peak Flow	37.63	kW
Energy Per Channel Per Day at Peak Flow	903	kWh/day

Table A 23 – UV Disinfection Design of Membrane Effluent with Medium-Pressure High Intensity Lamps at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Flow Parameters		
Average Flow	8.8	MGD
Average Flow	13.62	ft ³ /sec
Average Flow	23133	L/min
Peak Flow	9.6	MGD
Peak Flow	14.85	ft ³ /sec
Peak Flow	25236	L/min
Lamp Parameters		
Lamp Length	0.25	m
Lamp Length	0.820	ft
Lamp and Sleeve Diameter	76	mm
Lamp and Sleeve Diameter	2.992	in

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Lamp and Sleeve Area	4.54E-03	m ²
Lamp and Sleeve Area	4.88E-02	ft ²
Lamp Spacing (O.C.)	127	mm
Lamp Spacing (O.C.)	5.00	in
Lamps Per Module	24	
Modules Per Bank	4	
Banks Per Channel	1	
Standby Banks Per Channel	1	
Lamps Per Channel Not Including Standby	96	
Lamps Per Channel Including Standby	192	
UV Input/Output Range	30-100	%
Maximum UV Input	3200	W
Minimum UV Input	960.00	W
Maximum UV Output	384	W
Minimum UV Output	115.20	W
Minimum UV Dosage According To Ten States Standards	80	mW·s/cm ²
Initial Coliform Bacteria		
Initial Coliform Bacteria Count	1E+03	MPN/100 mL
Effluent Coliform Bacteria Count Requirement	2.2	MPN/100 mL
Effluent Coliform Bacterial Count Goal	2	MPN/100 mL
Reactor Design (EPA Method) Check Assuming Maximum Output		
Required Width of Channel	10.0	ft
Required Depth of Channel	1.7	ft
Freeboard	2	ft
Required Area of Channel	16.7	ft ²
Cross Sectional Area of Channel	12.0	ft ²
Volume of Liquid Per Lamp (V _v)	2.9	L
UV Density	132.5	W/L
Assumed Transmittance	80	%
au/cm from Equation 12-72 (Metcalf & Eddy, Inc, 2003)	0.095	au/cm
Right Side of Equation 12-72	80	%
Absorbance coefficient (α)	0.22	1/cm
Nominal Average Intensity (I _{avg}) From PSS Method	282.3	mW/cm ²
Adjusted Average Intensity (I _{avg})	158.1	mW/cm ²
Collins-Selleck b	4	mJ/cm ²
Collins-Selleck Λ_{CS}	26	

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Average Flow Contact Time Per Bank	0.72	sec
Average Flow Contact Time Per Channel	0.72	sec
Peak Flow Contact Time Per Bank	0.66	sec
Peak Flow Contact Time Per Channel	0.66	sec
Dosage at Average Flow	114.1	mW·s/cm ²
Dosage at Peak Flow	104.6	mW·s/cm ²
$\Lambda_{CS}[\ln(I_t)-\ln(b)]$ at Average Flow	-37.8	
$\Lambda_{CS}[\ln(I_t)-\ln(b)]$ at Peak Flow	-36.9	
Effluent Coliform Bacteria at Average Flow Collins-Selleck	1E-35	MPN/100 mL
Effluent Coliform Bacteria at Peak Flow Collins-Selleck	9.90E-14	MPN/100 mL
E-Coli First Order Inactivation Constant From WEF 1998	0.72	cm ² /mW·s
$kI_{avg}t$ at average flow	-82.1	
$kI_{avg}t$ at peak flow	-75.3	
Effluent Coliform Bacteria at Average Flow WEF 1998	2E-33	MPN/100 mL
Effluent Coliform Bacteria at Peak Flow WEF 1998	2.00E-30	MPN/100 mL
Emerick Darby Water Quality Factor (f) From Figure 19.36 of WEF 2010 Assuming 5 mg/L TSS	4.50E+04	
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Average Flow	2	MPN/100 mL
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Peak Flow	2	MPN/100 mL
Headloss		
Velocity at Average	0.35	m/s
Velocity at Average	34.65	cm/s
Headloss at Average (Metcalf & Eddy, Inc, 2003)	0.02	m
Headloss at Average	0.07	ft
Velocity at Peak	0.38	m/s
Velocity at Peak	37.80	cm/s
Headloss at Peak (Metcalf & Eddy, Inc, 2003)	0.03	m
Headloss at Peak	0.09	ft
Average Flow Actual Dosage		
UV Input Required	2250	W
UV Output Required	270.0	W

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Percent Illuminated	70.3	%
UV Density	93.2	W/L
Nominal Average Intensity (I _{avg}) From PSS Method	198.4	mW/cm ²
Adjusted Average Intensity (I _{avg})	111.104	mW/cm ²
Dosage at Average Flow	80.2	mW·s/cm ²
$\Lambda_{CS}[\ln(I_t)-\ln(b)]$ at Average Flow	-33.9	
Effluent Coliform Bacteria at Average Flow Collins-Selleck	1E-31	MPN/100 mL
$kI_{avg}t$ at average flow	-57.73	
Effluent Coliform Bacteria at Average Flow WEF 1998	9E-23	MPN/100 mL
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Average Flow	2	MPN/100 mL
Energy Per Channel At Average Flow	216.00	kW
Energy Per Channel Per Day at Average Flow	5184	kWh/day
Peak Flow Dosage		
UV Input Required	2500	W
UV Output Required	300.0	W
Percent Illuminated	78.1	%
UV Density	103.5	W/L
Nominal Average Intensity (I _{avg}) From PSS Method	220.5	mW/cm ²
Adjusted Average Intensity (I _{avg})	123.48	mW/cm ²
Dosage at Peak Flow	81.7	mW·s/cm ²
$\Lambda_{CS}[\ln(I_t)-\ln(b)]$ at Peak Flow	-34.1	
Effluent Coliform Bacteria at Peak Flow Collins-Selleck	1.61E-12	MPN/100 mL
$kI_{avg}t$ at average flow	-58.81	
Effluent Coliform Bacteria at Average Flow WEF 1998	3E-23	MPN/100 mL
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Average Flow	2	MPN/100 mL
Energy Per Channel At Peak Flow	240.00	kW
Energy Per Channel Per Day at Peak Flow	5760	kWh/day

Table A 24 – UV Disinfection Design of Filter Effluent with Low-Pressure High Intensity Lamps at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Flow Parameters		
Average Flow	8.8	MGD
Average Flow	13.62	ft ³ /sec
Average Flow	23133	L/min
Peak Flow	9.6	MGD
Peak Flow	14.85	ft ³ /sec
Peak Flow	25236	L/min
Lamp Parameters		
Lamp Length	1.50	m
Lamp Length	4.922	ft
Lamp and Sleeve Diameter	23	mm
Lamp and Sleeve Diameter	0.906	in
Lamp and Sleeve Area	4.15E-04	m ²
Lamp and Sleeve Area	4.47E-03	ft ²
Lamp Spacing (O.C.)	102	mm
Lamp Spacing (O.C.)	4.02	in
Lamps Per Module	8	
Modules Per Bank	20	
Banks Per Channel	2	
Standby Banks Per Channel	1	
Lamps Per Channel Not Including Standby	320	
Lamps Per Channel Including Standby	480	
UV Input/Output Range	60-100	%
Maximum UV Input	260	W
Minimum UV Input	156.00	W
Maximum UV Output	85	W
Minimum UV Output	51.00	W
Minimum UV Dosage According To Ten States Standards	100.00	mW·s/cm ²
Initial Coliform Bacteria		
Initial Coliform Bacteria Count	1E+06	MPN/100 mL
Effluent Coliform Bacteria Count Requirement	2.2	MPN/100 mL
Effluent Coliform Bacterial Count Goal	2	MPN/100 mL
Reactor Design (EPA Method) Check Assuming Maximum Output		
Required Width of Channel	6.7	ft
Required Depth of Channel	2.7	ft
Freeboard	2	ft
Required Area of Channel	17.9	ft ²

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Cross Sectional Area of Channel	17.2	ft ²
Volume of Liquid Per Lamp (V _v)	15.0	L
UV Density	5.7	W/L
Assumed Transmittance	75	%
au/cm from Equation 12-72 (Metcalf & Eddy, Inc, 2003)	0.125	au/cm
Right Side of Equation 12-72	75	%
Absorbance coefficient (α)	0.29	1/cm
Nominal Average Intensity (I _{avg}) From Figure 7-28 of EPA 1986	18.5	mW/cm ²
Adjusted Average Intensity (I _{avg})	10.36	mW/cm ²
Collins-Selleck b	4	mJ/cm ²
Collins-Selleck Λ_{CS}	26	
Average Flow Contact Time Per Bank	6.22	sec
Average Flow Contact Time Per Channel	12.44	sec
Peak Flow Contact Time Per Bank	5.70	sec
Peak Flow Contact Time Per Channel	11.40	sec
Dosage at Average Flow	128.1	mW·s/cm ²
Dosage at Peak Flow	118.1	mW·s/cm ²
$\Lambda_{CS}[\ln(I_t)-\ln(b)]$ at Average Flow	-39.2	
$\Lambda_{CS}[\ln(I_t)-\ln(b)]$ at Peak Flow	-38.2	
Effluent Coliform Bacteria at Average Flow Collins-Selleck	6E-34	MPN/100 mL
Effluent Coliform Bacteria at Peak Flow Collins-Selleck	2.51E-11	MPN/100 mL
E-Coli First Order Inactivation Constant From WEF 1998	0.72	cm ² /mW·s
kI _{avg} t at average flow	-92.8	
kI _{avg} t at peak flow	-85.0	
Effluent Coliform Bacteria at Average Flow WEF 1998	5E-35	MPN/100 mL
Effluent Coliform Bacteria at Peak Flow WEF 1998	1.18E-31	MPN/100 mL
Emerick Darby Water Quality Factor (f) From Figure 19.36 of WEF 2010 Assuming 5 mg/L TSS	2.50E+04	
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Average Flow	2	MPN/100 mL

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Peak Flow	2	MPN/100 mL
Headloss		
Velocity at Average	0.24	m/s
Velocity at Average	24.17	cm/s
Headloss at Average (Metcalf & Eddy, Inc, 2003)	0.02	m
Headloss at Average	0.05	ft
Velocity at Peak	0.26	m/s
Velocity at Peak	26.32	cm/s
Headloss at Peak (Metcalf & Eddy, Inc, 2003)	0.02	m
Headloss at Peak	0.06	ft
Average Flow Actual Dosage		
UV Input Required	160	W
UV Output Required	52.3	W
Percent Illuminated	61.5	%
UV Density	3.5	W/L
Nominal Average Intensity (I_{avg}) From Figure 7-28 of EPA 1986	15	mW/cm ²
Adjusted Average Intensity (I_{avg})	8.4	mW/cm ²
Dosage at Average Flow	104.5	mW·s/cm ²
$\Lambda_{CS}[\ln(I_t)-\ln(b)]$ at Average Flow	-36.8	
Effluent Coliform Bacteria at Average Flow Collins-Selleck	1E-31	MPN/100 mL
$kI_{avg}t$ at average flow	-75.21	
Effluent Coliform Bacteria at Average Flow WEF 1998	2E-27	MPN/100 mL
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Average Flow	2	MPN/100 mL
Energy Per Channel At Average Flow	51.20	kW
Energy Per Channel Per Day at Average Flow	1229	kWh/day
Peak Flow Dosage		
UV Input Required	190	W
UV Output Required	62.1	W
Percent Illuminated	73.1	%
UV Density	4.1	W/L
Nominal Average Intensity (I_{avg}) From Figure 7-28 of EPA 1986	16.5	mW/cm ²
Adjusted Average Intensity (I_{avg})	9.24	mW/cm ²
Dosage at Peak Flow	105.3	mW·s/cm ²

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
$\Delta_{CS}[\ln(I_t)-\ln(b)]$ at Peak Flow	-36.9	
Effluent Coliform Bacteria at Peak Flow Collins-Selleck	9.12E-11	MPN/100 mL
$kI_{avg}t$ at average flow	-75.84	
Effluent Coliform Bacteria at Average Flow WEF 1998	1E-27	MPN/100 mL
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Average Flow	2	MPN/100 mL
Energy Per Channel At Peak Flow	60.80	kW
Energy Per Channel Per Day at Peak Flow	1459	kWh/day

Table A 25 – UV Disinfection Design of Filter Effluent with Medium-Pressure High Intensity Lamps at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Flow Parameters		
Average Flow	8.8	MGD
Average Flow	13.62	ft ³ /sec
Average Flow	23133	L/min
Peak Flow	9.6	MGD
Peak Flow	14.85	ft ³ /sec
Peak Flow	25236	L/min
Lamp Parameters		
Lamp Length	0.25	m
Lamp Length	0.820	ft
Lamp and Sleeve Diameter	76	mm
Lamp and Sleeve Diameter	2.992	in
Lamp and Sleeve Area	4.54E-03	m ²
Lamp and Sleeve Area	4.88E-02	ft ²
Lamp Spacing (O.C.)	127	mm
Lamp Spacing (O.C.)	5.00	in
Lamps Per Module	24	
Modules Per Bank	5	
Banks Per Channel	1	
Standby Banks Per Channel	1	
Lamps Per Channel Not Including Standby	120	
Lamps Per Channel Including Standby	240	
UV Input/Output Range	30-100	%
Maximum UV Input	3200	W
Minimum UV Input	960.00	W

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Maximum UV Output	384	W
Minimum UV Output	115.20	W
Minimum UV Dosage According To Ten States Standards	100	mW·s/cm ²
Initial Coliform Bacteria		
Initial Coliform Bacteria Count	1E+06	MPN/100 mL
Effluent Coliform Bacteria Count Requirement	2.2	MPN/100 mL
Effluent Coliform Bacterial Count Goal	2	MPN/100 mL
Reactor Design (EPA Method) Check Assuming Maximum Output		
Required Width of Channel	10.0	ft
Required Depth of Channel	2.1	ft
Freeboard	2	ft
Required Area of Channel	20.8	ft ²
Cross Sectional Area of Channel	15.0	ft ²
Volume of Liquid Per Lamp (V _v)	2.9	L
UV Density	132.5	W/L
Assumed Transmittance	75	%
au/cm from Equation 12-72 (Metcalf & Eddy, Inc, 2003)	0.125	au/cm
Right Side of Equation 12-72	75	%
Absorbance coefficient (α)	0.29	1/cm
Nominal Average Intensity (I _{avg}) From PSS Method	217.4	mW/cm ²
Adjusted Average Intensity (I _{avg})	121.7	mW/cm ²
Collins-Selleck b	4	mJ/cm ²
Collins-Selleck Λ_{CS}	26	
Average Flow Contact Time Per Bank	0.90	sec
Average Flow Contact Time Per Channel	0.90	sec
Peak Flow Contact Time Per Bank	0.83	sec
Peak Flow Contact Time Per Channel	0.83	sec
Dosage at Average Flow	109.8	mW·s/cm ²
Dosage at Peak Flow	100.7	mW·s/cm ²
$\Lambda_{CS}[\ln(I_t)-\ln(b)]$ at Average Flow	-37.4	
$\Lambda_{CS}[\ln(I_t)-\ln(b)]$ at Peak Flow	-36.4	
Effluent Coliform Bacteria at Average Flow Collins-Selleck	4E-32	MPN/100 mL
Effluent Coliform Bacteria at Peak Flow Collins-Selleck	1.52E-10	MPN/100 mL

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
E-Coli First Order Inactivation Constant From WEF 1998	0.72	cm ² /mW·s
kI _{avg} t at average flow	-79.1	
kI _{avg} t at peak flow	-72.5	
Effluent Coliform Bacteria at Average Flow WEF 1998	5E-29	MPN/100 mL
Effluent Coliform Bacteria at Peak Flow WEF 1998	3.33E-26	MPN/100 mL
Emerick Darby Water Quality Factor (f) From Figure 19.36 of WEF 2010 Assuming 5 mg/L TSS	4.50E+04	
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Average Flow	2	MPN/100 mL
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Peak Flow	2	MPN/100 mL
Headloss		
Velocity at Average	0.28	m/s
Velocity at Average	27.72	cm/s
Headloss at Average (Metcalf & Eddy, Inc, 2003)	0.01	m
Headloss at Average	0.05	ft
Velocity at Peak	0.30	m/s
Velocity at Peak	30.24	cm/s
Headloss at Peak (Metcalf & Eddy, Inc, 2003)	0.02	m
Headloss at Peak	0.06	ft
Average Flow Actual Dosage		
UV Input Required	2950	W
UV Output Required	354.0	W
Percent Illuminated	92.2	%
UV Density	122.1	W/L
Nominal Average Intensity (I _{avg}) From PSS Method	200.4	mW/cm ²
Adjusted Average Intensity (I _{avg})	112.224	mW/cm ²
Dosage at Average Flow	101.2	mW·s/cm ²
Λ _{CS} [ln(I _t)-ln(b)] at Average Flow	-36.5	
Effluent Coliform Bacteria at Average Flow Collins-Selleck	3E-31	MPN/100 mL
kI _{avg} t at average flow	-72.89	
Effluent Coliform Bacteria at Average Flow WEF 1998	2E-26	MPN/100 mL

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Average Flow	2	MPN/100 mL
Energy Per Channel At Average Flow	354.00	kW
Energy Per Channel Per Day at Average Flow	8496	kWh/day
Peak Flow Dosage		
UV Input Required	3200	W
UV Output Required	384.0	W
Percent Illuminated	100	%
UV Density	132.5	W/L
Nominal Average Intensity (I_{avg}) From PSS Method	217.4	mW/cm ²
Adjusted Average Intensity (I_{avg})	121.744	mW/cm ²
Dosage at Peak Flow	100.7	mW·s/cm ²
$\Lambda_{CS}[\ln(I_t)-\ln(b)]$ at Peak Flow	-36.4	
Effluent Coliform Bacteria at Peak Flow Collins-Selleck	1.52E-10	MPN/100 mL
$kI_{avg}t$ at average flow	-72.48	
Effluent Coliform Bacteria at Average Flow WEF 1998	3E-26	MPN/100 mL
Effluent Total Coliform From Figure 19.37 of WEF 2010 At Average Flow	2	MPN/100 mL
Energy Per Channel At Peak Flow	384.00	kW
Energy Per Channel Per Day at Peak Flow	9216	kWh/day

A-9 Chlorination

The alternative disinfection process used to contrast UV disinfection was chlorination. Chloramination can also be used with the addition of ammonia ahead of the chlorine contact basin. Parameters used in the design of the chlorination contact basin are seen in Table A 26.

Table A 26 – Chlorination Design Parameters

Parameter	Value	Unit	Reference
Minimum chlorine contact time	450	mg-min/L	(Hirani, et al., 2010; WEF, 2010a)
Effluent total coliform concentration	2.2	MPN/100mL	(Hirani, et al., 2010; U.S. EPA, 2004a; Metcalf & Eddy, Inc, 2007; WEF, 2010a)
Membrane effluent total coliform concentration	807±1314	MPN/100mL	(DeCarolis Jr, et al., 2007)
Chlorine residual required	3	mg/L	
Detention time at peak flow	30	min	
Dispersion number at peak flow	0.0150	–	(Metcalf & Eddy, Inc, 2003)

To determine the required chlorine dosage to disinfect the membrane effluent the following equation was used

$$\frac{N}{N_o} = \left[\frac{C_R t}{b} \right]^{-n} \quad (\text{Metcalf \& Eddy, Inc, 2003})$$

where N = total number of surviving disperse coliform bacteria; N_o = total number of disperse coliform bacteria prior to chlorine dose; C_R = chlorine residual remaining at the end of time t ; t = contact time; n = slope of inactivation curve; and b = value of x-intercept when $N/N_o = 1$ or $\log N/N_o = 0$. The membrane effluent total coliform bacterium has a typical range of 10 to 1000 MPN/100mL (Metcalf & Eddy, Inc, 2003; DeCarolis Jr, et al., 2007). Chlorine residual required is assumed to be 3 mg/L leaving the facility. Once a design scheme for the layout of the chlorine contact basin was chosen, the basin was then sized. To ensure proper dispersion, the dispersion number for the chosen design is calculated using

$$D = 1.01\nu(N_R)^{0.875} \quad (\text{Metcalf \& Eddy, Inc, 2003})$$

where D = coefficient of dispersion; ν = kinematic viscosity; and N_R = Reynolds number, $4\nu R/\nu$ (Sturm, 2010): where R = hydraulic radius and ν = velocity in open

channel. If the dispersion number calculated is more than the desired peak dispersion number of 0.0150 (Metcalf & Eddy, Inc, 2003) then an alternative design will have to be done to achieve a lower value. Energy consumption for chlorination is driven by the size of the diaphragm pump used to inject chlorine before the contact basin. This energy requirement can be calculated using the pump equation. A pump efficiency of 70% was used (Goulds Pumps, 2012). Table A 27 and Table A 28 shows the design for chlorination for the 8.8 MGD MBR and CAS WRP facilities, respectively.

Table A 27 – Chlorination of Membrane Effluent Design at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Chlorination Dosage Design Parameters		
Minimum chlorine contact time	450	mg-min/L
Effluent total coliform concentration	2.2	MPN/100mL
Membrane effluent total coliform concentration	807±1314	MPN/100mL
Chlorine residual required in effluent	3	mg/L
Chlorination Dosage Calculations at Peak Flow		
Chlorine contact time	30	min
Chlorine demand due to decay during contact time	2.5	mg/L
Chlorine residual remaining	1.55	mg/L
Chlorine dosage	7.05	mg/L
Chlorine consumption	256.2	kg/day
Chlorination Contact Basin Design Parameters		
Detention time at peak flow	30	min
Dispersion number at peak flow	0.0150	
Number of parallel channels including redundancy	2	
Width	8	ft
Depth	8	ft
Chlorination Contact Basin Design Calculation		
Length	208.85	ft
Velocity at peak flow	0.116	ft/sec
Reynolds number	19178	
Coefficient of dispersion	6.832E-02	ft ² /sec
Dispersion number - check	0.0028	

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Average Flow Check		
Velocity at average flow	0.106	ft/sec
Reynolds number	17580	
Coefficient of dispersion	6.331E-02	ft ² /sec
Dispersion number - check	0.003	
Chlorination Dosage Calculations at Average		
Chlorine contact time	33	min
Chlorine demand due to decay during contact time	2.5	mg/L
Chlorine residual remaining	1.42	mg/L
Chlorine dosage	6.92	mg/L
Pump Sizing		
Sodium hypochlorite	12.5	% by weight
Required amount of sodium hypochlorite	2049.95	kg/day
Required volume of sodium hypochlorite	434.55	gal/day
	0.302	gal/min
Total dynamic head	25	ft
Pump efficiency (diaphragm/peristaltic)	0.7	
Brake horsepower required	0.0027	Hp
Brake horsepower used	0.25	Hp
Energy Required		
Energy required from chlorinator pump	0.1865	kW
	4.476	kWh/day
Total Energy Consumption	4.476	kWh/day

Table A 28 – Chlorination of Filter Effluent Design at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Chlorination Dosage Design Parameters		
Minimum chlorine contact time	450	mg-min/L
Effluent total coliform concentration	2.2	MPN/100mL
Membrane effluent total coliform concentration	10 ⁴ -10 ⁶	MPN/100mL
Chlorine residual required in effluent	3	mg/L
Chlorination Dosage Calculations at Peak Flow		
Chlorine contact time	30	min
Chlorine demand due to decay during contact time	2.5	mg/L
Chlorine residual remaining	13.98	mg/L
Chlorine dosage	19.48	mg/L
Chlorine consumption	707.9	kg/day

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Chlorination Contact Basin Design Parameters		
Detention time at peak flow	30	min
Dispersion number at peak flow	0.0150	
Number of parallel channels including redundancy	2	
Width	8	ft
Depth	8	ft
Chlorination Contact Basin Design Calculation		
Length	208.85	ft
Velocity at peak flow	0.116	ft/sec
Reynolds number	19178	
Coefficient of dispersion	6.832E-02	ft ² /sec
Dispersion number - check	0.0028	
Average Flow Check		
Velocity at average flow	0.106	ft/sec
Reynolds number	17580	
Coefficient of dispersion	6.331E-02	ft ² /sec
Dispersion number - check	0.003	
Chlorination Dosage Calculations at Average		
Chlorine contact time	33	min
Chlorine demand due to decay during contact time	2.5	mg/L
Chlorine residual remaining	12.81	mg/L
Chlorine dosage	18.31	mg/L
Pump Sizing		
Sodium hypochlorite	12.5	% by weight
Required amount of sodium hypochlorite	5663.17	kg/day
Required volume of sodium hypochlorite	1200.50	gal/day
	0.834	gal/min
Total dynamic head	25	ft
Pump efficiency (diaphragm/peristaltic)	0.7	
Brake horsepower required	0.0075	Hp
Brake horsepower used	0.25	Hp
Energy Required		
Energy required from chlorinator pump	0.1865	kW
	4.476	kWh/day
Total Energy Consumption	4.476	kWh/day

A-10 Anaerobic Digester

Parameters used in the design of the single-stage high-rate mesophilic anaerobic digester can be found in Table A 29. The HRT, equivalent to the SRT, was used in the determination of the volume required for the digester (Metcalf & Eddy, Inc, 2003). The amount of methane-forming volatile solids synthesized per day was determined using the complete-mix high-rate digester equation, followed by the calculation of the volume of methane gas using kinetic equations (Metcalf & Eddy, Inc, 2003; Davis, 2010). These were done taking into account the volume of methane gas at the operating temperature of 35°C. An egg-shaped digester was used in the design to provide a higher mixing efficiency, improved homogeneous biomass, and most importantly, a smaller real estate area in the WRP (Metcalf & Eddy, Inc, 2003; WEF, 2010b).

The anaerobic digestion process produces methane gas that can be used for energy generation; however, digestion itself consumes energy. Energy consumption for the anaerobic digester is driven by the mixers providing a homogeneous biomass mixture and by the heat-exchanger providing heating for the sludge and heat losses through the digester walls. Mixer energy requirements were determined based on the volume of the digester, using an average energy consumption of 6.5 W/m³ (WEF, 2010b). The energy requirement to heat the sludge was determined using (Metcalf & Eddy, Inc, 2003; Davis, 2010; WEF, 2010b):

$$q = M_s C_s (T - T_i)$$

where q = heat required, J/day; M_s = mass flow of sludge, kg/day; C_s = specific heat of sludge, J/kg·°C; T = digestion temperature, °C; and T_i = influent sludge temperature, °C. For purposes of this research, 4200 J/kg·°C was used for the specific heat of sludge

(Metcalf & Eddy, Inc, 2003). The energy required to compensate for the loss of heat through the walls of the digester were determined as (Metcalf & Eddy, Inc, 2003; Davis, 2010; WEF, 2010b):

$$q = UA\Delta T$$

where q = heat loss, J/sec; U = overall coefficient of heat transfer, $J/m^2 \cdot sec \cdot ^\circ C$; A = cross-sectional area perpendicular to heat flow, m^2 ; and ΔT = change in temperature between digestion and surface in question. Coefficients of heat transfer used in the research are 0.68, 0.85, and 0.91 $W/m^2 \cdot ^\circ C$ for the walls, floor, and roof, respectively (Metcalf & Eddy, Inc, 2003; Davis, 2010; WEF, 2010b). Energy production from the combustion of digester gas was determined using:

$$E = HVe$$

where E = energy generated, kJ/day; H = heat of combustion, kJ/m^3 ; V = volume of gas produced per day, m^3/day ; and e = electrical efficiency. In this research, 37,000 kJ/m^3 was used for the heat of combustion of methane (WEF, 2010b). An electrical efficiency of 33% was used based off the efficiency for an internal combustion engine (ICE) (WEF, 2010b). Table A 29 shows the design for the anaerobic digester at 8.8 MGD.

Table A 29 – Anaerobic Digester Design Parameters and Design at 8.8 MGD

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Anaerobic Digester Design Parameters		
Dry volatile solids	0.15	kg/m^3
Biodegradable COD removed	0.14	kg/m^3
Waste utilization efficiency	70	%
Bacterial yield	0.08	$kg\ VSS/ kg\ bCOD$
Bacterial decay coefficient	0.03	d^{-1}
Percentage of methane in digester gas	65	%
Solids retention time	15	day

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Sludge specific gravity	1.02	
Sludge moisture content	95	%
Temperature	35	°C
Anaerobic Digester Calculations		
Sludge volume	97.98	m ³ /day
bCOD loading	4663.6	kg/day
Digester volume required	1469.63	m ³
Volumetric loading	3.17	kg/m ³ ·day
Total volatile solids produced	180.1	kg/day
Volume of methane produced	1050.1	m ³ /day
Total volume of gas produced	1615.5	m ³ /day
Heating Requirements Design Parameters		
Heat-transfer coefficient - dry earth embanked for entire depth	0.68	W/m ² ·°C
Heat-transfer coefficient - floor of digester in groundwater	0.85	W/m ² ·°C
Heat-transfer coefficient - roof exposed to air	0.91	W/m ² ·°C
Temperature - air	25	°C
Temperature - earth next to wall	15	°C
Temperature - incoming sludge	18.3	°C
Temperature - earth below floor	12	°C
Temperature - sludge contents in digester	35	°C
Specific heat of sludge	4200	J/kg·°C
Heating Requirements Calculations		
Digester diameter	18.0	m
Digester side depth	6.0	m
Digester mid depth	9.0	m
Digester volume provided	1781.28	m ³
Safety factor	1.21	
Wall area	339.3	m ²
Floor area	268.2	m ²
Roof area	254.5	m ²
Digester capacity	84789	kg/day
Heat requirement for sludge	5.95E+09	J/day
Heat loss by conduction - walls	3.99E+08	J/day
Heat loss by conduction - floor	4.53E+08	J/day
Heat loss by conduction - roof	2.00E+08	J/day
Heat loss - total	1.05E+09	J/day

<i>Parameter</i>	<i>Value</i>	<i>Unit</i>
Heat-exchanger capacity	7.00E+09	J/day
Energy Requirement		
Energy required from mixers	6.5	W/m ³
	277.88	kWh/day
Energy required from heat-exchanger	7.00E+09	J/day
	1944.15	kWh/day
Total Energy Consumption	2222.03	kWh/day
Energy Generation		
Energy content of methane gas	37000	kJ/m ³
	10.28	kWh/m ³
Electrical efficiency	33	%
Energy Generation from Digester	3561.44	kWh/day

REFERENCES

Angelakis A and Durham B Water recycling and reuse in EUREAU countries: Trends and challenges [Journal] // Desalination. - [s.l.] : Elsevier, 2008. - 1-3 : Vol. 218. - ISSN 00119164.

Asano T, Maeda M and Takaki M Wastewater Reclamation and Reuse in Japan: Overview and Implementation Examples [Journal] // Water Science and Technology. - [s.l.] : Elsevier Science Ltd, 1996. - 11 : Vol. 34. - ISSN 02731223.

ASTM International ASTM G173 - 03(2008) [Online] // Standards. - American Society for Testing and Materials, 2012. - June 26, 2012. - <http://www.astm.org/Standards/G173.htm>.

Barbose Galen [et al.] Tacking the Sun IV: An Historical Summary of the Installed Cost of Photovoltaics in the United States from 1998 to 2010 [Report]. - [s.l.] : Environmental Energy Technologies Division, Lawrence Berkeley National Laboratory, 2011.

Bennett Anthony Energy efficiency: Wastewater treatment and energy production [Journal] // Filtration & Separation. - [s.l.] : Elsevier Ltd., 2007. - 10 : Vol. 44. - pp. 16-19.

Bernier David, Osgood Jennifer and Walsh Michael Using Green to Get to Blue: How Alternative Energy Technologies Reduce the Carbon Footprint of Wastewater Treatment [Conference] // Water Environment Federation Technical Exhibition and Conference 2011. - Los Angeles : Water Environment Federation, 2011.

Bixio D [et al.] Wastewater reuse in Europe [Journal] // Desalination and the Environment. - [s.l.] : Elsevier, 2006. - 1-3 : Vol. 187. - ISSN 00119164.

Brandt Malcolm [et al.] Energy efficiency in the water industry, a Global Research Project [Journal] // Water Practice and Technology. - [s.l.] : IWA Publishing, 2011. - 2 : Vol. 6. - ISSN 1751231X.

Burkart Christopher S and Arguea Nestor M Efficient scale for photovoltaic systems and Florida's solar rebate program [Journal] // Energy Policy. - [s.l.] : Elsevier, 2012. - Vol. 48.

California Energy Commission A Guide to Photovoltaic (PV) System Design and Installation [Online]. - Callifornia Energy Commision Energy Technology Development Division, June 2001. - June 26, 2012. - <http://www.ecodiy.org/california%20PV/californian%20photovoltaic%20best.htm>.

City of Boulder Wastewater Treatment Plant Solar Photovoltaic Facility [Online] // City of Boulder Colorado. - January 02, 2012. - July 26, 2012. -
http://www.bouldercolorado.gov/index.php?option=com_content&task=view&id=8763&Itemid=1189 .

Cleary Joseph G, Grey Gary M and Helmig Edward Treatment of Pharmaceuticals, Personal Care Products and Other Microconstituents - What Technologies are Working? [Conference] // Water Environment Federation Technical Exhibition and Conference 2011. - Los Angeles : Water Environment Federation, 2011.

Cluin Matt Effective Open Areas [E-Mail]. - [s.l.] : JWC Environmental, 2011.

Crites R and Tchobanoglous G Small and Decentralized Wastewater Management Systems [Book]. - New York : McGraw-Hill, 1998. - ISBN 0-07-289087-8.

Crook James Water reclamation and Reuse Regulatory and Water Quality Drivers [Conference] // Water Environment Federation Technical Exhibition and Conference 2011. - Los Angeles : Water Environment Federation, 2011.

Daigger Glen T Evolving Urban Water and Residuals Management Paradigms: Water Reclamation and Reuse, Decentralization, and Resource Recovery [Journal] // Water Environment Research. - [s.l.] : Water Environment Federation, 2009. - 8 : Vol. 81.

Davis Mackenzie L Water and Wastewater Engineering: Design Principles and Practice [Book]. - New York : McGraw-Hill, 2010. - ISBN 978-0-07-171384-9.

DeCarolus James [et al.] Bottom Line - Experts Evaluate the Costs of Municipal Membrane Bioreactors [Journal] // Water Environment & Technology. - [s.l.] : Water Environment Technology, 2008. - Vol. 20.

DeCarolus Jr James F and Adham Samer Performance Investigation of Membrane Bioreactor Systems During Municipal Wastewater Reclamation [Journal] // Water Environment Research. - [s.l.] : Water Environment Federation, 2007. - 13 : Vol. 79. - ISSN 10614303.

Demirbas A Global Renewable Energy Projections [Journal] // Energy Sources, Part B: Economics, Planning, and Policy. - [s.l.] : Taylor & Francis, 2009. - 2 : Vol. 4. - ISSN 1556-7249.

Drainville Marc [et al.] Reducing the Carbon Footprint of the Hyannis WPCF Through Renewable Energy Production and Energy Efficiency Measures [Conference] // Water Environment Federation Technical Exhibition and Conference 2011. - Los Angeles : Water Environment Federation, 2011.

Dryden Hugh and von Doenhoff A Solar Energy in the Exploration of Space [Journal] // Proceedings of the National Academy of Sciences of the United States of America. - [s.l.] : National Academy of Sciences, 1961. - 8 : Vol. 47.

du Pisani Petrus L Direct reclamation of potable water at Windhoek's Goreangab reclamation plant [Journal] // Desalination. - [s.l.] : Elsevier, 2006. - 1-3 : Vol. 188. - ISSN 00119164.

Energy Matters My Solar Estimator [Online]. - Energy Matters LLC, 2012. - June 26, 2012. - <http://www.solar-estimate.org/index.php>.

EPRI Program on Technology Innovation: Electric Efficiency Through Water Supply Technologies - A Roadmap [Report]. - Palo Alto, CA : Electric Power Research Institute, 2009.

EPRI Water & Sustainability (Volume 4): U.S. Electricity Consumption for Water Supply & Treatment - The Next Half Century [Report]. - Palo Alto, CA : Electric Power Research Institute, 2002.

Fabiyi and E Malcolm Understanding the Alpha Factor [Journal] // Membrane Technology. - [s.l.] : Water & Wastes Digest, 2008.

Fane A and Fane S The role of membrane technology in sustainable decentralized wastewater systems [Journal] // Water Science and Technology. - [s.l.] : IWA Publishing, 2005. - 10 : Vol. 51. - ISSN 02731223.

Find Solar Solar Calculator [Online]. - American Solar Energy Society & Cooler Planet , 2012. - June 26, 2012. - <http://www.findsolar.com/index.php?page=rightforme>.

Germain E [et al.] Biomass effects on oxygen transfer in membrane bioreactors [Journal] // Water Research. - [s.l.] : Elsevier, 2007. - Vol. 41.

GLUMRB Recommended Standards for Wastewater Facilities [Book]. - Albany, NY : Health Research Inc., 2004.

Goodrich Alan, James Ted and Woodhouse Michael Residential, Commercial, and Utility-Scale Photovoltaic (PV) System Prices in the United States: Current Drivers and Cost-Reduction Opportunities [Report]. - Golden, Colorado : National Renewable Energy Laboratory, 2012.

Goulds Pumps Pump Selection System [Java Program]. - Seneca Falls, NY : ITT Corporation, 2012.

Green Martin A Radiative efficiency of state-of-the-art photovoltaic cells [Journal] // Progress in Photovoltaics: Research and Applications. - [s.l.] : John Wiley & Sons, 2012. - Vol. 20.

Green Martin A Silicon Photovoltaic Modules: A Brief History of the First 50 Years [Journal] // Progress in Photovoltaics: Research and Applications. - [s.l.] : John Wiley & Sons, 2005. - Vol. 13.

Gude Verra G, Nirmalakhandan Nagamany and Deng Shuguang Renewable and sustainable approaches for desalination [Journal] // Renewable and Sustainable Energy Reviews. - [s.l.] : Elsevier Ltd., 2010. - Vol. 14.

Hartley Troy W Public perception and participation in water reuse [Journal] // Desalination. - [s.l.] : Elsevier B.V., 2006. - Vol. 187. - pp. 115-126.

Hartley Troy W Water Reuse: Understanding Public Perception and Participation [Report]. - Alexandria, Virginia : Water Environment Research Foundation, 2003.

Hecht Jeff New techniques boost photovoltaic efficiency [Journal] // Laser Focus World. - [s.l.] : PennWell, 2010.

Hirani Zakir M [et al.] Peak flux performance and microbial removal by selected membrane bioreactor systems [Journal] // Water Research. - [s.l.] : Elsevier Ltd, 2010. - 8 : Vol. 44. - ISSN 00431354.

Huber Technology Mechanical Wastewater Screening [Report]. - [s.l.] : Huber Technology, 2008.

Huertas E [et al.] Key objectives for water reuse concepts [Journal] // Desalination. - [s.l.] : Elsevier B.V., 2008. - Vol. 218. - pp. 120-131.

Ilemobade A, Adewumi J and van Zyl J Non-Potable Water Use/Reuse in South Africa: Review and Strategic Issues [Conference] // Water Distribution Systems Analysis 2008. - [s.l.] : American Society of Civil Engineers, 2008. - ISBN 978-0-7844-1024-0.

IRENA Renewable Energy Technologies: Cost Analysis Series - Volume 1: Power Sector - Biomass for Power Generation [Report]. - [s.l.] : International Renewable Energy Agency, 2012.

Jones Garr M [et al.] Pumping Station Design [Book]. - Burlington : Elsevier Inc, 2008. - ISBN 978-1-85617-513-5.

Kaya Durmus [et al.] Energy efficiency in pumps [Journal] // Energy Conversion and Management. - [s.l.] : Elsevier, 2008. - Vol. 49.

Kazmi A Wastewater reclamation and reuse areas - Japanese experiences [Journal] // Journal of Indian Water Works Association. - [s.l.] : Indian Water Works Association, 2005. - 2 : Vol. 37. - ISSN 0970275X.

Leonics How to Design Solar PV System [Online]. - Leonics Co, 2009. - June 26, 2012. - http://www.leonics.com/support/article2_12j/articles2_12j_en.php.

Leverenz Harold L, Tchobanoglous George and Asano Takashi Direct potable reuse: a future imperative [Journal] // Journal of Water Reuse and Desalination. - [s.l.] : IWA Publishing, 2011. - 1 : Vol. 1.

Lin Shun D Water and Wastewater Calculations Manual [Book]. - [s.l.] : McGraw-Hill, 2007. - 2nd Edition. - ISBN 0-07-147624-5.

Liu Betty, Brumbelow Kelly and Haberl Jeff S Water/Wastewater Engineering Report (High Efficiency Pump/Motor Replacement - M2 Model) [Report]. - [s.l.] : Texas A&M University, 2005.

Livingston Dennis Beyond Conventional MBRs: Oxygen transfer technology revolutionizing MBR applications [Article] // Water and Wastes Digest. - [s.l.] : Scranton Gillette Communications, 2010. - Fall.

Mackie Alec and Oyler Kenny The Inudestry's Finest: Operators share their experiences with the new breed of wastewater finescreens [Journal] // Water Environment & Technology. - [s.l.] : Water Environment Federation, 2007. - 7 : Vol. 19.

Malcolm Pirnie Wastewater Treatment and Sludge Management: Energy Reference Guide [Report]. - Albany, NY : New York State Energy Research and Development Authority, 1995.

Mandalaki M [et al.] Assessment of fixed shading devices with integrated PV for efficient energy use [Journal] // Solar Energy. - [s.l.] : Elsevier, 2012. - Vol. 86.

Mays Larry W Water Resources Engineering [Book]. - Hoboken, NJ : Wiley, 2010. - 2nd Edition. - ISBN 978-0-470-46064-1.

McMahon James E and Price Sarah K Water and Energy Interactions [Report] / Annual Review of Environment and Resources. - [s.l.] : Annual Reviews, 2011.

Menniti Adrienne [et al.] The Evolution of MBR Design to Minimize Capital Cost and Optimize Energy Efficiency [Conference] // Water Environment Federation Technical Exhibition and Conference 2011. - Los Angeles : Water Environment Federation, 2011.

Messenger John [et al.] Membrane Bioreactors: Results of Low Power Use Design Procedures [Conference] // Water Environment Federation Technical Exhibition and Conference 2011. - Los Angeles : Water Environment Federation, 2011.

Metcalf & Eddy, Inc Wastewater Engineering: Treatment and Reuse [Book]. - New York : Tata McGraw-Hill, 2003. - ISBN 978-0-07-049539-5.

Metcalf & Eddy, Inc Water Reuse: Issues, Technologies, and Applications [Book]. - New York : McGraw-Hill, 2007. - ISBN 978-0-07-145927-3.

Mizuta Kentaro and Shimada Masao Benchmarking energy consumption in municipal wastewater treatment plants in Japan [Journal] // Water Science and Technology. - [s.l.] : IWA Publishing, 2010. - 10 : Vol. 62. - ISSN 02731223.

Navaratnasamy Mahendran, Edeogu Ike and Papworth Lawrence Economic Feasibility of Anaerobic Digesters [Journal] // Agri-Facts. - [s.l.] : Alberta Agriculture and Rural Development, 2008.

NRDC Water Efficiency Saves Energy: Reducing Global Warming Pollution Through Water Use Strategies [Report]. - [s.l.] : Natural Resources Defense Council, 2009.

NREL PVWatts Grid Data Calculator (Version 2) [Online] // National Renewable Energy Laboratory. - United States Department of Energy, June 6, 2011. - 06 26, 2012. - <http://www.nrel.gov/rredc/pvwatts/grid.html>.

NWRI Ultraviolet Disinfection: Guidelines for Drinking Water and Water Reuse [Book]. - Fountain Valley, CA : National Water Research Institute, 2012. - 3rd.

Onn Lee Water Management Issues in Singapore [Conference] // Water in Mainland Southeast Asia. - Siem Reap, Cambodia : [s.n.], 2005.

Orange County Water District Groundwater Recharge [Online] // Groundwater Replenishment System. - 2012. - 02 06, 2012. - <http://www.gwrsystem.com/the-process/water-delivery/groundwater-recharge.html>.

Palmer Dennis W Wastewater Plant Taps Biogas, Solar and Wind [Journal] // BioCycle. - [s.l.] : JG Press Inc, 2009. - 12 : Vol. 50.

Pellegrin Marie-Laure and Kinnear David J MBR Energy Consumption: Comparing Operating Full-Scale Plants [Conference] // Water Environment Federation Technical Exhibition and Conference 2011. - Los Angeles : Water Environment Federation, 2011.

Public Utilities Board NEWater [Online] // PUB, Singapore's national water agency. - 01 03, 2012. - 02 10, 2012. - <http://www.pub.gov.sg/water/newater/Pages/default.aspx>.

Qasim Syed R Wastewater Treatment Plants: Planning, Design, and Operation [Book]. - Boca Raton : CRC Press, 1999. - ISBN 1-56676-688-5.

Rittmann Bruce E and McCarty Perry L Environmental Biotechnology: Principles and Applications [Book]. - New York : McGraw Hill, 2001. - ISBN 0-07-234553-9.

Rosso Diego and Stenstrom Michael K Alpha Factors in Full-Scale Wastewater Aeration Systems [Conference] // Water Environment Federation Technical Exhibition and Conference 2006. - [s.l.] : Water Environment Federation, 2006.

Salgot M [et al.] Wastewater reuse and risk: definition of key objectives [Journal] // Desalination. - [s.l.] : Elsevier B.V., 2006. - Vol. 187. - pp. 29-40.

Seeta Vamsi [et al.] "Free" Solar Power - A Big Leap Towards Energy Self-Sufficiency at WWTPs [Conference] // Water Environment Federation Technical Exhibition and Conference 2011. - Los Angeles : Water Environment Federation, 2011.

SEIA U.S. Market Installs 772 MW in Q2 2012; More than Doubling Q2 2011 Market Size [Online] // Solar Industry Data. - Solar Energy Industries Association, 2012. - November 20, 2012. - <http://www.seia.org/research-resources/solar-industry-data>.

Shrestha Eleeja [et al.] Carbon footprint of water conveyance versus desalination as alternatives to expand water supply [Journal] // Desalination. - [s.l.] : Elsevier, 2011. - 1-3 : Vol. 280.

Shrestha Eleeja [et al.] The carbon footprint of water management policy options [Journal] // Energy Policy. - [s.l.] : Elsevier, 2012. - Vol. 42.

Smith & Loveless PISTA Grit Removal Systems Clears Highest Grit Removal Efficiencies // PISTA Grit Removal System. - [s.l.] : Smith & Loveless Inc., 2007.

Sobhani Reza [et al.] Energy Footprint Analysis of Orange County Sanitation District's Operations [Conference] // Water Environment Federation Technical Exhibition and Conference 2011. - Los Angeles : Water Environment Federation, 2011.

Spanggaard Holger and Krebs Frederik C A brief history of the development of organic and polymeric photovoltaics [Journal] // Solar Energy Materials & Solar Cells. - [s.l.] : Elsevier, 2004. - Vol. 83.

Sturm Terry W Open Channel Hydraulics [Book]. - New York : McGraw-Hill, 2010. - 2nd Edition. - ISBN 978-0-07-339787-0.

Tchobanoglous G [et al.] Decentralized wastewater management: challenges and opportunities for the twenty-first century [Journal] // Water Science and Technology: Water Supply. - [s.l.] : IWA Publishing, 2004. - 1 : Vol. 4. - ISSN 16069749.

Tchobanoglous George [et al.] Direct Potable Reuse: A Path Forward [Report]. - Washington, DC : WaterReuse Research and WaterReuse California, 2011.

The World Bank World Development Report 2010: Development and Climate Change [Book]. - Washington DC : The International Bank for Reconstruction and Development / The World Bank, 2010. - ISBN 978-0-8213-7989-5.

Toze Simon Reuse of effluent water - benefits and risks [Journal] // Agricultural water management. - [s.l.] : Elsevier B.V., 2006. - Vol. 80. - pp. 147-159.

Trabish Herman K The Water-Energy Nexus and Our Infrastructure Gap [Online] // greentechmedia:. - GTM Research, February 16, 2012. - February 19, 2012. - <http://www.greentechmedia.com/articles/read/The-Water-Energy-Nexus-and-Our-Infrastructure-Gap/>.

Trojan Technologies TrojanUV3000Plus Brochure [Online] // Trojan UV. - 2008. - 03 30, 2012. - http://trojanuv.com/resources/trojanuv/Products/TrojanUV3000Plus/TROW1040_3000Plus_Detail_LR.pdf.

Trojan Technologies TrojanUV4000Plus Brochure [Online] // Trojan UV. - 2007. - 03 30, 2012. - http://trojanuv.com/resources/trojanuv/Products/TrojanUV4000Plus/TROJANUV_4000Plus.pdf.

U.S. EIA Electric Power Sector Consumption Estimates [Online] // State Energy Data System. - United States Energy Information Administration, 2010. - September 16, 2012. - http://www.eia.gov/state/seds/sep_use/total/pdf/use_NV.pdf.

U.S. EIA Electric Power Annual 2010 [Online] // Electricity. - United States Energy Information Administration, November 9, 2011b. - July 13, 2012. - <http://www.eia.gov/electricity/annual/>.

U.S. EIA World total primary energy consumption by region, Reference case, 2006-2035 [XLSX] = International Energy Outlook 2011. - [s.l.] : United States Energy Information Administration, 2011a.

U.S. EPA Calculations and References [Online] // Clean Energy. - United States Environmental Protection Agency, May 31, 2012. - September 18, 2012. - <http://www.epa.gov/cleanenergy/energy-resources/refs.html>.

U.S. EPA Clean Watersheds Needs Survey 2004: Report to Congress [Report]. - Washington DC : United States Environmental Protection Agency, 2004b.

- U.S. EPA** Clean Watersheds Needs Survey 2008: Report to Congress [Report]. - Washington DC : United States Environmental Protection Agency, 2008.
- U.S. EPA** Ensuring a Sustainable Future: An Energy Management Guidebook for Wastewater and Water Utilities [Report]. - Washington DC : United States Environmental Protection Agency, 2008.
- U.S. EPA** Evaluation of Energy Conservation Measures for Wastewater Treatment Facilities [Report] / Office of Wastewater Management. - Washington DC : United States Environmental Protection Agency, 2010.
- U.S. EPA** Fine Pore Aeration Systems - Design Manual [Book]. - Cincinnati : United States Environmental Protection Agency, 1989.
- U.S. EPA** Guidelines for Water Reuse [Report] / Office of Wastewater Management. - Washington, DC : United States Environmental Protection Agency, 2004a.
- U.S. EPA** Municipal Wastewater Disinfection Design Manual [Book]. - Cincinnati : United States Environmental Protection Agency, 1986.
- U.S. EPA** Nitrogen Control Manual [Book]. - Washington DC : United States Environmental Protection Agency, 1993.
- UNFCCC** Kyoto Protocol [Online] // United Nations Framework Convention on Climate Change. - 2012. - February 18, 2012. - http://unfccc.int/kyoto_protocol/items/2830.php.
- Urkiaga A [et al.]** Development of analysis tools for social, economic and ecological effects of water reuse [Journal] // Desalination. - [s.l.] : Elsevier B.V., 2008. - Vol. 218. - pp. 81-91.
- URS** Evaluation of Ultraviolet (UV) Radiation Disinfection Technologies for Wastewater Treatment Plant Effluent [Report]. - Albany, NY : New York State Energy and Research Development Authority, 2004.
- Verrecht Bart [et al.]** Model-based energy optimisation of a small-scale decentralised membrane bioreactor for urban use [Journal] // Water Research. - [s.l.] : Elsevier Ltd., 2010. - Vol. 44.
- Vulcan Industries, Inc** Mensch Crawler Bar Screen [Book]. - Missouri Valley, IA : Vulcan Industries, Inc, 2011.
- Wallis-Lage Cindy and Levesque Scott D** Energy-efficient MBRs [Journal] // Water Environment & Technology. - [s.l.] : Water Environment Federation, 2011.

WEF Clarifier Design [Book]. - New York : McGraw-Hill, 2005. - 2nd Edition. - ISBN 0-07-146416-6.

WEF Design of Municipal Wastewater Treatment Plants [Book]. - [s.l.] : McGraw-Hill, 2010a. - 5th Edition. - ISBN 978-0-07-166358-8.

WEF Energy Conservation in Water and Wastewater Facilities [Book]. - New York : McGraw-Hill, 2010b. - ISBN 978-0-07-166794-4.

WEF Membrane Bioreactors [Book]. - New York : McGraw-Hill, 2012. - ISBN 978-0-07-175366-1.

WEF Membrane Systems for Wastewater Treatment [Book]. - New York : McGraw-Hill, 2006. - ISBN 0-07-146419-0.

WEF Nutrient Removal [Book]. - New York : McGraw-Hill, 2011. - ISBN 978-0-07-173709-8.

WEF Operation of Municipal Wastewater Treatment Plants [Book]. - New York : McGraw-Hill, 2008. - ISBN 978-0071543675.

WHO WHO Guidelines for the Safe Use of Wastewater, Excreta and Greywater: Volumes 1-4 [Report]. - Geneva, Switzerland : World Health Organization Press, 2006.

Yang Lingbo [et al.] Operational energy performance assessment system of municipal wastewater treatment plants [Journal] // Water Science & Technology. - [s.l.] : IWA Publishing, 2010. - 6 : Vol. 62.

Yi Lili, Chen Xiaoning and Chen Weiping An overview of reclaimed water reuse in China [Journal] // Journal of Environmental Sciences. - [s.l.] : Chinese Academy of Sciences, 2011. - 10 : Vol. 23. - ISSN 10010742.

VITA

Graduate College
University of Nevada, Las Vegas

Jonathan R Bailey

Degrees:

Bachelor of Science in Engineering, Civil Engineering, 2010
University of Nevada, Las Vegas

Publications:

Bailey, Jonathan R; Batista, Jacimaria R; Ahmad, Sajjad. Water Reuse and Energy Interactions. Presentation at the Tri-State Seminar Annual Conference. Primm, NV. September 25-27, 2012.

Bailey, Jonathan R. Water Reuse and Energy Interactions. Presentation at the Nevada Water Environment Association (NWEA) Annual Conference. Sparks, NV. April 24-25, 2012.

Newell, Timothy; Bailey, Jonathan R; Batista, Jacimaria R; Risso, LeAnna; Mills, Jeff. Vivianite Formation Potential in Biological Phosphorus Removal Systems. Presentation at the Nevada Water Environment Association (NWEA) Annual Conference. Sparks, NV. April 24-25, 2012.

Bailey, Jonathan R; Newell, Timothy; Batista, Jacimaria R. Potential for Vivianite Formation at the Solids Handling Centrifuges of the Clark County Water Reclamation District – Technical Report. October 2011.

Thesis Title:

Investigating the Impacts of Conventional and Advanced Treatment Technologies on Energy Consumption at Satellite Water Reuse Plants

Thesis Examination Committee:

Committee Co-Chair, Jacimaria R. Batista, Ph. D

Committee Co-Chair, Sajjad Ahmad, Ph. D

Committee Member, Jose Christiano Machado Jr., Ph. D

Graduate Faculty Representative, Yahia Baghzouz, Ph. D