
Masters Theses

Student Theses and Dissertations

1970

OPTUMR a digital computer program to cost optimize a district heat piping network to remove waste heat from nuclear power reactors

James Richard Hendricks

Follow this and additional works at: https://scholarsmine.mst.edu/masters_theses

 Part of the [Nuclear Engineering Commons](#)

Department:

Recommended Citation

Hendricks, James Richard, "OPTUMR a digital computer program to cost optimize a district heat piping network to remove waste heat from nuclear power reactors" (1970). *Masters Theses*. 5454.
https://scholarsmine.mst.edu/masters_theses/5454

This thesis is brought to you by Scholars' Mine, a service of the Curtis Laws Wilson Library at Missouri University of Science and Technology. This work is protected by U. S. Copyright Law. Unauthorized use including reproduction for redistribution requires the permission of the copyright holder. For more information, please contact scholarsmine@mst.edu.

OPTUMR
A DIGITAL COMPUTER PROGRAM
TO COST OPTIMIZE A DISTRICT
HEAT PIPING NETWORK TO REMOVE
WASTE HEAT FROM NUCLEAR POWER REACTORS

BY
JAMES RICHARD HENDRICKS, 1942-

A
THESIS
submitted to the faculty of
UNIVERSITY OF MISSOURI-ROLLA
in partial fulfillment of the requirements for the
Degree of
MASTER OF SCIENCE IN NUCLEAR ENGINEERING

Rolla, Missouri

1970

T2508
180 pages
c.1

Approved by

D. Ray Edwards (advisor) Henry A. Wiebe
L. H. Morgan

ABSTRACT

The thermal pollution problem of a nuclear reactor electrical generating facility can be eliminated if an economical, productive use for the waste heat can be found. The computer program presented here is designed to investigate the economic feasibility of utilizing this waste heat to heat buildings. The program optimizes a district heating network using the reactor's rejected heat and performs a comparative analysis with a selected conventional heat rejection system. The results indicate that the system is feasible only if the reactor can be sited relatively close (5 miles) to an urban center. Increasing national concern regarding thermal pollution and recently enacted legislation will tend to make this system more competitive so long as the current siting restrictions (about 10-12 miles) are not made more stringent.

TABLE OF CONTENTS

	Page
ABSTRACT.....	ii
TABLE OF CONTENTS.....	iii
LIST OF ILLUSTRATIONS.....	iv
LIST OF TABLES.....	v
I. INTRODUCTION.....	1
II. REVIEW OF LITERATURE.....	3
III. DISCUSSION.....	8
A. SIMULATION OF PIPING NETWORK BY AN ELECTRICAL CIRCUIT.....	8
B. REDUCTION OF THE CIRCUIT.....	12
C. THEORY OF THE CALCULATIONS.....	15
D. OPTIMIZATION THEORY.....	19
E. ECONOMIC ANALYSIS.....	28
F. SAFETY.....	31
IV. COMPUTER PROGRAM FLOW DIAGRAM.....	33
V. TYPICAL PROBLEM AND RESULTS.....	40
VI. CONCLUSIONS.....	56
VII. APPENDICES.....	A1
A. SYMBOLS USED.....	A1
B. FORTRAN IV PROGRAM LISTING.....	B1
C. SUBROUTINE LISTING.....	C1
D. INPUT INSTRUCTIONS.....	D1
E. BALANCE SHEETS.....	E1
VIII. BIBLIOGRAPHY.....	60
IX. ACKNOWLEDGEMENTS.....	63
X. VITA.....	64

LIST OF ILLUSTRATIONS

FIGURE	Page
1. LOAD DISTRIBUTION OF FARSTA REACTOR.....	5
2. SCHEMATIC OF CONVENTIONAL REJECTION SYSTEM.....	9
3. SCHEMATIC OF DISTRICT HEATING REJECTION SYSTEM.....	10
4. CONTROL CIRCUIT.....	11
5. ARTIST'S SKETCH OF DISTRICT HEAT SYSTEM.....	13
6. EQUIVALENT CIRCUIT DIAGRAM.....	14
7. NETWORK REDUCTION.....	16
8. THREE DIMENSIONAL OPTIMIZATION SPACE.....	22
9. GENERAL COST CURVE.....	25
10. DISCONTINUOUS COST CURVE.....	26
11. THREE POSSIBLE CURVE SHAPES.....	27
12. COMPUTER PROGRAM FLOW DIAGRAM.....	34
13. THREE EXAMPLE CIRCUITS.....	D15

LIST OF TABLES

TABLE	Page
I. PARAMETERS OF AGE STA.....	6
II. COST CALCULATIONS OPTIONS.....	20
III. INPUT DATA FOR TYPICAL PROBLEM.....	44
IV. COMPUTER PROGRAM RESULTS FOR DATA IN TABLE III.....	45
V. COST DATA VS. DISTANCE FROM REACTOR TO URBAN AREA..	57

I. INTRODUCTION

The consumption of electrical power in the United States is doubling about every ten years [30]¹. To meet this increasing energy demand, the use of nuclear powered generating plants is currently considered by many to be the best solution. Among the many problems that have developed with the use of nuclear powered generating facilities is the increased thermal pollution from nuclear reactors as compared to fossil fueled plants. Although this problem exists in conventionally powered generating facilities, the nuclear powered plant rejects from ten to fifty per cent more waste heat than its conventionally powered counterpart.

The problem under consideration here is one possible solution to the thermal pollution problem by a nuclear powered generating plant. The heat rejected from a nuclear powered generating plant is low energy waste heat because the prime, high energy steam is used for electrical generation. If a practical use of this low energy waste heat can be developed and exploited, then this major problem of nuclear powered generating plants can be solved.

A practical use of this low energy rejected heat is in a district heating network. This use has been investigated by A. J. Miller [22] and most dramatically by the Swedish experimental nuclear reactor Agesta². In both of these investigations, it has been determined that, under proper conditions, the use of nuclear reactor waste heat to heat buildings can be profitable. To date, however, this scheme has not been utilized in the United States.

1. Numbers in brackets indicate references in bibliography.

2. In some references the designation ADAM or R3 are used.

The most significant disadvantage of the nuclear district heating system is the requirement to provide continuous heat to the system. An unscheduled shutdown of the reactor could cause serious consumer relationships. However, because the current tendency in the nuclear industry is to construct multiple reactor sites, the solution to this problem is to design the nuclear plants such that either plant could provide the base heating requirements of district heating network. Further, the reliability problem can be alleviated using conventional heat sources for peaking service (with the additional capability of providing the base load requirements for short periods of time) as is done in the Agesta Plant. (See Page 5.)

To further develop this use of nuclear reactor waste heat, the digital computer program described herein has been developed to cost optimize and economically analyze a district heat distribution network. The program is designed for use by an electrical generating facility that is considering the use of nuclear reactor power generation. By supplying appropriate input data, the electrical utility can determine the feasibility of installing a district heat distribution system to remove the reactor's waste heat.

II. REVIEW OF LITERATURE

Probably the most frequently discussed topic in the United States today is pollution -- smog, industrial pollution, automobile pollution, radioactive pollution, and thermal pollution [21,24,30]. At the present time there are numerous legal struggles in progress attempting to stop the construction of industrial plants on pollution grounds or to cause the shutdown of existing plants because of excessive pollution. In addition to the legal struggles, there is a newly enacted law (The National Environmental Policy Act) which may bring about even more dramatic legal action [21]. Further, Jaske [19] reported that growing national interest in the thermal and radioactive pollution problems could ultimately prevent the construction of nuclear reactor generating facilities.

There are many proposed solutions to the thermal pollution problem. Among these are: 1. cooling towers [25], 2. natural convection cooling ponds [20], 3. spray cooling ponds [25], 4. concurrent electrical production and desalination [28], 5. use of waste heat for industrial processes [3], 6. melting of the Saint Lawrence Seaway in the winter [6], 7. more efficient methods of sewage treatment [4], 8. heated irrigation water [2], and 9. district heating systems [6,13,22,31]. The first three methods can cause a severe mist or fog under certain weather conditions, particularly in the northern part of the United States, and, in general, require a relatively large makeup water supply. The next two require, in general, a higher energy source than the waste heat from a nuclear reactor. The remaining four have the disadvantage of being seasonal requirements. The district heating system, however, can be used to provide air

conditioning [18] using an absorption air conditioning plant.

The preliminary investigation by the United States into the utilization of waste heat from nuclear generating plants for district heating was conducted by A. J. Miller under an Atomic Energy Commission contract [22]. The results of this investigation revealed that if the nuclear reactor could be sited a reasonable distance from an urban-industrial area (by a reasonable distance, five miles is considered a maximum), then the installation of a district heating network would be profitable.

In addition to Miller's investigation, the Swedish government has constructed and successfully operated the Agesta heavy water reactor in a district heating network [7,27,31]. The Agesta reactor is a 65 Megawatt Thermal (MwT), dual purpose (10 Mw Electrical, 55 MwT) reactor designed to produce electrical power and to heat the city of Farsta which is 10-15 miles from Stockholm. This reactor has been in operation since about 1964.

The Agesta reactor is located about three miles from Farsta. The justification for the proximity to the population center is that the reactor is built underground. (In fact, the reactor is built in a mountain under rock.) The district heating water from the reactor ties into an existing district heating distribution system. The nuclear reactor is designed to absorb the base heating load with conventional plants assuming the peaking loads. This load distribution is shown as Figure 1. The plant is shut down for maintenance in the summer months [27]. A summary of the parameters of the Agesta reactor are shown in Table I.




FIGURE 1. LOAD DISTRIBUTION OF FARSTA REACTOR

TABLE I
PARAMETERS OF AGESTA

Rating	55 Mw Thermal 10 Mw Electrical
Type	Pressurized, heavy water moderated and cooled, slightly enriched Uranium.
Flowrate	4,800,000 lbs./hour
Outlet Temperature	160 to 240 degrees F
Return Temperature	130 to 150 degrees F
Operating time	5000 to 6000 hours/year
Make up water when operating cooling towers	75 tons/hour

The economic performance of the Agesta reactor is not satisfactory [27]. This statement is made, even with consideration given to the reduction in size of conventional heat removal equipment, and the advantages gained from lesser maintenance expenses. (The Agesta has fully capable conventional heat removal system.) The problem with Agesta, however, is not in the district heating concept. The economic difficulties in Agesta are caused by severe losses of heavy water (D_2O) from the primary plant. The replacement cost of the D_2O has led to the development of a pressurized light water reactor for district heating [5].

The design, construction, operation and maintenance of district heating systems have been under development and used for many years [6]. Due to the volume of literature available dealing with these systems, a summary of the opinions of several authors [8,9,16,20,32] is presented:

1. The system should be installed underground.
2. A closed liquid system (e.g. water) should be used in preference to steam.
3. Due to the corrosiveness of the environment, the piping should be relatively corrosion resistant, insulated for protection, and encased in a conduit with provision for conduit drainage.
4. Adequate duplication of equipment, manholes, isolation capability, and instrumentation should be provided to increase the system's reliability.

These guidelines were used to prepare the computer program. In some cases, the user has the option of changing these guidelines. See Appendix D for input instructions.

III. DISCUSSION

The logical starting point of the district heating system analysis is at the heat source. A schematic diagram of a typical power reactor and the reactor's heat rejection system is shown in Figure 2. Figure 3 shows the heat rejection system for a typical reactor plant that has a district heating network capability. Since the systems are equivalent from the reactor to the condenser, for the rest of this discussion, the heat source is considered to be the condenser. Figure 3 shows that in addition to the district heating network, a small heat rejection system (cooling tower, cooling pond, etc.) would be installed. This would give the plant the capability of following minor transient heat demands on the district heating network while producing a constant amount of electrical power.

An automatic control system would sense the fluid temperature to the district heating network and the inlet to the condenser. The control system would then generate position commands for the automatically controlled throttle valves in the pump suction and condenser discharge lines. This would distribute the flow to the district heating network and to the tower to maintain the desired temperature. Figure 4 shows a block diagram of a simple analog circuit that will control the system as described above.

A. Simulation of Piping Network by an Electrical Circuit

The piping network that is proposed for installation as the district heat piping network is simulated using an electrical circuit to represent the network. The mass flowrate is treated as an electrical current; pressure drops are treated as voltage drops; and piping lengths, bends, traps, etc. are treated as resistors. Pumps




FIGURE 2. SCHEMATIC OF CONVENTIONAL REJECTION SYSTEM




FIGURE 3. SCHEMATIC OF DISTRICT HEATING REJECTION SYSTEM




FIGURE 4. CONTROL CIRCUIT

are analyzed as voltage or current sources and the head losses, due to the fluid passing through the buildings, are treated as series resistors.

The principles used to accomplish this simulation are illustrated using Figures 5 and 6. Figure 5 shows a piping system that might be a typical, scale district heating system using a nuclear reactor's waste heat. The reduction of this network to an electrical circuit is shown in Figure 6. The current source is the representation of the pump; R1 is the line loss from the reactor to the city; R2,R3, R5,R7,R8, and R9 are the losses in the piping to and from buildings 2,3,5,7,8, and 9 of Figure 5; R4,R6,R10, and R11 are the losses in the lines between building groups; and R12 is the loss from the city back to the reactor.

Since the heating requirements for the buildings are known, one can readily compute the mass flowrates (currents) required for each building. A simple Kirchoff's node law application gives a mass balance at the nodes. In addition, one can readily calculate the pressure drops in each path of the network if one is given the size of piping required. The details of the above outlined technique are more fully explained in the next section and are illustrated by means of an example on page 40.

B. Reduction of the Circuit

Once the physical space heating network has been simulated by an electrical circuit, there is a reduction procedure that is employed to insure that:

1. All piping runs are optimized,

and




FIGURE 5. ARTIST'S SKETCH OF DISTRICT HEAT SYSTEM




FIGURE 6. EQUIVALENT CIRCUIT DIAGRAM

2. No piping run has duplicate calculations performed.

To accomplish these objectives, the electrical network is step-by-step reduced in the manner discussed below.

The basic principle used is that any linear, purely resistive, two terminal electrical circuit can be simulated by an equivalent circuit composed of a voltage or current source and an equivalent resistance [10,17,23].

The reduction is accomplished by starting at the most distant flowpath from the reactor and by step-wise reducing the network until the entire system is optimized. This reduction is best illustrated by using the example problem shown in Figure 6. The step-by-step reduction is shown in Figure 7. This reduction technique is explained in more detail in Appendix D.

C. Theory of the Calculations

In this section, the basic equations and theory used in computing the cost and economic values are presented.

The calculations start with a given mass flow rate and an assumed diameter. From this data and the continuity equation

$$W = \rho A \bar{V} , \quad (1)$$

one can calculate the average velocity for a one pipe system. If more than one pipe of the same diameter is used, the flow is assumed to be equally distributed. Thus, by increasing the number of pipes, the average velocity can be reduced. This is done by the program to insure that \bar{V} is less than the maximum desired by the programmer. For later use, it is also noted that the volumetric flowrate, Q , is given by

$$Q = A \bar{V} \quad (2)$$








FIGURE 7. NETWORK REDUCTION

For incompressible, closed system fluid flow, the Bernoulli equation reduces to

$$H_{\ell} = \Delta p / \rho = \frac{4fL}{D} \frac{\bar{V}^2}{2gc} \quad (3)$$

The unknown friction factor in equation 3 is computed using an empirical relationship [20] based on the Reynolds Number

$$RE = \frac{D V \rho}{\mu}, \quad (4)$$

and the following relationships:

$$f = \frac{16}{RE} \quad RE \leq 2200 \quad (5)$$

$$f = 0.186 - .0026 \log RE \quad 2100 < RE < 100000 \quad (6)$$

$$f = 0.0025 \quad RE \geq 100000 \quad (7)$$

Summarizing the results, one has the head loss in the piping, volumetric flow rate, velocity and the number of pipes.

The installation costs that are computed are the pump cost, piping cost, excavation cost, insulation cost, conduit cost and manhole costs. In addition, a supplemental cost subroutine is provided to permit other cost inputs to be made. The cost estimation schemes for each of these items will be further described below.

Before describing the cost schemes in detail, however, some basic cost estimation techniques that are used frequently throughout the program will be described.

One of the most powerful tools of the cost estimator is the cost-price index [25,28,29]. For a variety of specific and general types of equipment, components, or operations, cost analysts compute a number called the cost-price index. A cost-price index is

the ratio of the cost (price) of a specific item (e.g. a pump) at some specified time to the cost (price) of the same item at some other time. The advantageous feature of the cost-price index is the ability to accurately predict the cost of a specified item at some later time, using some previous time. If, for example, one had cost estimates for three different items: one based on 1965 dollars, one on 1967 dollars and one on 1969 dollars, the uncorrected addition of these costs to obtain a total cost would be in error. If, however, one uses the cost-price indices, one can adjust the costs to the same year. Further, using the same concept, one can estimate the cost at some future date.

Another tool for the estimator is the exponential estimation technique [25]. In this technique, one is given a base size of an item and a base price for that size. Then, to estimate the cost of the same item of a different size, one uses

$$\text{New Cost} = (\text{Base Cost}) \times \left(\frac{\text{New Size}}{\text{Base Size}} \right)^a \quad (8)$$

Numerous references in the literature give values of the exponent, a , to use for various types of equipment. In general, this value lies from 0.4 to 1.5, average being about 0.6.

An extension of the exponent method is to have two values of item size and item cost. In equation 8, designate new cost, new size as cost 2, size 2; base values as cost 1, size 1. Thus,

$$\text{cost 2} = (\text{cost 1}) \times \left(\frac{\text{size 2}}{\text{size 1}} \right)^{\text{expon}} \quad (9)$$

Taking logarithms of (9),

$$\ln (\text{cost 2}) = \ln (\text{cost 1}) + (\text{expon}) \times \ln \left(\frac{\text{cost 2}}{\text{cost 1}} \right) \quad (10)$$

Solving (10) for exponent

$$\text{expon} = \frac{\ln (\text{cost } 2) - \ln (\text{cost } 1)}{\ln (\text{cost } 2/\text{cost } 1)} \quad (11)$$

Thus, one can calculate the exponent for use in equation 8.

Returning to the costs that are computed in the program, Table II indicates the options available for the cost calculations previously mentioned. In addition, the functional dependence of each cost is indicated. Notes are provided to explain the table.

D. Optimization Theory

There are an infinite number of combinations of pipe size and number of pipes that can transport fluid at a given rate. The principles of linear algebra can be used to describe the manner that the optimum size and number of pipes can be computed.

The first problem is to identify the independent variables that one can have. Certainly the mass flowrate, the number of pipes and the size of piping are independent variables. There are other independent variables (e.g. length), however, it is assumed that these variables are specified to fit the problem under consideration³. The result is that one has a three dimensional space in flowrate, number of pipes and size of pipes. This three dimensional space is not an infinite space. There are physical limitations imposed that reduce the space to a finite size. For example, the maximum pipe diameter commercially available is a finite number; the minimum

3. For example, to get from the reactor to a building there are many conceivable paths of different lengths. However, one is going to select the one that is the most acceptable for the particular situation, and thus will specify the length and length will become a constant rather than a variable.

TABLE II
COST CALCULATIONS OPTIONS

	Cost Price Index	Table Cost vs. Size	Exponent Method	Extrapolated Exponent Method	Direct Input Method	Functional Relationship
Pump Cost	Yes	Yes	Yes	Yes	Yes	$N*Q^{.98}$ **
Pipe Cost	Yes	Yes	Yes	Yes	Yes	$N*L*D^{1.15}$
Excavation Cost	Yes	No	No	No	Yes	$VOL* COST / VOL = (2+N*D) (3+D)$ ***
Manhole Cost	Yes				Yes	$L*DEPTH*HOLE COST / \# \text{ of ft. per hole}$
Insulation Cost	Yes				Yes	$N*L*D*COST / ft.$
Conduit Cost	Yes	Yes		Yes	Yes	$N*L*D^{.6}$
Pumping Cost	Yes				Yes	$N*H*\rho*Q / CONST$

** Exponents taken from reference

*** Assumes pipes side by side with 3 feet of earth on top

number of pipes to be considered may be set by reliability criteria; the flowrate may be a specified flowrate.

In this problem, the constraints are chosen as follows:

1. Flowrate is fixed.
2. A maximum and minimum pipe diameter is specified.
3. A minimum number of pipes is specified.
4. A maximum velocity of fluid is specified. (This is not an independent variable. However, to define a finite region of interest in three dimensional space, a combination of three complete restraints is required. The flowrate is one restraint. The minimum and maximum diameter is a second restraint. The maximum fluid velocity and the minimum number of pipes combine to make the third restraint.)

Figure 8 shows a sketch of this three dimensional space and how these restraints define an operating line.

There are many dependent variables that could be chosen for an optimization scheme. Some of these could be:

1. minimize installation cost
2. minimize operating expense
3. minimize maintenance expense
4. minimize shut down time (maximize reliability)
5. minimize total costs
6. maximize profit

or

7. a combination of some or all of the above.




FIGURE 9. GENERAL COST CURVE

Two different schemes are available to be selected which will optimize the network as is described below⁴.

The first of these schemes is an optimization based on the minimization of the cost of installing the network and the cost of operating the network for a specified period of time. The minimization of installation cost alone was not chosen as a basis for optimization due to the effect of operating expenses on the economic analysis⁵. Total cost was not chosen since the installation and operating expenses are the most important terms in the total cost analysis. The period of time for this optimization was chosen to be one year since the other economic considerations (depreciation, taxes, etc.) are annual charges. The user has the ability to change this time period if he desires. A description of the methods used to optimize the network using this technique follows.

Using the input data of flowrate (W), length of piping (L), and building loss (BLOSS), and the limits of pipe size to be considered, the program calculates the number of pumps and pipes required and the cost of the pumps, piping, excavation, insulation, manholes, conduits and any supplemental installation costs for a given piping diameter. It also calculates the pumping power cost for the specified period of time and pipe diameter as previously mentioned. The total of these cost items is then computed and stored in memory. In addition, the user can input right of way cost data and can input the

4. These schemes were selected by consideration of recommendations contained in reference [29].

5. Further details can be found in reference [26], pg 4-8 and pg 135-167.

economic advantage of installing the piping in rivers or lakes where no right of way expense is incurred.

The general form of the cost of installation and pumping cost is illustrated in Figure 9. As one can see, the total cost curve has a broad minimum that one should be able to find quite readily. However, the real world is not so simple. For the flow rates required by a heating system of the size under consideration, the economic feasibility and reality of the problem requires that a limit be placed on the velocity of fluid flowing in the pipes. This limiting velocity is input specified and determines the number of pipes and pumps required to move the quantity of fluid required. Thus, as the diameter varies, so does the number of pipes, pumps, etc. The result of this is the curve shown in Figure 10. As one can see, the curve is now discontinuous. (The discontinuities are caused by changing the number of pipes.)

One method of finding the minimum would be to take the range of pipe sizes under consideration, start at the smallest and proceed through to the largest in a step-by-step manner (hereafter referred to as a march-out technique). The optimum size would be the smallest total cost found while conducting the march-out technique. This method, however, can be very costly in computer time and a better technique has been found.

Referring to Figures 9 and 10, the cost is computed for the maximum size, the minimum size and the medium size (K_1, K_2 , and K_3 on Figure 10). A smooth curve is then fit to the points and the curve is analyzed for shape. Three possible shapes exist and are shown in Figure 11. If the curve orientation is as in Figure 11A, then




FIGURE 8. THREE DIMENSIONAL OPTIMIZATION SPACE




FIGURE 10. DISCONTINUOUS COST CURVE






FIGURE 11. THREE POSSIBLE CURVE SHAPES

costs for sizes K4 and K5 are computed. The shape of the curve that fits through K4, K2 and K5 is then checked. If the shape is as in Figure 11A, the process is repeated (K6, K7 of Figure 10) until the orientation changes to 11B or 11C, or until K2 is found to be the minimum. When the orientation changes to either 11B or 11C (as it does in Figure 10 using points K6, K2, and K7), then the march-out procedure is used from a little before the smaller diameter to a little beyond the larger diameter. Thus, one finds the minimum using considerably less computer time than a straight march-out technique.

The second method of optimization is to maximize the profit that can be made. This is done by calculating the hourly financing cost, operating and maintenance costs, the pumping costs and then comparing these values with the hourly gross income from the sale of heat for a march-out of the pipe diameters. The maximum net income is found from this march-out technique. This is then taken to be the optimum size for maximum return on investment and a full set of cost calculations and cost analysis is performed.

E. Economic Analysis

The economic analysis is a basic discounted cash flow type of analysis. This type of analysis is a summary of all cash assets and liabilities as either cash inflows or as cash outflows on an annual basis. A net cash flow is the algebraic sum of the cash inflows and the cash outflows. The net cash flow for each year is then adjusted to the plant start-up time for the time value of money by applying an appropriate adjustment factor. This factor is obtained from a continuous interest table or from the equation

$$\text{factor} = e^{-rt} \left[\frac{e^r - 1}{r} \right] \quad (12)$$

In principle, this type of analysis is quite easy. The result of this analysis is the return on investment rate, r , which appears in the factor term in a rather complicated fashion requiring a trial and error type of solution.

The elements of the cash flow analysis are the fixed capital investment (assumed to be expended one year before start-up), operating and maintenance expenses, financing charges, insurance, taxes, overhead, taxes, miscellaneous annual expenses and the gross income from the sale of heat.

In the proposed system, there is a possibility that the system may not be a profitable investment. There are situations, however, which may justify the use of a non-profitable investment. Consider, for example, the situation that is developing in the field of electrical generation. At the projected rate of growth, the available cooling water supply that can be used without severely disturbing the ecological balance will soon be exhausted [24]. The use of rivers, lakes and streams for cooling of the generating facilities will therefore be precluded.

Continuing with the example, local legislation may forbid the use of cooling towers due to the severe fog and mist problems associated with cooling towers. Further, similar difficulties could be encountered in the other possible methods of heat rejection. The extreme case would be that the district heat rejection method would be the only acceptable method of heat rejection. Thus, as previously asserted, the use of a non-profitable system could be justified.

To make a meaningful analysis of the district heating system of heat rejection, an analysis of the cost of this system versus the cost of the alternative system must be made. The ultimate test of the district heating system can be stated as follows: Is the district heating system of heat rejection the least expensive method compared to the alternative methods (if any)? The method chosen to answer this question is described below.

Consider a district heating system that is not profitable. Adjustments to the cost of installation of the district heating system are made by computing the cost of construction and operation of a selected alternative system. This cost is then subtracted from the district heating systems cost. In addition, a factor can be specified to account for the intangible benefit of no thermal pollution. If, by repeating the cash flow analysis, the district heating system can then be shown to be profitable, the district heating system should be installed. Further, even if this adjusted system analysis does not show a true profit, but does yield an acceptable pay out time⁶, the district heating system should be installed.

The adjusted economic analysis can reveal that the installation of a district heating system will not be profitable nor will yield an acceptable pay out time. However, the decision to install this system could still be made for better public relations or to gain technology in the field. To encourage this, the program calculates

6. As used here, pay out time is the number of years to regain the capital investment.

the incremental increase in selling price of heat or selling price of electricity that would be required to pay off the plant in the specified lifetime.

F. Safety

A discussion of a project using nuclear reactors in any manner is not complete until a safety analysis of some sort is performed. It is assumed that the reactor plant and its' associated equipment meets the requirements set forth in Title 10 of the Code of Federal Regulations. With this assumption, the only safety analysis required is just the analysis of the district heating system.

The primary safety concern of a nuclear reactor is the release of radioactivity to the environment in such a manner that would be detrimental to the general population. The general criterion set forth in the federal regulations is that at least two barriers against release of radioactivity be provided.

Consider a boiling water reactor with a district heating system installed. (This reactor type is chosen because the possibility of radioactivity in the condenser is greatest for this type reactor.) The only source of radioactivity to the fluid in the system would be leakage from the condenser into the district heating system fluid. The tube walls of the condenser serve as the first barrier. The second barrier is a potential barrier. The condenser is operated in a slight vacuum while the district heating system is pressurized to about 200-300 pounds per square inch at the condenser. Thus, any leakage that would occur in the condenser tubes would be from the district heating system into the condenser. Further, the district heating system piping would serve as a third barrier. A periodic or continuous

monitoring of the district heating system fluid for radioactivity would serve as an independent control.

The other serious problem (Maximum Credible Accident) is the effect of a major rupture in the district heating system. Since the reactor is protected against a loss of cooling system, all that need be considered is the effect on the district heating system. Since the major portion of the piping is underground, the effect of this accident would be slight if the rupture occurred in a portion of the piping that is underground. However, one might consider the rupture of the pipe line inside a building. As one can readily see, this accident is the determining factor in the choice of fluid that is used. If steam were used, this accident would be very serious because of the high temperatures and high internal energy of the steam. Further, isolation of a steam system will not stop the steam flow from the rupture. However, since water is used, the rupture would cause an almost instantaneous depressurization of the system. This would then lead to hot (170-180 degree) water being pumped into the building at low pressure. With automatic isolation capabilities sensed by a severe pressure transient installed, the effect of this accident is only that a small quantity of fairly high temperature water is sprayed into a building. This hot water could cause some damage; however, the probability of this accident being serious is fairly low.

IV. COMPUTER PROGRAM FLOW DIAGRAM

Figure 12 shows a block diagram which indicates the flow control of the computer program. The figure consists of a flow diagram for the main program, a flow diagram for each of the three path types (series, parallel and series-parallel) and a flow diagram for the two optimization schemes (minimization of installation cost and pumping cost, and maximization of the rate of return on investment).




FIGURE 12. COMPUTER PROGRAM FLOW DIAGRAM




FIGURE 12. (CONT'D)




FIGURE 12. (CONT'D)




FIGURE 12. (CONT'D)




FIGURE 12. (CONT'D)




FIGURE 12. (CONT'D)

V. TYPICAL PROBLEM AND RESULTS

The following paragraphs will give the statement of a typical problem of the type that can be solved by OPTUMR.

Suppose it was desired to heat the buildings shown in Figure 5 and simulated by Figure 6 using the waste heat from a nuclear reactor. The objective is to find the installation cost, the operating cost, and the profit or loss potentials of such a system in sufficient detail to determine the feasibility of starting the preliminary design phases.

It is assumed that the following data is given:

1. The effective lifetime of the plant is 30 years.
2. The effect of pumping power cost determines the shape of the optimization curve (see Figures 9 and 10). For the optimization in the problem, a basis of 600 days is chosen at a cost of 1.1¢ per kilowatt-hour.
3. An overall plant load factor of 0.8 is specified.
4. The selling price of heat at 170 degrees F at the buildings is \$1.37/million BTU.
5. Due to reliability requirements, no less than two pipes are permitted in any flowpath.
6. Due to reliability requirements, 150% of the number of pumps required will be purchased and installed.
7. The maximum velocity in any pipe is 12 ft/second.
8. The cooling medium is water (density is 62.4, viscosity is 0.000292.)
9. The plant's salvage value at the end of thirty years is 5%.
10. Depreciation is to be calculated by the sum of the years digits method.

11. The operating costs are 2% of the total installation charges.
12. Working capital is 10% of the annual pumping power cost.
13. The basic plant overhead is \$1000.00 per month.
14. The cost of the conduit drainage system is 10% of the insulation cost.
15. The minimum and maximum diameters to be considered are 6 and 100 inches respectively.
16. It is desired to minimize the capital investment and operating expenses.
17. All costs are to be corrected to 1975 dollars. To accomplish this, use the following values for cost price indices:

Pumps	1.83	Pumping Power	1.28
Excavation	1.44	Insulation	1.39
Manhole	1.26	Piping	1.28
Conduit	1.33		
18. There is an engineering service charge of \$200,000.
19. The company will borrow 50% of the investment cost at 7% interest.
20. The federal income tax rate is 50%.
21. The county tax rate is 1¢/\$100 of capital investment.
22. Insurance costs are \$7,623 dollars per year.
23. There is a paving cost of \$2.00 per foot of piping that is installed.
24. The following cost data is supplied:

Pump Cost	Unknown
Pipe Cost	A 10" pipe costs \$30.00 per foot

Conduit Cost	A 36" conduit costs \$14.00 per foot; a 72" conduit costs \$46.00 per foot
Insulation Cost	\$1.50 per foot
Manhole Cost	\$38.00 per foot of depth; one hole every 500 feet

25. The building requirements are as follows:

Building	Length To & From (ft)	Heat Requirement (BTU/hr)	Flow (lbs/hr)	Building Loss (ft)
2	300	10^7	$4. \times 10^5$	30
3	300	5×10^7	$2. \times 10^6$	40
5	400	2×10^8	$1. \times 10^7$	50
7	200	5×10^7	$2. \times 10^6$	40
8	200	10^7	$4. \times 10^5$	30
9	200	8×10^7	$4. \times 10^6$	45

26. The piping from the reactor site to buildings 2 & 3 is five miles.

27. The distance from building 2 & 3 to building 5 is 1/2 mile.

28. The distance from building 5 to buildings 7, 8, & 9 is 1000 feet.

29. The right of way costs are \$1.00 per foot.

30. For comparative analysis, use:

Cost of physical plant	\$5,000,000.00
Savings	50%
Flowrate of conventional plant	36,800 gal. per min.

Pumping cost	\$1,000,000.00
Piping cost	\$1,000,000.00

The input data describing this problem is given in Table III. (See also Appendix D.) Table IV shows the computer output for this problem. (The computer program computes an annual balance sheet for the life of the plant. Table IV contains only the balance sheet for the 1st year for the non-adjusted and the adjusted economic analyses; Appendix E contains the balance sheets for years 2-30.)

COST OPTIMIZATION OF A
DISTRICT HEATING PIPING
NETWORK

J1	J2	J3	J4	J5	J6	J7	J8	J9	J10	J11	J12	J13	J14	J15	J16	J17	J18	J19	J20
1	1	0	1	1	1	3	2	1	1	1	1	1	0	0	0	1	1	1	2
JJ1	JJ2	JJ3	JJ4	JJ5	JJ6	JJ7	JJ8	JJ9	JJ10	JJ11	JJ12	JJ13	JJ14	JJ15	JJ16	JJ17	JJ18	JJ19	JJ20
1	1	0	2	1	0	1	1	0	0	1	2	0							

THE INPUT DIAMETER LIMITS ARE 6 53 100

INPUT DENSITY AND VISCOSITY ARE: 62.3999939 0.0002920

COST PRICE INDICES ARE:
 1.8299999 1.2799997 1.4399996 1.3899994 1.2599993 1.3299999 1.2799997

LIMITING VELOCITY IS : 12.0000000

THE MIN # OF PIPES IS : 2

MANHOLE COST IS : \$ 38.0000000 A MANHOLE IS INSTALLED EVERY 500.000000FEET

INPUT DATA BASE COSTS

BASE FLOW RATE	PUMP COST	BASE PIPE SIZE	PIPE COST	EXCAVATION	INSULATION	BASE DAYS	\$/KWH
0.0	0.0	10.000	30.000	2.250	1.500	600.000	0.011

TABLE IV. COMPUTER PROGRAM RESULTS FOR DATA IN TABLE III

PATH NO.	# OF PIPES	DIA.	PUMP COST	PIPE COST	EXCAVATION COST	INSULATION COST	MANHOLE COST	CONDUIT COST	PUMPING COST
1	2	9	0.0	13607.23	8505.00	625.50	172.37	3207.42	30362.38
2	2	6	0.0	8536.20	6804.00	417.00	172.37	2723.44	4296.41
3	2	12	0.0	18943.02	10367.99	834.00	172.37	3724.00	67299.25
4	2	15	0.0	122423.81	61964.97	5212.49	861.84	21361.80	36821.38
6	2	15	0.0	122423.81	61964.97	0.0	861.84	21361.80	36821.38
7	2	24	0.0	554890.88	256607.81	22017.59	2275.25	80538.50	155989.19
8	2	19	0.0	64266.86	30689.97	2641.00	344.74	10103.49	188932.06
9	2	24	0.0	554890.88	256607.81	0.0	2275.25	80538.50	155989.19
10	2	6	0.0	12804.30	10205.99	625.50	258.55	4085.16	4384.20
11	2	9	0.0	20410.84	12757.49	938.25	258.55	4811.13	31807.47
12	2	26	184606.25	6083923.00	2798923.00	238523.63	22752.56	863833.00	1476410.00
13	2	26	0.0	6083923.00	2798923.00	0.0	22752.56	863833.00	1476410.00

TOTAL COST IS: \$\$\$ 30563344.0000000

TABLE IV. (CONT'D)

ECONOMIC INPUT DATA

LOAD FACTOR	SALE PRICE OF HEAT	EFFECTIVE LIFE	SALVAGE VALUE	SINKING FUND RATE
0.80000	1.37000	30.00000	0.05000	0.0
T1-T5 VALUES ARE :	0.0	0.0	0.0	0.0
0.0				
T6-T10 VALUES ARE :	0.01000	0.0	0.0	0.03500
12000.00000				
T11-T15 VALUES ARE :	0.50000	0.0	0.00010	0.0
0.0				
T16-T18 VALUES ARE :	0.0	7623.00000		
0.0				
U1-U5 VALUES ARE :	0.0	0.0	0.10000	0.0
1.50000				
U6-U10 VALUES ARE :	0.10000	0.0	0.0	2.00000
0.0				
U11,U12,U13 VALUES ARE :	0.0	200000.00000		
0.0				
U14-U19 VALUES ARE :	1.00000	1.00000	0.0	0.0
0.0				
U19-U23 VALUES ARE :	1000000.00000	36800.00000	0.50000	5000000.00000
1000000.00000	1000000.00000			

TABLE IV. (CONT'D)

COST DATA AND TOTALS

PATH #	PUMP COST	PIPE COST	EXCAVATION COST	INSULATION COST	MANHOLE COST	CONDUIT COST	PUMPING COST	GROSS INCOME/HOUR
1	0.0	13607.23	8505.00	625.50	172.37	3207.42	30362.38	54.80
2	0.0	8536.20	6804.00	417.00	172.37	2723.44	4296.41	10.96
3	0.0	18943.02	10367.99	834.00	172.37	3724.00	67299.25	87.68
4	0.0	122423.81	61964.97	5212.49	861.84	21361.80	36821.38	0.0
6	0.0	122423.81	61964.97	0.0	861.84	21361.80	36821.38	0.0
7	0.0	554890.88	256607.81	22017.59	2275.25	80538.50	155989.19	0.0
8	0.0	64266.86	30689.97	2641.00	344.74	10103.49	188932.06	219.20
9	0.0	554890.88	256607.81	0.0	2275.25	80538.50	155989.19	0.0
10	0.0	12804.30	10205.99	625.50	258.55	4085.16	4384.20	10.96
11	0.0	20410.84	12757.49	938.25	258.55	4811.13	31807.47	54.80
12	184606.25	6083923.00	2798923.00	238523.63	22752.56	863833.00	1476410.00	0.0
13	0.0	6083923.00	2798923.00	0.0	22752.56	863833.00	1476410.00	0.0
TOTALS	184606.25	13661042.00	6314321.00	271834.94	53158.24	1960121.00	3665522.00	438.40

TABLE IV. (CONT'D)

YEAR 1		OUTFLOWS	INFLOWS
	THE TOTAL INSTALLATION COST IS :	\$ 26897824.00	
	THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:	4452744.00	
	THE GROSS ANNUAL INCOME IS :		3787770.00
	THE DEPRECIATION IS :	1648576.00	
	THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	268978.13	
	THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:	941423.69	
	THE ANNUAL PUMPING COST IS:	2199313.00	
	THE ANNUAL SUPPLEMENTARY COSTS ARE:	12000.00	
	THE PROPERTY TAXES ARE:	2689.78	
	THE ANNUAL INSURANCE CHARGES ARE:	7623.00	
	THE ANNUAL RIGHT-OF-WAY COST IS:	2056.00	
	THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:		294061.19

TABLE IV. (CONT'D)

A CASH FLOW SUMMARY FOLLOWS

YEAR	NET CASH FLOW	5%	10%	15%	20%	25%	30%	35%
-1	-27581776.00	-28288784.00	-29019856.00	-29776304.00	-30558624.00	-31368096.00	-32205712.00	
1		286830.44	279836.25	273069.13	266521.19	260184.38	254050.94	248113.56
2		279836.25	266521.19	254050.94	242365.13	231408.13	221128.31	211478.13
3		273069.13	254050.94	236798.88	221128.25	206875.31	193894.25	182055.31
4		266521.19	242365.19	221128.31	202413.69	185882.13	171243.06	158247.56
5		260184.38	231408.06	206875.31	185882.06	167849.00	152298.19	138834.88
6		254050.94	221128.31	193894.25	171243.06	152298.19	136362.88	122881.69
7		248113.56	211478.19	182055.31	158247.56	138834.88	122881.69	109667.56
8		242365.13	202413.69	171243.06	146682.00	127132.19	111410.19	98635.44
9		236798.88	193894.25	161354.56	136362.88	116918.81	101592.13	89352.38
10		231408.06	185892.13	152298.19	127132.19	107969.25	93140.25	81480.38
11		226186.56	178342.50	143991.94	118853.75	100095.44	85822.81	74754.19
12		221128.25	171243.06	136362.88	111410.19	93140.25	79451.75	68964.63
13		216227.31	164554.00	129345.63	104700.06	86972.06	73874.06	63945.89
14		211478.13	158247.63	122881.69	98635.44	81480.38	68964.63	59565.61
15		206875.31	152298.19	116918.81	93140.25	76572.13	64620.99	55717.73
16		202413.69	146682.00	111410.19	88148.31	72168.81	60758.56	52316.75
17		198088.25	141377.13	106313.88	83602.13	68203.88	57307.54	49293.27
18		193894.25	136362.88	101592.13	79451.75	64621.01	54209.83	46590.66
19		189827.00	131620.50	97211.00	75653.38	61372.02	51417.07	44162.50
20		185882.06	127132.19	93140.25	72168.81	58415.97	48888.72	41970.44
21		182055.31	122881.69	89352.38	68964.63	55717.75	46590.66	39982.62
22		178342.50	118853.75	85822.81	66011.56	53247.17	44494.11	38172.46
23		174739.63	115034.38	82529.25	63283.77	50978.32	42574.61	36517.68
24		171243.06	111410.25	79451.75	60758.56	48888.72	40811.33	34999.40
25		167949.00	107959.25	76572.13	58415.97	46958.97	39186.47	33601.66
26		159154.31	101264.44	71449.94	54392.86	43689.89	36448.12	31250.55
27		140983.38	83766.00	62335.61	47365.76	38019.96	31710.81	27186.81
28		123482.38	76966.44	53813.94	40823.37	32750.02	27310.44	23412.92
29		106623.31	65817.00	45833.61	34719.24	27839.96	23212.58	19899.04
30		90379.33	55272.90	38348.49	29012.38	23254.71	19387.25	16619.23
TOTALS		-21455536.00	-23527488.00	-25122192.00	-26468592.00	-27678704.00	-28812848.00	-29905776.00

TABLE IV. (CONT'D)

A LISTING OF THE NET CASH FLOW FOLLOWS:

YEAR AFTER START-UP	NET CASH FLOW
1	294061.19
2	294061.19
3	294061.19
4	294061.19
5	294061.19
6	294061.19
7	294061.19
8	294061.19
9	294061.19
10	294061.19
11	294061.19
12	294061.19
13	294061.19
14	294061.19
15	294061.19
16	294061.19
17	294061.19
18	294061.19
19	294061.19
20	294061.19
21	294061.19
22	294061.19
23	294061.19
24	294061.19
25	294061.19
26	284411.88
27	256935.63
28	229459.38
29	201983.13
30	174506.81

THE PAY OUT TIME AT CURRENT RATE IS: 9.1470154E 01

TABLE IV. (CONT'D)

YEAR 1		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1308292.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		60010.50	

TABLE IV. (CONT'D)

A CASH FLOW SUMMARY FOLLOWS

YEAR	NET CASH FLOW	5%	10%	15%	20%	25%	30%	35%
-1	-21888592.00	-22449680.00	-23029840.00	-23630160.00	-24250992.00	-24893376.00	-25558096.00	
1		1334656.00	1302111.00	1270623.00	1240155.00	1210669.00	1182129.00	1154502.00
2		1281361.00	1220392.00	1163291.00	1109782.00	1059610.00	1012539.69	968351.81
3		1230126.00	1144453.00	1066735.00	996142.56	931935.75	873458.19	820126.13
4		1180866.00	1073839.00	979745.81	896827.69	823581.69	758720.88	701142.19
5		1133498.00	1008133.69	901256.25	809798.88	731237.50	663490.00	604836.75
6		1087939.00	946952.69	830326.38	733325.69	652196.94	583956.06	526224.50
7		1044115.69	889945.88	766128.25	665939.94	584247.19	517112.69	461505.00
8		1001953.31	836791.50	707929.88	606393.13	525572.69	460577.13	407765.44
9		961383.00	787194.00	655085.75	553621.63	474680.44	412455.19	362763.00
10		922337.69	740882.00	607024.50	506718.69	430339.94	371234.94	324761.44
11		884754.06	697606.50	563240.63	464909.63	391534.50	335705.44	292409.31
12		848571.69	657139.13	523287.69	427532.69	357422.31	304893.19	264649.38
13		813730.94	619268.06	486767.94	394019.06	327303.00	278011.19	240648.31
14		780176.88	583801.00	453330.31	363882.13	300594.19	254421.75	219747.13
15		747856.31	550559.50	422662.81	336702.94	276809.00	233605.50	201420.13
16		716718.56	519380.56	394488.00	312120.81	255539.63	215137.50	185246.25
17		686714.50	490113.44	368559.38	289824.44	236443.19	198668.56	170885.44
18		657797.56	462619.13	344657.19	269544.69	219230.50	183910.00	158061.50
19		629923.38	436770.44	322585.75	251048.69	203657.38	170622.75	146549.19
20		603049.19	412449.38	302170.88	234134.13	189516.38	158607.50	136162.81
21		577134.69	389548.00	283256.56	218625.25	176631.13	147697.31	126749.13
22		552140.44	367966.00	265703.56	204368.81	164850.88	137751.75	118180.19
23		528029.13	347611.38	249387.38	191231.13	154046.50	128652.13	110349.25
24		504765.13	328398.75	234196.19	179095.13	144106.94	120297.63	103166.06
25		482314.56	310250.00	220030.19	167858.38	134936.69	112602.38	96554.44
26		460644.50	293092.44	206799.50	157430.63	126452.75	105492.75	90449.25
27		439723.75	276858.94	194423.19	147732.63	118583.31	98905.19	84795.00
28		419522.06	261487.56	182828.69	138694.25	111265.69	92785.13	79543.56
29		400011.38	246921.19	171950.75	130253.75	104445.19	87085.00	74653.81
30		381164.13	233106.69	161730.06	122356.13	98073.88	81763.31	70089.56
TOTALS		1404426.00	-4014007.00	-7729589.00	-10510034.00	-12735397.00	-14610953.00	-16255642.00

TABLE IV. (CONT'D)

A LISTING OF THE NET CASH FLOW FOLLOWS:
 YEAR AFTER START-UP

	NET CASH FLOW
1	1368302.00
2	1346497.00
3	1324692.00
4	1302887.00
5	1281083.00
6	1259278.00
7	1237473.00
8	1215668.00
9	1193863.00
10	1172058.00
11	1150253.00
12	1128449.00
13	1106644.00
14	1084839.00
15	1063034.00
16	1041229.38
17	1019424.63
18	997619.75
19	975814.87
20	954009.88
21	932205.00
22	910400.31
23	888595.38
24	866790.38
25	844985.44
26	823180.69
27	801375.94
28	779570.69
29	757765.94
30	735961.19

THE RETURN ON INVESTMENT IS : 3 PER CENT

THE PAY OUT TIME AT CURRENT RATE IS: 1.4944779E 01

TABLE IV. (CONT'D)

FLOW EDIT

PATH #	# OF PIPES	FLOWRATE	LENGTH	BUILDING LOSS	DELTA T	Q	HEAD LOSS
1	2	0.200000E 07	0.200000E 03	0.400000E 02	0.250000E 02	0.4451570E 01	0.4420813E 02
2	2	0.400000E 06	0.200000E 03	0.300000E 02	0.250000E 02	0.8903134E 00	0.3127821E 02
3	2	0.400000E 07	0.200000E 03	0.450000E 02	0.200000E 02	0.8903137E 01	0.4899443E 02
4	2	0.640000E 07	0.100000E 04	0.0	0.0	0.1424502E 02	0.1675392E 02
5	2	0.640000E 07	0.100000E 04	0.0	0.0	0.1424502E 02	0.1675392E 02
6	2	0.164000E 08	0.264000E 04	0.0	0.0	0.3650284E 02	0.2769794E 02
7	2	0.164000E 08	0.264000E 04	0.0	0.0	0.3650284E 02	0.2769794E 02
8	2	0.100000E 08	0.400000E 03	0.500000E 02	0.200000E 02	0.2225783E 02	0.5501770E 02
9	2	0.164000E 08	0.264000E 04	0.0	0.0	0.3650284E 02	0.2769794E 02
10	2	0.400000E 06	0.300000E 03	0.300000E 02	0.250000E 02	0.8903134E 00	0.3191733E 02
11	2	0.200000E 07	0.300000E 03	0.400000E 02	0.250000E 02	0.4451570E 01	0.4631721E 02
12	2	0.184000E 08	0.264000E 05	0.0	0.0	0.4095441E 02	0.2336607E 03
13	2	0.184000E 08	0.264000E 05	0.0	0.0	0.4095442E 02	0.2179092E 01

TABLE IV. (CONT'D)

VI. CONCLUSIONS

Thermal pollution from nuclear reactor electrical generating facilities is a serious problem now. The most important consideration affecting the use of a district heating rejection method is the siting consideration. For example, the Palisades reactor, located along the shore of Lake Michigan, has a court injunction against operation due to thermal pollution of Lake Michigan. Use of the district heating rejection scheme is not feasible because the closest urban center is about thirty miles distant.

The conservationist group that backed the injunction has demanded that the returning coolant enter the lake with not more than one degree temperature rise from inlet to outlet. Consumers Power Corporation, the owner, is faced with the installation of cooling towers of the closed type⁷. The cost of the delay while cooling tower construction takes place is about \$33,000.00 per day. The solution of this reactor's problem is still unresolved [30].

Table V is a summary of the results of the computer programs solutions for various distances from the reactor to the urban area. In compiling the data for the table, all of the input parameters except distance remained as in the typical problem described on page 40. As one can see from the table, a distance from the reactor to the urban center of greater than 5 miles yields a system that does not show a profit and greater than 8 miles yields a system whose gross income will not meet the annual operation expenses.

7. Closed cooling towers installation cost is 2.6 times the cost of open cooling towers. Open towers cannot be used at Palisades because of the proximity of an interstate highway.

TABLE V
COST DATA VERSUS DISTANCE FROM REACTOR TO URBAN AREA

Distance (Miles)	Installation* Costs	Annual** Financing Costs	Annual** Operating & Maintenance	Annual** Taxes	Return on Investment (Per Cent)
1	5.23	183.	517.	1363.	23
2	9.33	326.	770.	1033.	14
3	13.3	464.	1020.	713.	9
4	17.3	606.	1276.	386.	6
5	21.3	747.	1538.	60.	3
6	25.7	900.	1780.	-----	0
7	29.8	1042.	2038.	-----	-3
8	33.9	1186.	2291.	-----	-9
9	38.0	1329.	2398.	-----	.54&&
10	42.0	1473.	2799.	-----	.73&&

* Millions of dollars

** Thousands of dollars

&& Incremental cost increase to pay off plant in 30 years, $\$/10^6$ BTU

As previously mentioned, the district heating system must have a back-up method of supplying heat to the buildings. Dual reactor sites can provide this reliability especially if the scheduled shutdowns for maintenance and refueling are conducted at times of low heat demand. If a dual reactor site is not possible, an additional expense that is not included in the computer program would be incurred for a back-up system.

The population of the United States is facing a critical decision. A critical shortage of available fossil fuels is just starting to be apparent. To meet the energy demand requirements, the use of nuclear energy seems to be the only plausible solution. The shortage of cooling water, as exhibited in the Palisades case, is critical now. The question that the public must answer is: Does the severity of potential danger of nuclear reactors (thermal pollution and radioactive pollution, in particular) warrant the cessation of increasing the electrical power consumption? This question raises a direct conflict when applied to a nuclear reactor supplied district heating system. This system would minimize the thermal pollution. To be efficient, however, the reactor must be sited close to an urban center. The potential damage from a gross fission product release accident increases as the distance to an urban center decreases. The cost of electrical power generation will increase, in any case, as the anti-pollution legislation increases.

The ability to choose reactor sites close to cities that would meet the safety requirements with regard to radioactive pollution is the first problem that must be solved. Once this problem is solved, then use of the district heating rejection system will resolve the thermal pollution problem. Perhaps the Palisades case will cause











increased investigation and experimentation in proximity siting and district heating. The computer code presented here is a tool for the utility to use for comparative analysis with other heat rejection systems. If the current trend in legislation is a valid trend, certainly this program will receive extensive use.

VII. APPENDICES

APPENDIX A

SYMBOLS USED

Standard abbreviations [12] are used throughout.

	Valve
	Turbine Generator
	Pump
	Heat Exchanger (Condenser or Steam Generator)
	Summing Junction
	Amplifier
	Feedback Gain
	Resistor
	Current Source
	Voltage Source

W Mass flow rate, lbs./hr.

ρ Density, lbs./ft.³

A Area normal to flow, ft.²

\bar{V} Average velocity of fluid, ft./sec.

Q Volumetric flow rate, ft.³/sec.

H_L Head loss, ft. of water

Δp Pressure drop, lbs./ft.²

f Friction factor, dimensionless

L Length of piping, ft.

D Diameter of piping, ft.

g_c Gravitational constant, 32.17 ft-lb mass/lb force sec.²

R_E Reynolds number, dimensionless

μ Viscosity, ft/lb-sec.

\log Logarithm, base 10

BLOSS	Building loss, ft. of water
K1,K2,K(I)	Piping sizes, inches
r	Return on investment rate, years ⁻¹
t	Time, years
BTU	British thermal unit

```

COMMON/A1/K1,K2,K3
COMMON/A2/RHO,POIS
COMMON/A4/MONY
COMMON/A3/CPI(7)
COMMON/A5/ NJ1,NJ2,NJ3,NJ4,NJ5
COMMON /A6/ KK
COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2
COMMON/A9/TPIPE(100)
COMMON/A10/TCNDT(200)
COMMON/A11/TPUMP(100)
COMMON/A12/BASEW,BASEP,BASEE,BASEV,BASED,BASE$,BASEW$,BASEP$
COMMON/A13/HOLCST,HOLFT
COMMON/A14/ VELLIN,NNN
COMMON/A15/J10,J11,J12,J13,J14,J15,J16,J17,J18,J19,J20
COMMON/A16/ NODE(13),TCOST(100)
COMMON/A17/ N,Q,H,DD,D,ZL,ZCOST,ZZCOST,ACOST
COMMON/A18/ BCOST,CCOST,DCOST,ECOST,FCOST,GCOST
COMMON/A19/ $2(4),$1(4),X1(4),X2(4)
COMMON/A20/JJ1,JJ2,JJ3,JJ4,JJ5,JJ6,JJ7,JJ8,JJ9
COMMON/A22/FCTRLD,BASEH$
COMMON/A23/YEARS,SALVAS$,FRINTR,T1,T2,T3,T4,T5,T6
COMMON/A24/ T7,T8,T9,T10,T11,T12,T13,T14,T15,T16,T17,T18
COMMON/A25/U1,U2,U3,U4,U5,U6,U7,U8,U9,U10,U11,U12,U13
COMMON/A27/ INSULI
COMMON/A28/U14,U15,U16,U17,U18,U19,U20,U21,U22,U23
DATA NIN,NOUT /1,3/
1 FORMAT(I10)
2 FORMAT(I10,13I5)
23 FORMAT(I2,8F9.2)
25 FORMAT(6F10.2)
107 FORMAT(////,' TOTAL COST IS: $$$',F20.7,/)
647 FORMAT('1',//////////,F50,' COST OPTIMIZATION OF A
1',/,T50,' DISTRICT HEATING PIPING',/,T59,' NETWORK',/, '1')
701 FORMAT(' PATH # OF DIA.',4X,'PUMP',T35,'PIPE',T46,'EXCAVATION',T
162,' INSULATION',T78,'MANHOLE',T94,'CONDUIT',T107,'PUMPING',/,
2' NO. PIPES',I21,' COST',T35,'COST',T50,'COST',T65,'COST',T80,
3'COST',T95,'COST',T110,'COST',/)
705 FORMAT('1')
4612 FORMAT(5I10)
CALL ERRSET(208,260,-2,1)
WRITE(NOUT,647)
READ(NIN,4612) NJ1,NJ2,NJ3,NJ4,NJ5
DEFINE FILE 11(1000,40,U,K400)
DEFINE FILE 12(1000,40,U,K400)
DEFINE FILE 13(1000,40,U,K400)
DEFINE FILE 14(1000,40,U,K400)
DEFINE FILE 15(1000,40,U,K400)
CALL DRECCN
CALL DREAD
CALL VELIN
CALL ANHLIN
CALL EXPJIN
READ(NIN,23) N,Q,H,DD,D,ZHL,ZCOST,ZZCOST,ACOST
CALL TLREAD
CALL PKICEI
READ(NIN,25) BCOST,CCOST,DCOST,ECOST,FCOST,GCOST
ARGST=0.0
L=0

```

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58

B. FORTRAN IV PROGRAM LISTING

	READ(NIN,1) NBRANH	59
	WRITE(NOUT,705)	60
	WRITE(NOUT,701)	61
6	L=L+1	62
	SMCST=0.0	63
	IF(L.GT.NBRANH) GO TO 69	64
	READ(NIN,10) INDIC,NPATHS,NPLLP,MONY	65
	IF(INDIC.EQ.0) GO TO 77	66
	IF(INDIC.EQ.1) GO TO 91	67
	IF(INDIC.EQ.2) GO TO 89	68
77	CALL STRFL((NPATHS+1),ZCOST,ZHL,KK)	69
	SMCST=SMCST+ZCOST	70
	GO TO 106	71
91	CALL PLLP(NPATHS,INDIC,ZCOST,ZHL,KK)	72
	SMCST=SMCST+ZCOST	73
	GO TO 106	74
89	CALL PLLP(NPLLP,INDIC,ZCOST,ZHL,KK)	75
	CALL STRFL((NPATHS-NPLLP+1),ZCOST,ZHL,KK)	76
	SMCST=SMCST+ZCOST+ZCOST	77
	GO TO 106	78
106	BRCST=BRCST+SMCST	79
	GO TO 6	80
69	WRITE(NOUT,107) BRCST	81
10	FORMAT(4I10)	82
	CALL WRITEQ(KK)	83
	STOP	84
	END	85

C	SUBROUTINE DREAD	86
C	THIS ROUTINE READS & WRITES INPUT DATA	87
	COMMON/A1/K1,K2,K3	88
	COMMON/A2/RHO,POIS	89
	COMMON/A3/CPI(7)	90
	COMMON /A6/ KK	91
	COMMON/A9/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	92
	COMMON/A15/J10,J11,J12,J13,J14,J15,J16,J17,J18,J19,J20	93
	COMMON/A20/JJ1,JJ2,JJ3,JJ4,JJ5,JJ6,JJ7,JJ8,JJ9	94
	DATA NIN,NDOUT /1,3/	95
	READ(NIN,2) J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	96
	READ(NIN,2) J10,J11,J12,J13,J14,J15,J16,J17,J18,J19,J20	97
	READ(NIN,1) JJ1,JJ2,JJ3,JJ4,JJ5,JJ6,JJ7,JJ8,JJ9	98
	IF(J1.GT.1) WRITE(NDOUT,3)	99
	IF(J2.GT.1) WRITE(NDOUT,3)	100
	IF(J5.GT.1) WRITE(NDOUT,3)	101
	IF(J6.GT.1) WRITE(NDOUT,3)	102
	IF(J3.GT.3) WRITE(NDOUT,3)	103
	IF(J4.GT.3) WRITE(NDOUT,3)	104
	IF(J8.GT.2) WRITE(NDOUT,3)	105
	IF(J9.GT.1) WRITE(NDOUT,3)	106
	IF(J7.GT.3) WRITE(NDOUT,3)	107
	IF(J10.GT.1) WRITE(NDOUT,3)	108
	IF(J11.GT.1) WRITE(NDOUT,3)	109
	IF(J12.GT.1) WRITE(NDOUT,3)	110
	IF(J13.GT.1) WRITE(NDOUT,3)	111
	IF(J14.GT.1) WRITE(NDOUT,3)	112
	IF(J15.GT.1) WRITE(NDOUT,3)	113
	IF(J16.GT.1) WRITE(NDOUT,3)	114
	IF(J17.GT.1) WRITE(NDOUT,3)	115
	IF(J18.GT.1) WRITE(NDOUT,3)	116
	IF(J19.GT.1) WRITE(NDOUT,3)	117
	IF(J20.GT.2) WRITE(NDOUT,3)	118
	WRITE(NDOUT,R026)	119
	IF(J10.EQ.1) WRITE(NDOUT,4) J1,J2,J3,J4,J5,J6,J7,J8,J9,J10,J11,	120
	1J12,J13,J14,J15,J16,J17,J18,J19,J20	121
	WRITE(NDOUT,R027) JJ1,JJ2,JJ3,JJ4,JJ5,JJ6,JJ7,JJ8,JJ9,I1,I2	122
	READ(NIN,5) K1,K2,K3	123
	IF(J11.EQ.1) WRITE(NDOUT,6) K1,K2,K3	124
	READ(NIN,7) RHO,POIS	125
	IF(J12.EQ.1) WRITE(NDOUT,8) RHO,POIS	126
	READ(NIN,9) CPI(1),CPI(2),CPI(3),CPI(4),CPI(5),CPI(6),CPI(7)	127
	IF(J13.EQ.1) WRITE(NDOUT,10) CPI(1),CPI(2),CPI(3),CPI(4),CPI(5),	128
	1CPI(6),CPI(7)	129
	RETURN	130
	1 FORMAT(9I5)	131
	2 FORMAT(11I5)	132
	3 FORMAT(//,' ***** ERROR*** ONE OF THE J VALUES ARE TOO LARGE',//)	133
	4 FORMAT(20I5)	134
	5 FORMAT(3I10)	135
	6 FORMAT(//,' THE INPUT DIAMETER LIMITS ARE',3I10)	136
	7 FORMAT(2F20.7)	137
	8 FORMAT(//,' INPUT DENSITY AND VISCOSITY ARE:',2F20.7)	138
	9 FORMAT(7F10.5)	139
	10 FORMAT(//,' COST PRICE INDICES ARE:',7F15.7)	140
R026	FORMAT(' J1 J2 J3 J4 J5 J6 J7 J8 J9 J10 J11	141
	1J12 J13 J14 J15 J16 J17 J18 J19 J20')	142
R027	FORMAT(' JJ1 JJ2 JJ3 JJ4 JJ5 JJ6 JJ7 JJ8 JJ9 JJ0 I1 I2',	143
	1 /,11I5)	144
	END)	145
		146

C		147
C		148
C		149
C		150
	SUBROUTINE PLLP(INDIC,NODEN,ZCOST,ZHL,KK)	151
	THIS ROUTINE CONTROLS PARALLEL FLOW PATHS	152
	COMMON/A5/ NJ1,NJ2,NJ3,NJ4,NJ5	153
	COMMON/A7/LQ	154
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	155
	COMMON/A15/J10,J11,J12,J13,J14,J15,J16,J17,J18,J19,J20	156
	COMMON/A16/ NODE(13),TCOST(100)	157
	COMMON/A18/ BCOST,CCOST,DCOST,ECOST,FCOST,GCOST	158
	COMMON/A19/ \$2(4),\$1(4),X1(4),X2(4)	159
	COMMON/A20/JJ1,JJ2,JJ3,JJ4,JJ5,JJ6,JJ7,JJ8,JJ9	160
	COMMON/A27/ INSULI	161
	DATA NIN,NOUT /1,3/	162
	J=0	163
	ZZHL=0.	164
	SUM=0.	165
	1 J=J+1	166
	IF(J20.EQ.0) GO TO 1410	167
	IF(J20.EQ.1) GO TO 1411	168
	IF (J20.EQ.2) GO TO 1412	169
1411	READ(NIN,1413) KK,INSULI,ZL,QHEAT,BLOSS	170
	W=QHEAT/30.	171
	DELTA=30.	172
	GO TO 1414	173
1412	READ(NIN,982) KK,INSULI,W,ZL,QHEAT,BLOSS	174
	DELTA=QHEAT/W	175
	GO TO 1414	176
1410	READ(NIN,982) KK,INSULI,W,ZL,BLOSS,DELTA	177
1414	LQ=KK	178
	WRITE(NJ1*KK) W,ZL,BLOSS,DELTA	179
	IF(JJ3.EQ.0) CALL COPTIM(KK,W,ZL,BLOSS,DELTA,ZCOST,ZHL,DD)	180
	IF(JJ3.EQ.1) CALL TEMOP(KK,W,ZL,BLOSS,DELTA,ZCOST,ZHL,DD)	181
	SUM= SUM+ZCOST	182
	IF(ZHL.GE.ZZHL) ZZHL=ZHL	183
	IF(ZHL.LT.ZZHL) ZZHL=ZZHL	184
	IF(J.EQ.INDIC) GO TO 67	185
	IF(J.LT.INDIC) GO TO 1	186
67	ZCOST=SUM	187
	ZHL=ZZHL	188
	RETURN	189
982	FORMAT(2I5,4F15.7)	190
1413	FORMAT(2I5,3F15.7)	191
	END	192

C		193
C		194
	SUBROUTINE STRTFL(NODEN, ZCOST, ZZHL, KK)	195
	THIS ROUTINE CONTROLS SERIES FLOW PATHS	196
	COMMON/A5/ NJ1, NJ2, NJ3, NJ4, NJ5	197
	COMMON/A7/LQ	198
	COMMON/A8/J1, J2, J3, J4, J5, J6, J7, J8, J9, I1, I2	199
	COMMON/A15/J10, J11, J12, J13, J14, J15, J16, J17, J18, J19, J20	200
	COMMON/A16/ NODE(13), TCOST(100)	201
	COMMON/A18/ BCOST, CCOST, DCOST, ECOST, FCOST, GCOST	202
	COMMON/A19/ \$2(4), \$1(4), X1(4), X2(4)	203
	COMMON/A20/JJ1, JJ2, JJ3, JJ4, JJ5, JJ6, JJ7, JJ8, JJ9	204
	COMMON/A27/ INSULI	205
	DATA NIN, NOUT /1, 3/	206
	J=0	207
	SUM=0.0	208
	SUMLOS=0.0	209
	1 J=J+1	210
	IF(J20.EQ.0) GO TO 1410	211
	IF(J20.EQ.1) GO TO 1411	212
	IF (J20.EQ.2) GO TO 1412	213
1411	READ(NIN, 1413) KK, INSULI, ZL, QHEAT, BLOSS	214
	W=QHEAT/30.	215
	DELTA=30.	216
	GO TO 1414	217
1412	READ(NIN, 982) KK, INSULI, W, ZL, QHEAT, BLOSS	218
	DELTA=QHEAT/W	219
	GO TO 1414	220
1410	READ(NIN, 982) KK, INSULI, W, ZL, BLOSS, DELTA	221
1414	LQ=KK	222
	WRITE(NJ1*KK) W, ZL, BLOSS, DELTA	223
	IF(JJ3.EQ.0) CALL COPTIM(KK, W, ZL, BLOSS, DELTA, ZCOST, ZZHL, DD)	224
	IF(JJ3.EQ.1) CALL TEMOP(KK, W, ZL, BLOSS, DELTA, ZCOST, ZZHL, DD)	225
	SUM= SUM+ZCOST	226
	SUMLOS= SUMLOS+ZHL	227
	IF(J.EQ.(NODEN-1)) GO TO 67	228
	IF(J.LT.(NODEN-1)) GO TO 1	229
67	ZCOST=SUM	230
	ZZHL=SUMLOS	231
	RETURN	232
982	FORMAT(2I5, 4F15.7)	233
1413	FORMAT(2I5, 4F15.7)	234
	END	235

C		236
C		237
C		238
	SUBROUTINE COPTIM(KK,W,ZL,BLOSS,DELTA,TCOST,ZHL,DD)	239
C	THIS ROUTINE OPTIMIZES BASED ON INSTALLATION & PUMPING COST	240
	COMMON/A1/K1,K2,K3	241
	COMMON/A2/RHD,POIS	242
	COMMON/A3/CPI(7)	243
	COMMON/A4/MONY	244
	COMMON/A5/ NJ1,NJ2,NJ3,NJ4,NJ5	245
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	246
	COMMON/A9/TPIPE(100)	247
	COMMON/A10/TCNDT(200)	248
	COMMON/A11/TPUMP(100)	249
	COMMON/A12/BASEW,BASEP,BASEF,BASEV,BASED,BASE\$,BASEW\$,BASEP\$	250
	COMMON/A13/HOLCST,HOLFT	251
	COMMON/A14/ VELLIM,NNN	252
	COMMON/A15/J10,J11,J12,J13,J14,J15,J16,J17,J18,J19,J20	253
	COMMON/A16/ NDEE(13),TCOST(100)	254
	COMMON/A18/ RCOST,CCOST,DCOST,ECOST,FCOST,GCOST	255
	COMMON/A19/ \$2(4),\$1(4),X1(4),X2(4)	256
	COMMON /A20/JJ1,JJ2,JJ3,JJ4,JJ5,JJ6,JJ7,JJ8,JJ9	257
	COMMON/A27/ INSULI	258
	DATA NIN,NOUT /1,3/	259
	L=0	260
	LL=-1	261
	M=0	262
	K=K1	263
121	L=L+1	264
100	M=M+1	265
	IF(W.LT.0.) GO TO 1001	266
117	Z=FLOAT(K)/12.	267
	CALL FLOCLOC(W,ZL,D,BLOSS,Q,N,H)	268
	CALL CPUMP(N,Q,D,ACOST)	269
	CALL CPIPE(N,D,ZL,RCOST)	270
	CALL CEXCAV(N,D,ZL,CCOST)	271
	IF(INSULI.EQ.0) DCOST=0.0	272
	IF(INSULI.NE.0) CALL CINSUL(N,D,ZL,DCOST)	273
	CALL CMNHOL(N,ZL,ECOST)	274
	CALL CCNDT(N,D,ZL,FCOST)	275
	CALL PUMCST(H,Q,N,GCOST)	276
	CALL SUPCST(ACOST,RCOST,CCOST,DCOST,ECOST,FCOST,GCOST,D,ZL,Q,N,HCO	277
	IST)	278
	IF(KK.NE.MONY) ACOST=0.0	279
	TDIAM=D*12.+0.5	280
	TCOST(K)= ACOST+RCOST+CCOST+DCOST+ECOST+FCOST+GCOST	281
	IF(LL.EQ.0) GO TO 803	282
	IF(LL.EQ.1) GO TO 804	283
	IF(LL.EQ.2) GO TO 673	284
	IF(M.EQ.1) K=K2	285
	IF(M.EQ.2) K=K3	286
	IF(M.EQ.3) GO TO 581	287
	IF(M.GT.3) GO TO 673	288
	GO TO 100	289
581	KK1=K1	290
	KK2=K2	291
	KK3=K3	292
	GO TO 673	293

```

673 R= FLOAT(K3-K1)/(2.0**L)
    IF(((ABS(TCOST(KK1)-TCOST(KK2))).LT.50.).AND.((ABS(TCOST(KK2)-TCO
1ST(KK3))).LT.50.)) GO TO 578
    IF((TCOST(KK1).GT.TCOST(KK2)).AND.(TCOST(KK2).GT.TCOST(KK3)))
1 CALL WRONG(KK1,KK2,KK3,R,KK5,KK6,KK7,6807)
    IF((TCOST(KK3).GT.TCOST(KK2)).AND.(TCOST(KK2).GT.TCOST(KK1)))
1 CALL WRONG(KK3,KK2,KK1,R,KK5,KK6,KK7,6807)
    IF((TCOST(KK3).GT.TCOST(KK2)).AND.(TCOST(KK1).GT.TCOST(KK2)))
1CALL STANDD(KK1,KK2,KK3,R,KK5,KK6,KK7,6802)
    WRITE(NOUT,801)
801 FORMAT(/, ' *****ERROR*** THE COST OF THE CENTER POINT IS GREATER
1 THAT THE LIMIT POINTS. THIS INDICATES A DISCONTINUOUS COST FUNCT
2 ION. ',/, ' PERUN PROBLEM WITH LIMITS SET BY 50% DIFFERENT FROM
3THIS PROBLEM')
    GO TO 69
802 K=KK5
    LL=0
    GO TO 100
803 K=KK6
    LL=1
    GO TO 100
804 K=KK7
    LL=2
    IF((IABS(KK5-KK6)).LT.2) KK2=KK6
    IF((IABS(KK5-KK6)).LT.2) GO TO 679
    IF((IABS(KK5-KK7)).LT.2) KK2=KK6
    IF((IABS(KK6-KK7)).LT.2) GO TO 678
    KK1=KK5
    KK2=KK6
    KK3=KK7
    GO TO 121
679 ZCOST=TCOST(KK2)
    DD=KK2
    ZHL=H
    GO TO 1003
807 DD 808 J=KK5,KK7
    Q=FLOAT(J)/12.
    CALL FLOCLC(W,ZL,D,BLOSS,Q,N,H)
    CALL CPIJMP(N,Q,D,ACOST)
    CALL CPIPE(N,D,ZL,BCOST)
    CALL CEXCAV(N,D,ZL,CCOST)
    IF(INSULI.EQ.0) DCOST=0.0
    IF(INSULI.NE.0) CALL CINSUL(N,D,ZL,DCOST)
    CALL CMNHGL(N,ZL,ECOST)
    CALL CCNDGT(N,D,ZL,FCOST)
    CALL PUMCST(H,Q,N,GCOST)
    CALL SUPCST(ACOST,BCOST,CCOST,DCOST,ECOST,FCOST,GCOST,D,ZL,Q,N,HCO
1ST)
    IF(KK.NE.MQNY) ACOST=0.0
    TCOST(J)= ACOST+BCOST+CCOST+DCOST+ECOST+FCOST+GCOST
    IF(J.EQ.KK5) GO TO 808
    IF(J.EQ.(KK5+1)) JJ=KK5
    IF(TCOST(J).LT.TCOST(JJ)) SAVE=TCOST(J)
    IF(TCOST(JJ).LE.TCOST(J)) SAVE =TCOST(JJ)
    IF(TCOST(J).LT.TCOST(JJ)) JJ=J
808 CONTINUE
    DD=JJ
    Q=JJ/12.

```

294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351

1003	CALL FLOCLC(W,ZL,(DD/12.),BLOSS,Q,N,H)	352
	CALL CPUMP(N,Q,D,ACOST)	353
	CALL CPIPE(N,D,ZL,BCOST)	354
	CALL CEXCAV(N,D,ZL,CCOST)	355
	IF(INSULI.EQ.0) DCOST=0.0	356
	IF(INSULI.NE.0) CALL CINSUL(N,D,ZL,DCOST)	357
	CALL CMNHOL(N,ZL,ECOST)	358
	CALL CCOND(N,D,ZL,FCOST)	359
	CALL PUMCST(H,Q,N,GCOST)	360
	CALL SUPCST(ACOST,BCOST,CCOST,DCOST,ECOST,FCOST,GCOST,D,ZL,Q,N,HCO	361
	1ST)	362
	IF(KK.NE.MONY) ACOST=0.0	363
	PRINCP=ACOST+BCOST+CCOST+DCOST+ECOST+FCOST+HCOST	364
	ZCOST=PRINCP+GCOST	365
	CALL HEAT\$(W,DELTA,\$SOLD)	366
	IF(DELTA.LT.0) GO TO 707	367
	GO TO 708	368
707	RETINV=0.0	369
708	WRITE(NJ4,*) KK) PRINCP,\$SOLD,ACOST,BCOST,CCOST,DCOST,ECOST,FCOST,GC	370
	1ST,HCOST	371
	DD=JJ	372
	ZHL=H	373
	IDIAM=JJ	374
	WRITE(NOUT,712) KK,N,IDIAM,ACOST,BCOST,CCOST,DCOST,ECOST,FCOST,GC	375
	2ST	376
	GO TO 1002	377
1001	ZCOST=0.	378
	ZHL=0.	379
	DD=0.	380
1002	RETURN	381
712	FORMAT(//,3I5,7F15.2)	382
69	STOP	383
	END	384

C		385
		386
		387
	SUBROUTINE TEMOP(KK,W,ZL,BLOSS,DELTA,ZCOST,ZHL,DD)	388
	THIS ROUTINE OPTIMIZES BASED ON MAXIMUM PROFIT	389
	COMMON /A1/K1,K2,K3	390
	COMMON/A4/MQNY	391
	COMMON/A5/ NJ1,NJ2,NJ3,NJ4,NJ5	392
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	393
	COMMON/A12/BASEW,BASEP,BASEE,BASEV,BASED,BASE\$,BASEW\$,BASEP\$	394
	COMMON /A20/JJ1,JJ2,JJ3,JJ4,JJ5,JJ6,JJ7,JJ8,JJ9	395
	COMMON/A22/CTRLD,BASEH\$	396
	COMMON/A23/YEARS,SALVAS\$,FRINTR,T1,T2,T3,T4,T5,T6	397
	COMMON/A27/ INSULI	398
	COMMON/A28/U14,U15,U16,U17,U18,U19,U20,U21,U22,U23	399
	DATA NIN,NOUT/1,3/	400
	IF(W.LT.0) GO TO 146	401
	CALL HEAT\$(W,DELTA,\$SOLD)	402
	DO 29 LM=K1,K3	403
	CALL FLOCLOC(W,ZL,(FLOAT(LM)/12.),BLOSS,Q,N,H)	404
	DIA=FLOAT(LM)/12.	405
	CALL CPIPE(N,DIA,ZL,BCOST)	406
	CALL CEXCAV(N,DIA,ZL,CCOST)	407
	CALL PUMCST(H,Q,N,GCOST)	408
	PRINCP=(BCOST+CCOST)/YEARS	409
	CALL FINAN(PRINCP,FIN\$)	410
	CALL DANDM(PRINCP,RETINV,DANDM\$)	411
	GGCOST=PRINCP+DANDM\$+FIN\$+GCOST	412
	CALL HEAT\$(W,DELTA,\$SOLD)	413
	IF(LM.EQ.K1) GO TO 27	414
	IF(GGCOST.LT.SAVE) GO TO 27	415
	GO TO 29	416
27	SAVE=GGCOST	417
28	ISAVE=LM	418
29	CONTINUE	419
	DIA=FLOAT(ISAVE)/12.	420
	D=DIA	421
	CALL FLOCLOC(W,ZL,DIA,BLOSS,Q,N,H)	422
	CALL PUMCST(H,Q,N,GCOST)	423
	GO TO 118	424
116	RETINV=0.0	425
118	CALL CMNHOL(N,ZL,ECOST)	426
	CALL CPIJMP(N,D,DIA,ACOST)	427
	CALL CPIPE(N,DIA,ZL,BCOST)	428
	CALL CEXCAV(N,DIA,ZL,CCOST)	429
	IF(INSULI.EQ.0) DCOST=0.0	430
	IF(INSULI.NE.0) CALL CINSUL(N,D,ZL,DCOST)	431
	CALL CCOST(N,DIA,ZL,FCOST)	432
	CALL SUPCST(ACOST,BCOST,CCOST,DCOST,ECOST,FCOST,GCOST,D,ZL,Q,N,HCO	433
	1ST)	434
	IF(KK.NE.MQNY) ACOST=0.0	435
	PRINCP=ACOST+BCOST+CCOST+DCOST+ECOST+FCOST+HCOST	436
	ZCOST=PRINCP+GCOST	437
	IDIAM=ISAVE	438
	WRITE(NOUT,712) KK,N,IDIAM,ACOST,BCOST,CCOST,DCOST,ECOST,FCOST,GC	439
	1ST	440
708	WRITE(NJ4*KK) PRINCP,\$SOLD,ACOST,BCOST,CCOST,DCOST,ECOST,FCOST,GC	441
	1ST,HCOST	442

	7HL=H	443
	DD=01A	444
	RETURN	445
146	ZCONST=0.	446
	7HL=0.	447
	DD=0.	448
	RETURN	449
712	FORMAT(//,3I5,7F15.2)	450
	END	451
C		452
C		453
C		454
C		455
	SUBROUTINE VELIN	456
	THIS ROUTINE INPUTS VELOCITY & # OF PIPES	457
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	458
	COMMON/A14/ VELLIM,NNN	459
	COMMON/A15/J10,J11,J12,J13,J14,J15,J16,J17,J18,J19,J20	460
	COMMON/A20/JJ1,JJ2,JJ3,JJ4,JJ5,JJ6,JJ7,JJ8,JJ9	461
	DATA NIN,NOUT /1,3/	462
	IF(J1.EQ.0) VELLIM=10.	463
	IF(J1.GT.0) READ(NIN,10) VELLIM	464
	IF(J19.EQ.1) WRITE(NOUT,13) VELLIM	465
	IF(JJ1.EQ.1) READ(NIN,11) NNN	466
	IF(JJ1.EQ.0) NNN=0	467
	NJ=NNN+1	468
	IF(JJ2.EQ.1) WRITE(NOUT,18) NJ	469
	RETURN	470
10	FORMAT(F20.7)	471
11	FORMAT(I5)	472
13	FORMAT(/,' LIMITING VELOCITY IS : ', F20.7)	473
18	FORMAT(//, ' THE MIN # OF PIPES IS : ',I5)	474
	END	475

C		476
C		477
C		478
	SUBROUTINE ANHLIN	479
	THIS ROUTINE INPUTS MANHOLE DATA	480
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	481
	COMMON/A13/HQLCST,HQFLT	482
	COMMON/A15/ J10,J11,J12,J13,J14,J15,J16,J17,J18,J19,J20	483
	DATA NIN,NOUJ /1,3/	484
	IF(J7.EQ.0) RETURN	485
	IF(J7.EQ.1) GO TO 1	486
	IF(J7.EQ.2) GO TO 3	487
	IF(J7.EQ.3) GO TO 5	488
	1 READ(NIN,10) HQLCST	489
	HQFLT=1000.	490
	GO TO 19	491
	3 READ(NIN,10) HQFLT	492
	HQLCST=38.	493
	GO TO 19	494
	5 READ(NIN,11) HQLCST,HQFLT	495
	19 IF(J18.EQ.1) WRITE(NOUI,17) HQLCST,HQFLT	496
	RETURN	497
	10 FORMAT(F20.7)	498
	11 FORMAT(2F20.7)	499
	17 FORMAT(/,' MANHOLE COST IS : \$ ',F20.7,' A MANHOLE IS INSTALLED	500
	EVERY ',F15.7,'FEET')	501
	END	502

C		503
C	SUBROUTINE TREAD	504
	THIS ROUTINE INPUTS TABLE DATA	505
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	506
	COMMON/A9/TPIPE(100)	507
	COMMON/A10/TCNDT(200)	508
	COMMON/A11/TPUMP(100)	509
	COMMON/A15/J10,J11,J12,J13,J14,J15,J16,J17,J18,J19,J20	510
	DATA NIN,NOUT /1,3/	511
	IF(J3.EQ.2) GO TO 1	512
2	IF(J4.EQ.2) GO TO 3	513
4	IF(J8.EQ.1) GO TO 5	514
	RETURN	515
1	IF(J16.EQ.1) WRITE(NOUT,44)	516
	DO 43 J=1,100	517
	READ(NIN,10) N,\$PUMP	518
	IF(J16.EQ.1) WRITE(NOUT,45) N,\$PUMP	519
	TPUMP(N)=\$PUMP	520
43	CONTINUE	521
	GO TO 2	522
3	IF(J14.EQ.1) WRITE(NOUT,46)	523
	DO 20 J=1,100	524
	READ(NIN,10) N,\$PIPE	525
	IF(J14.EQ.1) WRITE(NOUT,45) N,\$PIPE	526
	TPIPE(N)=\$PIPE	527
20	CONTINUE	528
	GO TO 4	529
5	IF(J15.EQ.1) WRITE(NOUT,47)	530
	DO 30 J=1,50	531
	READ(NIN,10) N,\$CNDUT	532
	IF(J15.EQ.1) WRITE(NOUT,45) N,\$CNDUT	533
	TCNDT(N)=\$CNDUT	534
30	CONTINUE	535
	RETURN	536
10	FORMAT(15,F20.7)	537
44	FORMAT('1',' PUMP COST DATA')	538
45	FORMAT(15,F20.7)	539
46	FORMAT('1',' PIPE COST DATA')	540
47	FORMAT('1',' CONDUIT COST DATA')	541
	END	542
		543

C
C
C

```
SUBROUTINE PRICE1
THIS ROUTINE INPUTS COST DATA
COMMON/AR/J1,J2,J3,J4,J5,J6,J7,J8,J9,11,12
COMMON/A12/BASEW,BASEP,BASEF,BASEV,BASED,BASE$,BASEW$,BASEP$
COMMON/A15/J10,J11,J12,J13,J14,J15,J16,J17,J18,J19,J20
DATA NIN,NOUT /1,3/
BASEW= 0.0
BASEP= 0.0
BASEF= 0.0
BASEV= 0.0
BASED= 0.0
BASE$= 0.0
BASEW$= 0.0
BASEP$= 0.0
IF(J3.EQ.1) GO TO 1
2 IF(J4.EQ.1) GO TO 3
4 IF(J5.EQ.1) GO TO 5
6 IF(J6.EQ.1) GO TO 7
8 IF(J9.EQ.1) GO TO 9
12 IF(J17.EQ.1) WRITE(NOUT,49) BASEW,BASEW$,BASEP,BASEP$,BASEF
1, BASEV, BASED, BASE$
RETURN
1 READ(NIN,11) BASEW,BASEW$
GO TO 2
3 READ(NIN,11) BASEP,BASEP$
GO TO 4
5 READ(NIN,10) BASEF
GO TO 5
7 READ(NIN,10) BASEV
GO TO 8
9 READ(NIN,11) BASED,BASE$
IF(J17.EQ.1) WRITE(NOUT,49) BASEW,BASEW$,BASEP,BASEP$,BASEF,
1 BASEV, BASED, BASE$
RETURN
10 FORMAT(F20.7)
11 FORMAT(2F20.7)
49 FORMAT(/,' INPUT DATA BASE COSTS',/, ' BASE FLOW RATE PUMP COS
1T BASE PIPE SIZE PIPE COST EXCAVATION INSULATION BASE DAYS $
2$/KWH',/,9F12.3,/)
END
```

544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586

		587
		588
		589
	SUBROUTINE FLOCLO(W,ZL,D,BLOSS,D,N,H)	590
	THIS ROUTINE CALCULATES HEAD LOSS AND # OF PIPES	591
	COMMON/A1/K1,K2,K3	592
	COMMON/A2/RHO,P1IS	593
	COMMON/A5/ NJ1,NJ2,NJ3,NJ4,NJ5	594
	COMMON /A6/ KK	595
	COMMON/A7/LQ	596
	COMMON/AP/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	597
	COMMON/A14/ VFLLIM,NNN	598
	COMMON/A10/ S2(4),S1(4),X1(4),X2(4)	599
	COMMON/A20/JJ1,JJ2,JJ3,JJ4,JJ5,JJ6,JJ7,JJ8,JJ9	600
	DATA NIN,NOOUT/1,3/	601
	GC=32.17	602
	IF(JJ1.EQ.0) N=0	603
	IF(JJ1.GT.0) N=NNN	604
20	N=N+1	605
	WT= W/ FLOAT(N)	606
	A= 3.14159*0**2/4.	607
	V= WT/(RHO*A*3600.)	608
	IF(V.GT.VFLLIM) GO TO 20	609
	RF= D*V*RHO/P1IS	610
	Q=A*V	611
	IF(RF.LT.2100.) F=16./RF	612
	IF((RF.GT.2100.).AND.(RF.LT.1.E5)) F=0.186-.0026*ALOG10(RF)	613
	IF(RF.GE.1.E5) F=.0025	614
	HL=4.0*F*ZL*V**2/(2.0*GC*D)	615
	IF(BLOSS.LT.0.) GO TO 9515	616
	IF(J2.EQ.1) GO TO 35	617
	BLOSS= 0.4*HL	618
	GO TO 35	619
9515	BLOSS=0.0	620
35	H=HL+ BLOSS	621
	WRITE(NJ2,'LQ) N,Q,H	622
	RETURN	623
	END	624

C		625
C		626
	SUBROUTINE CPUMP(NPUMP,Q,D,ACOST)	627
C	THIS ROUTINE CALCULATES PUMP COST	628
	COMMON/A3/CPI(7)	629
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	630
	COMMON/A11/TPUMP(100)	631
	COMMON/A12/BASEW,BASEP,BASEE,BASEV,BASED,BASE\$,BASEW\$,BASEP\$	632
	COMMON/A19/\$2(4),\$1(4),X1(4),X2(4)	633
	DATA NIN,NOUT/1,3/	634
	IF(J3.EQ.0) GO TO 1	635
	IF(J3.EQ.1) GO TO 2	636
	IF(J3.EQ.2) GO TO 3	637
	IF(J3.EQ.3) GO TO 4	638
C	TOTAL INSTALLED COST OF THE PUMPS	639
	1 WBASE= 400.0/(60.0*7.48)	640
	RATIO = Q/WBASE	641
	ACOST= CPI(1)*RATIO**0.98*1185.0*NPUMP	642
	GO TO 5	643
	2 RATIO= Q/BASEW	644
	ACOST= CPI(1)*RATIO**0.98*BASEW\$*NPUMP	645
	GO TO 5	646
	3 NO=D*12.+ .5	647
	ACOST=CPI(1)*TPUMP(NO)*NPUMP	648
	GO TO 5	649
	4 DIA=12.*D	650
	CALL CPOLF(1,DIA,\$\$\$)	651
	ACOST=CPI(1)*\$\$\$*NPUMP	652
	GO TO 5	653
	5 RETURN	654
	END	655
		656

CCCCC
C

```

SUBROUTINE CPIPE(NPIPE,D,ZLENTH,BCOST)
THIS ROUTINE CALCULATES PIPE COST
COMMON/A3/CPI(7)
COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2
COMMON/A9/TPIPE(100)
COMMON/A12/BASEW,BASEE,BASEV,BASED,BASE$,BASEW$,BASEP$
COMMON/A19/ $2(4),$1(4),X1(4),X2(4)
DATA NIN,NOUT/1,3/
IF(J4.EQ.0) GO TO 1
IF(J4.EQ.1) GO TO 2
IF(J4.EQ.2) GO TO 3
IF(J4.EQ.3) GO TO 4
1  RATIO = 1.2*D
   BCOST= NPIPE*RATIO**1.15*ZLENTH*CPI(2)*30.
   GO TO 5
2  RATIO = 12.0*D/BASEP
   BCOST=NPIPE*RATIO**1.15*ZLENTH*CPI(2)*BASEP$
   GO TO 5
3  NO=D*12.+5
   BCOST= NPIPE*ZLENTH*CPI(2)*TPIPE(NO)
   GO TO 5
4  DIA=12.*D
   CALL CPOLE(2,DIA,$$$)
   BCOST= NPIPE*ZLENTH*CPI(2)*$$$
   GO TO 5
5  RETURN
   END
```

657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689

C		690
C		691
C		692
C	SUBROUTINE CFXCAVIN(PIPE,D,ZLENTN,CCOST)	693
	THIS ROUTINE CALCULATES EXCAVATION COST	694
	COMMON/A3/CPI(7)	695
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	696
	COMMON/A12/BASEW,BASEP,BASEE,BASEV,BASED,BASE\$,BASEW\$,BASEP\$	697
	DATA NIN,NOUT/1,3/	698
	IF(J5.EQ.0) GO TO 1	699
	IF(J5.EQ.1) GO TO 2	700
1	WIDTH= 2.0+NPIPE*D	701
	DEPTH = 3.0+D	702
	VOL= ZLENTN*WIDTH*DEPTH	703
	CCOST= CPI(3)*VOL*2.0	704
	GO TO 5	705
2	WIDTH= 2.0+ NPIPE*D	706
	DEPTH= 3.0+D	707
	VOL= ZLENTN*WIDTH*DEPTH	708
	CCOST= CPI(3)*VOL*BASEE	709
	GO TO 5	710
5	RETURN	711
	END	712

C		713
C		714
C		715
C	SUBROUTINE CINSUL(NPIPE,D,ZLENTN,DCOST)	716
	THIS ROUTINE CALCULATES INSULATION COST	717
	COMMON/A3/CPI(7)	718
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	719
	COMMON/A12/BASEW,BASEP,BASEE,BASEV,BASED,BASE\$,BASEW\$,BASEP\$	720
	DATA NIN,NOUT/1,3/	721
	IF(J6.EQ.0) GO TO 1	722
	IF(J6.EQ.1) GO TO 2	723
1	DCOST= CPI(4)*NPIPE*ZLENTN*D	724
	GO TO 5	725
2	DCOST=CPI(4)*NPIPE*ZLENTN*BASEV*D	726
	GO TO 5	727
5	RETURN	728
	END	729

C		730
C		731
C		732
C	SUBROUTINE CMNHOL(NPIPE,ZLENT,ECOST)	733
	THIS ROUTINE CALCULATES MANHOLE COSTS	734
	COMMON/A3/CPI(7)	735
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	736
	COMMON/A13/HOLCST,HOLF	737
	DATA NIN,NOUT/1,3/	738
	IF(J7.EQ.0) GO TO 1	739
	IF(J7.EQ.1) GO TO 2	740
	IF(J7.EQ.2) GO TO 3	741
	IF(J7.EQ.3) GO TO 4	742
1	DEPTH=9.+(NPIPE-2)*0.5	743
	ECOST=CPI(5)*ZLENT*DEPTH*38./1000.	744
	GO TO 5	745
2	DEPTH=9.+(NPIPE-2)*0.5	746
	ECOST=CPI(5)*ZLENT*DEPTH*HOLCST/HOLF	747
	GO TO 5	748
3	DEPTH=9.+(NPIPE-2)*0.5	749
	ECOST=CPI(5)*ZLENT*DEPTH*HOLCST/HOLF	750
	GO TO 5	751
4	DEPTH=9.+(NPIPE-2)*0.5	752
	ECOST=CPI(5)*ZLENT*DEPTH*HOLCST/HOLF	753
	GO TO 5	754
5	RETURN	755
	END	756

C		757
C		758
C		759
C	SUBROUTINE CONNDT(NPIPE,D,ZLENT,ECOST)	760
	THIS ROUTINE CALCULATES CONDUIT COST	761
	COMMON/A3/CPI(7)	762
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	763
	COMMON/A10/TCNDT(200)	764
	COMMON/A19/ \$2(4),\$1(4),X1(4),X2(4)	765
	DATA NIN,NOUT/1,3/	766
	IF(J8.EQ.0) GO TO 1	767
	IF(J8.EQ.1) GO TO 2	768
	IF(J8.EQ.2) GO TO 4	769
1	DIA=2.0*D+(NPIPE-2)*D/2.	770
	RATIO=DIA/3.	771
	ECOST=CPI(6)*RATIO**0.6*ZLENT*14.	772
	GO TO 5	773
2	NO=(12.*D+2.)/4.	774
	NNO=4*NO	775
	IF(NNO.EQ.0) NNO=4	776
	ECOST=CPI(6)*ZLENT*TCNDT(NNO)	777
	GO TO 5	778
4	DIA=(2.0*D+(NPIPE-2)*D/2.0)*12.	779
	CALL CPDLE(3,DIA,\$\$\$)	780
	ECOST=CPI(6)*ZLENT*\$\$\$	781
	GO TO 5	782
5	RETURN	783
	END	784

C		785
C		786
C	SUBROUTINE PUMCST(DELTA P,Q,NPIPE,GCOST)	787
	THIS ROUTINE CALCULATES PUMPING POWER COST	788
	COMMON/A2/RHO,POIS	789
	COMMON/A3/CPI(7)	790
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	791
	COMMON/A12/BASEW,BASEP,BASEE,BASEV,BASED,BASE\$,BASEW\$,BASEP\$	792
	DATA NIN,NOUT/I,3/	793
	HP=DELTA P*Q/(550.0*0.4)	794
	ZKW=HP/0.74548	795
	IF(J9.EQ.0) GO TO 1	796
	IF(J9.EQ.1) GO TO 2	797
1	HRS=300.0*24.	798
	WTHRS=ZKW*HRS	799
	TTLKWH=NPIPE*WTHRS	800
	GCOST=0.010*CPI(7)*TTLKWH	801
	GO TO 24	802
2	HRS=BASED*24.	803
	WTHRS=ZKW*HRS	804
	TTLKWH=NPIPE*WTHRS	805
	GCOST=BASE\$*CPI(7)*TTLKWH	806
	GO TO 24	807
24	RETURN	808
	END	809
C		810
	SUBROUTINE CPOLE(M,VARI,\$\$\$)	811
	COMMON/A19/\$2(4),\$1(4),X1(4),X2(4)	812
	EXPON=(ALOG10(\$2(M))-ALOG10(\$1(M)))/ALOG10(X2(M)/X1(M))	813
	\$\$\$=\$1(M)*(VARI/X1(M))**EXPON	814
	RETURN	815
	END	816
		817

SUBROUTINE EXPDIN	818
COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	819
COMMON/A19/ \$2(4),\$1(4),X1(4),X2(4)	820
DATA NIN,NOUT/1,3/	821
IF(J3.EQ.3) GO TO 1	822
2 IF(J4.EQ.3) GO TO 3	823
4 IF (J8.EQ.2) GO TO 5	824
RETURN	825
1 READ(NIN,8) X1(1),\$1(1),X2(1),\$2(1)	826
GO TO 2	827
3 READ(NIN,8) X1(2),\$1(2),X2(2),\$2(2)	828
GO TO 4	829
5 READ(NIN,8) X1(3),\$1(3),X2(3),\$2(3)	830
RETURN	831
8 FORMAT(4F20.7)	832
END	833

C		834
C		835
C		836
	SUBROUTINE WRONG(KK1, KK2, KK3, R, KK5, KK6, KK7, *)	837
	THIS ROUTINE CONTROLS WHEN CURVE ORIENTATION IS WRONG	838
	COMMON/A1/K1, K2, K3	839
	IF(KK1.GT.KK3) GO TO 46	840
	IF(KK1.LE.KK3) GO TO 47	841
46	KK5=KK3	842
	K01=KK3-R/2.5	843
	IF(K01.GT.K1) KK5=K01	844
	KK6=0	845
	KK7=KK2	846
	RETURN 1	847
47	KK5=KK2	848
	KK6=0	849
	KK7=KK2	850
	K01=KK2+P/2.	851
	IF(K01.LT.K3) KK7=K01	852
	RETURN 1	853
	END	854

C		855
C		856
C		857
C	SUBROUTINE STANDD(KK1, KK2, KK3, R, KK5, KK6, KK7, *)	858
C	THIS ROUTINE CONTROLS WHEN CURVE ORIENTATION IS RIGHT	859
	KK5=KK2 - IFIX(R)/2	860
	KK6=KK2	861
	KK7=KK2 + IFIX(R)/2	862
	RETURN 1	863
	END	864
C		865
C		866
C		867
	SUBROUTINE HEAT\$(W, DELTA, \$SOLD)	868
	COMMON/A20/JJ1, JJ2, JJ3, JJ4, JJ5, JJ6, JJ7, JJ8, JJ9	869
	COMMON/A22/FCTRLD, BASEH\$	870
	RETINV=\$SOLD-GCOST	871
	IF(W.LT.0.) \$SOLD=0.	872
	IF(W.LT.0.) GO TO 5	873
	IF(JJ4.EQ.1) GO TO 1	874
	IF(JJ4.EQ.2) GO TO 2	875
	1 \$SOLD=W*FCTRLD*DELTA*.23/100000.	876
	GO TO 5	877
	2 \$SOLD=W*DELTA*FCTRLD*BASEH\$/1000000.	878
	5 RETURN	879
	END	880
C		881
C		882
C	SUBROUTINE DRECON	883
	THIS ROUTINE READS ECONOMIC DATA	884
	COMMON/A5/ NJ1, NJ2, NJ3, NJ4, NJ5	885
	COMMON /A6/ KK	886
	COMMON/A22/FCTRLD, BASEH\$	887
	COMMON/A23/YEARS, SALVA\$, FRINTR, T1, T2, T3, T4, T5, T6	888
	COMMON/A24/ T7, T8, T9, T10, T11, T12, T13, T14, T15, T16, T17, T18	889
	COMMON/A25/U1, U2, U3, U4, U5, U6, U7, U8, U9, U10, U11, U12, U13	890
	COMMON/A2R/U14, U15, U16, U17, U18, U19, U20, U21, U22, U23	891
	DATA NIN, NOUT/1, 3/	892
	READ(NIN, 1) FCTRLD, BASEH\$, YEARS, SALVA\$, FRINTR	893
	READ(NIN, 1) T1, T2, T3, T4, T5	894
	READ(NIN, 1) T6, T7, T8, T9, T10	895
	READ(NIN, 1) T11, T12, T13, T14, T15	896
	READ(NIN, 1) T16, T17, T18, U1, U2	897
	READ(NIN, 1) U3, U4, U5, U6, U7	898
	READ(NIN, 1) U8, U9, U10, U11, U12	899
	READ(NIN, 2) U13	900
	READ(NIN, 1) U14, U15, U16, U17, U18	901
	READ(NIN, 1) U19, U20, U21, U22, U23	902
	RETURN	903
	1 FORMAT(5F15.5)	904
	2 FORMAT(F15.5)	905
	3 FORMAT(4F15.5)	906
	END	907

C
C
C

```
SUBROUTINE SUPCST(ACOST,RCOST,CCOST,DCOST,ECOST,FCOST,GCOST,D,ZL,  
IQ,N,HCOST)  
COMMON/A25/U1,U2,U3,U4,U5,U6,U7,U8,U9,U10,U11,U12,U13  
HCOST=U1*ACOST+U2*RCOST+U3*CCOST+U4*DCOST+U5*ECOST+U6*FCOST  
+U7*GCOST+U9*D+U13+U10*ZL+U11*Q+U8+U12*N  
RETURN  
END
```

908
909
910
911
912
913
914
915
916
917

C
C

```
SUBROUTINE DEPREC(M,PRINCP,DEPRE$)  
COMMON/A20/JJ1, JJ2, JJ3, JJ4, JJ5, JJ6, JJ7, JJ8, JJ9  
COMMON/A22/FCTRLD, BASEH$  
COMMON/A23/YEARS, SALVA$, FRINTR, T1, T2, T3, T4, T5, T6  
I=0  
IF(JJ5.EQ.0) GO TO 1  
IF(JJ5.EQ.1) GO TO 2  
IF(JJ5.EQ.2) GO TO 3  
IF(JJ5.EQ.3) GO TO 4  
1 DEPRE$=(PRINCP*(1.-SALVA$))/YEARS  
GO TO 5  
2 K=IFIX(YEARS)  
DO 7 J=1,K  
7 I=I+J  
DEPRE$=(2.0*(YEARS-FLOAT(M)+1.)*PRINCP*(1.-SALVA$))/(YEARS*(YEARS+  
1.))  
GO TO 5  
3 DEPRE$=(PRINCP*(1.-SALVA$)*FRINTR)/((1.+FRINTR)**M-1.)  
GO TO 5  
4 IF(M.EQ.1) DEPRE$=PRINCP*2.0*(1./YEARS)  
IF(M.EQ.1) GO TO 5  
FR=2.0*(1./YEARS)  
VA=PRINCP*(1.-SALVA$)*(1.-FR)**(M-1)  
DEPRE$=VA*FR  
5 RETURN  
END
```

918
919
920
921
922
923
924
925
926
927
928
929
930
931
932
933
934
935
936
937
938
939
940
941
942
943
944
945

```

SUBROUTINE QANDM(PRINCP,RETINV,QANDM$)
COMMON/A24/ T7,T8,T9,T10,T11,T12,T13,T14,T15,T16,T17,T18
QANDM$=T7*PRINCP+T8*RETINV+T9
RETURN
END

```

946
947
948
949
950

```

SUBROUTINE SUPPCS(PRINCP,RETINV,QANDM$,FIN$,DFPRE$,SUPP$)
COMMON/A23/YEARS,SALVA$,FRINTR,T1,T2,T3,T4,T5,T6
SUPP$=PRINCP*T1+RETINV*T2+QANDM$*T3+FIN$*T4+DFPRE$*T5+T6
RETURN
END

```

951
952
953
954
955
956
957

```

SUBROUTINE FINAN(PRINCP,FIN$)
COMMON/A24/ T7,T8,T9,T10,T11,T12,T13,T14,T15,T16,T17,T18
FIN$=T10*PRINCP+T11
RETURN
END

```

958
959
960
961
962
963
964
965
966

```

SUBROUTINE RTOWAY(KK,RTWAY$)
COMMON/A5/ NJ1,NJ2,NJ3,NJ4,NJ5
COMMON/A28/U14,U15,U16,U17,U18,U19,U20,U21,U22,U23
ZLT=0.
DO 1 J=1,KK
READ(NJ1,J) W,ZL,BLOSS,DELTA
IF(W.LT.0.) GO TO 1
ZLT=ZLT+ZL
1 CONTINUE
RTWAY$=(ZLT-U14)*U15 +U18
RETURN
END

```

967
968
969
970
971
972
973
974
975
976
977
978
979
980
981

	SUBROUTINE ADJUST(XX1,XX2)	982
	THIS ROUTINE COMPUTES THE ADJUSTMENTS TO BE APPLIED	983
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	984
	COMMON/A28/U14,U15,U16,U17,U18,U19,U20,U21,U22,U23	985
	IF(I2.EQ.0) GO TO 1	986
	IF(I2.EQ.1) GO TO 2	987
1	IF(I1.EQ.0) GO TO 3	988
	IF(I1.EQ.1) GO TO 4	989
	IF(I1.EQ.2) GO TO 5	990
3	XX1=U21*15.0+U23	991
	ZL=5280.	992
	W=500.0*U21	993
	BLOSS=0.0	994
	D=4.	995
	CALL FLOCLC(W,ZL,D,BLOSS,Q,N,H)	996
	CALL PUMCST(H,Q,N,GLCOST)	997
	XX2=GLCOST/2.	998
	GO TO 6	999
4	XX1=U21*20.0*0.5+U23	1000
5	ZL=5280.	1001
	W=500.0*U21	1002
	BLOSS=0.	1003
	D=4.	1004
	CALL FLOCLC(W,ZL,D,BLOSS,Q,N,H)	1005
	CALL PUMCST(H,Q,N,GLCOST)	1006
	XX2=GLCOST	1007
	IF(I1.EQ.1) GO TO 6	1008
	A=U21*7.3	1009
	V=5.0*A/1.5	1010
	XX1=V*2.0/9.0+U21*7.5+A*0.25	1011
	GO TO 6	1012
2	XX1=(1.-U22)*U19+U23	1013
	XX2=(1.-U22)*U20	1014
6	RETURN	1015
	END	1016

	SUBROUTINE WRITED(KK)	1017
C	THIS IS THE OUTPUT AND ECONOMICS CONTROL ROUTINE	1018
	COMMON/A1/K1,K2,K3	1019
	COMMON/A2/RHO,POIS	1020
	COMMON/A3/CPI(7)	1021
	COMMON/A4/MONY	1022
	COMMON/A5/ NJ1,NJ2,NJ3,NJ4,NJ5	1023
	COMMON/A8/J1,J2,J3,J4,J5,J6,J7,J8,J9,I1,I2	1024
	COMMON/A9/TPIPE(100)	1025
	COMMON/A10/TCNOT(200)	1026
	COMMON/A11/TPUMP(100)	1027
	COMMON/A12/BASEW,BASEP,BASEE,BASEV,BASED,BASE\$,BASEW\$,BASEP\$	1028
	COMMON/A13/HOLCST,HOLFT	1029
	COMMON/A14/ VELLIM,NNN	1030
	COMMON/A16/ NODE(13),TCOST(100)	1031
	COMMON/A17/ N,Q,H,DD,D,ZL,ZCOST,ZZCOST,ACOST	1032
	COMMON/A18/ BCOST,CCOST,DCOST,FCOST,GCOST	1033
	COMMON/A20/JJ1,JJ2,JJ3,JJ4,JJ5,JJ6,JJ7,JJ8,JJ9	1034
	COMMON/A22/FCTRLD,BASEH\$	1035
	COMMON/A23/YEARS,SALVA\$,FRINTR,T1,T2,T3,T4,T5,T6	1036
	COMMON/A24/ T7,T8,T9,T10,T11,T12,T13,T14,T15,T16,T17,T18	1037
	COMMON/A25/U1,U2,U3,U4,U5,U6,U7,U8,U9,U10,U11,U12,U13	1038
	COMMON/A28/U14,U15,U16,U17,U18,U19,U20,U21,U22,U23	1039
	DIMENSION PVALUE(7),PSS(7)	1040
	DATA NIN,NOUT/1,3/	1041
	DATA SP,SA,SB,SC,SD,SE,SF,SG,S\$/0.,0.,0.,0.,0.,0.,0.,0.,0./	1042
	FIND(NJ1'1)	1043
	FIND(NJ2'1)	1044
	FIND(NJ3'1)	1045
	SH=0.	1046
	ILLK=0	1047
	IF(JJ8.EQ.0) GO TO 13	1048
	WRITE(NOUT,204)	1049
12	WRITE(NOUT,14) FCTRLD,BASEH\$,YEARS,SALVA\$,FRINTR	1050
	WRITE(NOUT,15) T1,T2,T3,T4,T5	1051
	WRITE(NOUT,16) T6,T7,T8,T9,T10	1052
	WRITE(NOUT,17) T11,T12,T13,T14,T15	1053
	WRITE(NOUT,18) T16,T17,T18	1054
	WRITE(NOUT,19) U1,U2,U3,U4,U5	1055
	WRITE(NOUT,20) U6,U7,U8,U9,U10	1056
	WRITE(NOUT,21) U11,U12,U13	1057
	WRITE(NOUT,22) U14,U15,U16,U17,U18	1058
	WRITE(NOUT,23) U19,U20,U21,U22,U23	1059
	GO TO 13	1060
13	IF(JJ6.EQ.0) GO TO 1	1061
5	IF(JJ6.EQ.0) GO TO 6	1062
	IF(JJ6.EQ.2) GO TO 6	1063
1	WRITE(NOUT,2)	1064
	DO 3 L=1,KK	1065
	READ(NJ1'L) W,ZL,BLOSS,DELTA	1066
	READ(NJ4'L) PRINCP,\$SOLD,ACOST,BCOST,CCOST,DCOST,FCOST,GCOST	1067
	1,HCOST	1068
	IF(W.LT.0.) GO TO 3	1069
	WRITE(NOUT,4) L,ACOST,BCOST,CCOST,DCOST,FCOST,GCOST,\$SOLD	1070
	SA=SA+ACOST	1071
	SB=SB+BCOST	1072
	SC=SC+CCOST	1073
	SD=SD+DCOST	1074

	SE=SE+ECOST	1075
	SF=SF+FCOST	1076
	S\$=S\$+S\$SOLD	1077
	SG=SG+GCOST	1078
	SP=SP+PRINCP	1079
	SH=SH+HCOST	1080
	3 CONTINUE	1081
	WRITE(NOUT,205) SA,SB,SC,SD,SE,SF,SG,S\$	1082
2832	IF(ILLK.EQ.2) GO TO 2322	1083
	IF(ILLK.EQ.0) WRITE(NOUT,207)	1084
	IF(ILLK.EQ.1) WRITE(NOUT,2831)	1085
	MMI5=FIX(YEARS+0.5)	1086
	DO 220 M=1,MMI5	1087
	WRITE(NOUT,221) M	1088
	IF((ILLK.EQ.1).AND.(M.EQ.1)) CALL ADJUST(SPA,SGA)	1089
	IF((ILLK.EQ.1).AND.(M.EQ.1)) SP=SP-SPA	1090
	IF(SP.LT.0.) SP=0.	1091
	WRITE(NOUT,206) SP	1092
	WRITE(NOUT,2557) SH	1093
	IF((ILLK.EQ.0).AND.(M.EQ.1)) S\$=S\$*360.0*24.	1094
	WRITE(NOUT,208) S\$	1095
	CALL DEPREC(M,SP,DEPRE\$)	1096
	WRITE(NOUT,210) DEPRE\$	1097
	CALL QANDM(SP,S\$,QANDM\$)	1098
	WRITE(NOUT,211) QANDM\$	1099
	CALL FINAN(SP,FIN\$)	1100
	WRITE(NOUT,209) FIN\$	1101
	IF((ILLK.EQ.1).AND.(M.EQ.1)) SG=SG-SGA	1102
	IF(SG.LT.0.) SG=0.	1103
	IF((J9.EQ.1).AND.(M.EQ.1)) SG=SG*360.0/BASED	1104
	WRITE(NOUT,222) SG	1105
	CALL SUPPCS(SP,S\$,QANDM\$,FIN\$,DEPRE\$,SUPP\$)	1106
	WRITE(NOUT,223) SUPP\$	1107
	TXSL=(T14+T15)*SP	1108
	WRITE(NOUT,228) TXSL	1109
	PIS=T16*SP+T17*SP+T18	1110
	WRITE(NOUT,224) PIS	1111
	CALL RTOWAY(KK,RTWAY\$)	1112
	RTWY\$=RTWAY\$/YEARS	1113
	WRITE(NOUT,256) RTWY\$	1114
	PRFTBD=S\$-QANDM\$-FIN\$-SG-SUPP\$-PIS-TXSL-RTWAY\$	1115
	IF(PRFTBD.LT.0.0) WRITE(NOUT,225) YFARS	1116
	IF(PRFTBD.LT.0.) GO TO 240	1117
C	REACH HERE IS ONE IS GOING TO MAKE SOME SORT OF PROFIT	1118
	WRITE(NOUT,226) PRFTBD	1119
	PRFTAD=PRFTBD-DEPRE\$	1120
	IF(PRFTAD.LT.0.) CSFLNT=DEPRE\$	1121
	IF(PRFTAD.LT.0.) GO TO 6111	1122
C	REACH HERE IS ONE IS REALLY GOING TO MAKE MONEY	1123
	TXBLI=PRFTAD	1124
	TXSF=(T12+T13)*TXBLI	1125
	WRITE(NOUT,229) TXSF	1126
	CSFLNT=(1.0-(T12+T13))*TXBLI+DEPRE\$	
6111	WRITE(NJ5'M) CSFLNT	
220	CONTINUE	1128
	WRITE(NOUT,230)	1129
	DO 231 MMP=1,7	1130
	RATE=0.05*MMP	1131
		1132

	TIME=-1.	1133
	FACTOR=(EXP(RATE)-1.0)/(EXP(RATE*TIME)*RATE*EXP(RATE))	
	PVALUE(MMP)=-SP*FACTOR	1135
	PSS(MMP)=PVALUE(MMP)	1136
231	CONTINUE	1137
	WRITE(NOUT,232)(PVALUE(MMP),MMP=1,7)	1138
	MMI5=FIX(YEARS+0.5)	1139
	DO 233 MMQ=1,MMI5	1140
	DO 234 MMR=1,7	1141
	READ(NJ5'MMQ) CSFLNT	1142
	RATE=0.05*MMR	1143
	TIME=MMQ	1144
	FACTOR=(EXP(-(RATE*TIME))-1.)/(RATE*TIME)	1145
	PVALUE(MMR)=CSFLNT*FACTOR	1146
	PSS(MMR)=PSS(MMR)+PVALUE(MMR)	1147
234	CONTINUE	1148
	WRITE(NOUT,235)MMQ,(PVALUE(MMT),MMT=1,7)	1149
233	CONTINUE	1150
	WRITE(NOUT,267)(PSS(MMU),MMU=1,7)	1151
	WRITE(NOUT,6100)	1152
	JINX=-51	A1153
6107	JINX=JINX+1	B1153
	IF(JINX.EQ.0) FACTOR=1.0	C1153
	IF(JINX.EQ.0) GO TO 6108	D1153
	IF(JINX.EQ.100) WRITE(NOUT,6110)	E1153
	IF(JINX.EQ.100) GO TO 2321	F1153
	RATE=0.01*JINX	1154
	TIME=-1	1155
	FACTOR=(EXP(RATE)-1.0)/(EXP(RATE*TIME)*RATE*EXP(RATE))	
6108	PART=-SP*FACTOR	1157
	PARTY=-SP*FACTOR	1158
	MMI5=FIX(YEARS+0.5)	1159
	DO 6102 J=1,MMI5	1160
	IF(JINX.EQ.0.) GO TO 6112	
	FACTOR=(EXP(RATE)-1.)/(EXP(RATE*J)*RATE*EXP(RATE))	
6112	READ(NJ5'J) CSFLNT	1163
	QUART=FACTOR*CSFLNT	1164
	PART=PART+QUART	1165
6102	CONTINUE	1166
	IF(PART.LT.0.) GO TO 6103	
6101	GO TO 6107	1167
6103	DO 6105 L=1,MMI5	1168
	READ(NJ5'L) CSFLNT	1169
	WRITE(NOUT,6106) L,CSFLNT	1170
6105	CONTINUE	1171
	WRITE(NOUT,6207) JINX	1172
	GO TO 241	1173
240	DEPRE\$=SP/YEARS	1174
	RQDINC=ABS(PRFTRD)+DEPRE\$	1175
	IF(U16.GT.0.) GO TO 242	1176
	IF(U16.LT.0.) GO TO 243	1177
242	IF(JJ4.EQ.1) QSOLD=S\$/0.23	1178
	IF(JJ4.EQ.0) QSOLD=S\$/0.23	1179
	IF(JJ4.EQ.2) QSOLD=S\$/BASEH\$	1180
	\$INCR=RQDINC/QSOLD	1181
	WRITE(NOUT,244) YEARS,\$INCR	1182
	GO TO 2321	1183
243	\$INCR=RQDINC/(350.0*24.0*U17*1000.)	1184

```

WRITE(NOUT,246) $INCR
GO TO 2321
241 RQDYRS=SP/PREFTRD
WRITE(NOUT,245) RQDYRS
2321 ILLK=ILLK+1
GO TO 2332
2322 IF(JJ6.EQ.1) GO TO 250
IF(JJ6.EQ.0) GO TO 5
6 WRITE(NOUT,8)
DO 43 L=1,KK
READ(NJ1,L) W,ZL,BLOSS,DELTA
READ(NJ2,L) N,Q,H
IF(W.LT.0.) GO TO 43
WRITE(NOUT,44) L,N,W,ZL,BLOSS,DELTA,Q,H
43 CONTINUE
250 RETURN
2 FORMAT('1',//,T40,' COST DATA AND TOTALS',///,' PATH #',4X,' PUM
10',T30,' PIPE',T40,' EXCAVATION',T54,' INSULATION',T71,' MANHOLE',T86,
2 ' CONDUIT',T101,' PUMPING',T113,' GROSS',/,T14,' COST',T30,' COST',
3T40,' COST',T54,' COST',T71,' COST',T86,' COST',T101,' COST',T108,' INCO
4ME/HOUR',//)
4 FORMAT(15,TR,F12.2,2F15.2,2F14.2,2F15.2,F12.2)
8 FORMAT('1',T43,' FLOW EDIT',///,' PATH # OF FLOWRATE', T30,
1'LENGTH',T45,' BUILDING LOSS',T60,' DELTA T', T75,' Q',T90,' HEAD LOSS
2',/, ' # PIPES',//)
14 FORMAT('1 LOAD FACTOR SALE PRICE OF HEAT EFFECTIVE LIFE SALVAGE
LVALUE SINKING FUND RATE',/,5F15.5,//)
15 FORMAT('1 T1-T5 VALUES ARE :',/,5F15.5,//)
16 FORMAT('1 T6-T10 VALUES ARE :',/,5F15.5,//)
17 FORMAT('1 T11-T15 VALUES ARE :',/,5F15.5,//)
18 FORMAT('1 T16-T18 VALUES ARE :',/,3F15.5,//)
19 FORMAT('1 U1-U5 VALUES ARE :',/,5F15.5,//)
20 FORMAT('1 U6-U10 VALUES ARE :',/,5F15.5,//)
21 FORMAT('1 U11,U12,U13 VALUES ARE :',/,3F15.5)
22 FORMAT(//,' U14-U18 VALUES ARE :',/,5F15.5)
23 FORMAT(//,' U19-U23 VALUES ARE :',/,5F15.5)
44 FORMAT(215,5F15.7)
204 FORMAT('1',///,' ECONOMIC INPUT DATA',//)
205 FORMAT('1 TOTALS',/,TR,F12.2,2F15.2,2F14.2,2F15.2,F12.2)
206 FORMAT(//,' THE TOTAL INSTALLATION COST IS :',T5R,'$$',F20.2)
207 FORMAT('1',///,' THE FOLLOWING IS AN ECONOMIC ANALYSIS W/O ADJUSTME
INT',//)
208 FORMAT(//,' THE GROSS ANNUAL INCOME IS :',T90,F20.2)
209 FORMAT(//,' THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:
1',T60,F20.2)
210 FORMAT(//,' THE DEPRECIATION IS :', T60,F20.2)
211 FORMAT(//,' THE ANNUAL OPERATING AND MAINTENANCE EXPENSE IS :',T60
1,F20.2)
221 FORMAT('1',///,' YEAR',I3,T65,' OUTFLOWS',T90,' INFLOWS',//)
222 FORMAT(//,' THE ANNUAL PUMPING COST IS :',T60,F20.2)
223 FORMAT(//,' THE ANNUAL SUPPLEMENTARY COSTS ARE :',T60,F20.2)
224 FORMAT(//,' THE ANNUAL INSURANCE CHARGES ARE :',T60,F20.2)
225 FORMAT(////,T20,' THE SUM OF THE ANNUAL OPERATING EXPENSES IS GREA
1TER',/,T20,' THAN THE GROSS INCOME, THUS THERE WILL ALWAYS BE AN',
2/,T20,' OPERATING EXPENSE FOR THIS SYSTEM. THE FOLLOWING',/,T20,
3' WILL BE AN ANALYSIS OF THE REQUIREMENTS TO JUST PAY',/,T20,' OFF
4 THE PLANT IN',F10.0,' YEARS')
226 FORMAT(//,' THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION I

```

```

1185
1186
1187
1188
1189
1190
1191
1192
1193
1194
1195
1196
1197
1198
1199
1200
1201
1202
1203
1204
1205
1206
1207
1208
1209
1210
1211
1212
1213
1214
1215
1216
1217
1218
1219
1220
1221
1222
1223
1224
1225
1226
1227
1228
1229
1230
1231
1232
1233
1234
1235
1236
1237
1238
1239
1240
1241
1242

```

```

1S: ',T75,F20.2)
227 FORMAT(//,T20,' THE ANNUAL NET INCOME, INCLUDING THE ',/,T20,' ANNU
1AL DEPRECIATION CHARGE INDICATES A LOSS. THEREFORE, THE ',/,T20,'
2 FOLLOWING WILL BE AN ESTIMATION OF THE NUMBER OF ',/,T20,' YEARS
3 TO PAY OFF THE PLANT AT THE SPECIFIED RATE OF INCOME')
228 FORMAT(//, ' THE PROPERTY TAXES ARE: ',T60,F20.2)
229 FORMAT(//, ' THE FEDERAL AND STATE INCOME TAXES ARE: ',T60,F20.2)
230 FORMAT('1', ' A CASH FLOW SUMMARY FOLLOWS ',//, ' YEAR ',T8,' NET CASH
1FLOW ',T22,' 5%',T36,' 10%',T50,' 15%',T64,' 20%',T78,' 25%',T102,' 30%'
2,T112,' 35%')
232 FORMAT(' ', ' -1 ',T8,7F14.2)
235 FORMAT(I8,T22,7F14.2)
247 FORMAT(//, ' TOTALS ',T22,7F14.2)
244 FORMAT(//, ' THE INCREMENTAL SELLING INCREASE REQUIRED($/1. E6 BTU)
1 TO PAY OFF THE PLANT IN ',F10.1,' YEARS IS: ',F20.2)
245 FORMAT(//, ' THE PAY OUT TIME AT CURRENT RATE IS: ',IPE15.7)
246 FORMAT(//, ' THE REQUIRED INCREASE IN ELECTRICITY COSTS, $/KWH IS: '
1,E15.7)
256 FORMAT(//, ' THE ANNUAL RIGHT-OF-WAY COST IS: ',T60,F20.2)
2557 FORMAT(//, ' THE TOTAL SUPPLEMENTARY INSTALLATION COST IS: ',T60,F20
1.2)
2831 FORMAT('1',//, ' ADJUSTED ECONOMIC ANALYSIS ',//)
6100 FORMAT('1',//, ' A LISTING OF THE NET CASH FLOW FOLLOWS: ',
1/, ' YEAR AFTER START-UP ',T35,' NET CASH FLOW')
6106 FORMAT(I30,F20.2)
6207 FORMAT(////, ' THE RETURN ON INVESTMENT IS : ',I3,' PER CENT')
6110 FORMAT(////, ' THE RETURN ON INVESTMENT CANNOT BE FOUND BETWEEN -50
1 AND 100 PER CENT ')
END

```

```

1243
1244
1245
1246
1247
1248
1249
1250
1251
1252
1253
1254
1255
1256
1257
1258
1259
1260
1261
1262
1263
1264
1265
1266
1267
1268
1269

```


APPENDIX C

SUBROUTINE LISTING

The digital computer program is written in the Fortran IV, level G language for the IBM 360-50 computer system. The program consists of a main program and 31 subroutines.

Following is a listing of the subroutine names, the functions of the subroutines, the subroutines that are called and the subroutines that call the named subroutine. (I/O means input or output device.)

Name	Function	Subroutines Called	Subroutine Called By	
MAIN	Flow Control; I/O	STRNFL	PLLP	-----
		DRECON	DREAD	
		VELIN	ANHLIN	
		EXPOIN	PRICEI	
		TLREAD	WRITEO	
STRNFL	Flow Control of Series Circuit	COPTIM	MAIN	
		TEMOP		
PLLP	Flow Control of Parallel Circuit	COPTIM	MAIN	
		TEMOP		
COPTIM	Optimization by minimizing in- stallation and pumping costs	FLOCLC	CINSUL	STRNFL
		CPUMP	CMNHOL	PLLP
		CPIPE	CCONDT	
		CEXCAV	PUMCST	
		SUPCST	WRONG	
		RIGHT	HEAT\$	

TEMOP	Optimization by Maximization of Annual Rate of Return	HEAT\$ FLOCLC CPIPE CEXCAV PUMCST OANDM FINAN CMNHOL CPUMP CINSUL CCONDT SUPCST	STRTFL PLLP	
DRECON	I/O Economics Data	-----	MAIN	
DREAD	I/O OPTIONS	-----	MAIN	
VELIN	I/O Velocity & Number of Pipes	-----	MAIN	
ANHLIN	I/O Manhole Data	-----	MAIN	
EXPOIN	I/O Exponent Data	-----	MAIN	
TLREAD	I/O Table Data	-----	MAIN	
PRICEI	I/O Cost Data	-----	MAIN	
FLOCLC	Pressure Drop; Number of Pipes	-----	TEMOP COPTIM ADJUST	
CPUMP	Pump Cost	CPOLE	TEMOP COPTIM	
CPIPE	Pipe Cost	CPOLE	TEMOP ADJUST	COPTIM
CEXCAV	Excavation Cost	-----	TEMOP ADJUST	COPTIM
CINSUL	Insulation Cost	-----	TEMOP	COPTIM

CMNHOL	Manhole Cost	-----	TEMOP	COPTIM
CCONDT	Conduit Cost	-----	TEMOP	COPTIM
PUMCST	Pumping Cost	-----	TEMOP	COPTIM
			ADJUST	
SUPCST	Supplemental Cost	-----	TEMOP	COPTIM
WRONG	Curve Orientation	-----	COPTIM	
STANDD	Curve Orientation	-----	COPTIM	
HEAT\$	Income from Sale	-----	COPTIM	TEMOP
	of Heat			
OANDM	Operation and	-----	TEMOP	WRITEO
	Maintenance Cost			
FINAN	Financing Charges	-----	TEMOP	WRITEO
CPOLE	Computes Exponent	-----	CPUMP	CPIPE
	for Cost Extrapol-		CCONDT	
	ation			
WRITEO	Output; Flow	ADJUST	DEPREC	MAIN
	Control;	OANDM	FINAN	
	Economics	SUPPCS	RTOWAY	
ADJUST	Computes Adjustment	FLOCLC		WRITEO
	and Comparative Cost	PUMCST		
	Data			
DEPREC	Calculates	-----		WRITEO
	Depreciation			
SUPPCS	Supplemental	-----		WRITEO
	Annual Costs			
RTOWAY	Right-of-Way	-----		WRITEO
	Costs			

The program can compute optimum sizes for as many as 999 flowpaths and piping diameters from one inch to 100 inches. Five tape or disk storage units are utilized, each containing 1000 records of 40 words each. 130,000 bytes of core storage are required in the execution of this program.

The program consists of some 1200 computer cards. Compilation time for the program is on the order of 3 minutes. The example problem computation required 5 minutes of computer time; a problem with 999 flowpaths executed in 50 minutes.

APPENDIX D

INPUT INSTRUCTIONS

The input data is separated into four sections: economic data, fixed point and mandatory data, optional data and flow path data. In each case, the required format is given. All data that is mandatory is coded (M) and optional data is coded (O).

A. ECONOMIC DATA

Card 01	Column 1-15	Overall plant load factor. If not available, input 0.8. (F15.5)(M)
	Col 16-30	Selling price of heat, $\$/10^6$ BTU (F15.5)(M)
	Col 31-45	Effective plant life, years (F15.5)(M)
	Col 46-60	Salvage value of plant as a fraction of the initial investment. A value from 0.00 to 0.25 is recommended. (F15.5)(M)
	Col 61-75	Sinking fund interest rate. Required only if sinking fund depreciation is selected. (F15.5)(M)

The next six data values are used in a supplemental cost routine for cash flow analysis. This permits the investigator to change varying interest rates on the capital cost, return on investment, operating and maintenance costs, financing costs, depreciation costs, and an independent supplemental cost. Thus, a cost such as operating capital

(which is not included elsewhere) could be input as a percentage of the investment; labor cost as an independent cost, etc.

Card 02	T1	Column 1-15	Supplemental cost, fraction of installation cost. (F15.5)(0)
	T2	Col 16-30	Supplemental cost, fraction of gross income. (F15.5)(0)
	T3	Col 31-45	Supplemental cost, fraction of operating and maintenance costs (F15.5)(0)
	T4	Col 46-60	Supplemental cost, fraction of financing costs. (F15.5)(0)
	T5	Col 61-75	Supplemental cost, fraction of depreciation cost. (F15.5)(0)
Card 03	T6	Col 1-15	Supplemental cost, independent. (\$/year) (F15.5)(0)
	T7	Col 16-30	Annual operating and maintenance costs, fraction of installation costs. (F15.5)(0)
	T8	Col 31-45	Annual operating/maintenance costs- fraction of installation costs. (F15.5)(0)
	T9	Col 46-60	Operation and Maintenance costs, independent input. (\$/year)(F15.5)(0)
	T10	Col 61-75	Annual financing charge interest rate (expressed as a fraction). (F15.5)(0)

Card 04	T11	Column 1-15	Financing cost, independent. (\$/year) (F15.5)(0)
	T12	Col 16-30	Federal income tax rate (fraction). (F15.5)(0)
	T13	Col 31-45	State income tax rate (fraction). (F15.5)(0)
	T14	Col 46-60	County tax rate (computed considering investment costs only). (fraction) (F15.5)(0)
	T15	Col 61-75	City tax rate (computed considering investment costs only). (fraction) (F15.5)(0)
Card 05	T16	Col 1-15	Liability insurance rate (computed on investment cost only). (fraction) (F15.5)(0)
	T17	Col 31-45	Independent insurance costs (annual). (F15.5)(0)

The remainder of this card and the next few cards are used to input percentages of the component costs. This can be used, for example, as a reliability input by using 1.5 or 2.0 for the pump cost. (Note: The effect of these inputs are added to the total installation costs for computing the total installation costs.)

Card 05 (cont'd)	U1	Column 46-60	Supplemental cost-fraction of the pump cost. (F15.5)(0)
	U2	Col 61-75	Supplemental cost-fraction of piping cost. (F15.5)(0)

Card 06	U3	Column 1-15	Supplemental cost-fraction of excavation cost. (F15.5)(0)
	U4	Col 16-30	Supplemental cost-fraction of insulation cost. (F15.5)(0)
	U5	Col 31-45	Supplemental cost-fraction of manhole cost. (F15.5)(0)
	U6	Col 46-60	Supplemental cost-fraction of conduit cost. (F15.5)(0)
	U7	Col 61-75	Supplemental cost-fraction of pumping cost. (F15.5)(0)
Card 07	U8	Column 1-15	Supplemental cost-independent. (F15.5)(0)
	U9	Col 16-30	Supplemental cost-multiple of diameter. (F15.5)(0)
	U10	Col 31-45	Supplemental cost-multiple of length. (F15.5)(0)
	U11	Col 46-60	Supplemental cost-multiple of volumetric flowrate. (F15.5)(0)
	U12	Col 61-75	Supplemental cost-multiple of the number of pipes. (F15.5)(0)
Card 08	U13	Col 1-15	Supplemental cost-independent. (F15.5)(0)

The following data is used to input right of way costs, easement costs, and an indicator for adjustment calculations.

Card 09	U14	Column 1-15	Input length of pipe installed in lakes, rivers (no right of way costs for this length), ft. (F15.5)(0)
---------	-----	-------------	---

U15 Col 16-30 Input \$\$/foot of right of way cost.
(F15.5)(0)

U16 Col 31-45 If greater than 0, computes any
increase in selling price in terms
of \$\$/10⁶ BTU increase. (F15.5)(0)
If less than 0, computes the increase
in selling price required in \$\$/Kilo-
watt-hour. (F15.5)(0)

U17 Col 46-60 Megawatt electrical rating of the
plant. (F15.5)(0)

U18 Col 61-75 Easement costs, \$/year. (F15.5)(0)

The next card contains the data required for the adjusted cost analysis. The input data determines the type of conventional system for the comparative analysis.

Card 10 U19 Column 1-15 Installation cost of the piping
of the conventional condensing
system. (F15.5)(0)

U20 Col 16-30 Annual pumping cost, \$\$/year (for
condensing system). (F15.5)(0)

U21 Col 31-45 Flowrate of conventional cooling
system in gallons per minute.
(F15.5)(0)

U22 Col 46-60 Fractional cost expenditure
required (fraction of size of
conventional equipment and operating
cost). (F15.5)(0)

U23 Col 61-75 Cost of installation of conventional
condensing system (physical plant).
(F15.5)(0)

B. FIXED POINT AND MANDATORY DATA

The following data cards are the control cards for the program.
Most of the data in this section must be supplied.

Card 1	J1	Column 5	Input=0::limiting velocity is 10 ft/sec Input=1::limiting velocity is supplied
	J2	Col 10	Input=0::building loss is calculated Input=1::building loss is supplied
	J3	Col 15	Input=0::pump cost is calculated (1962 dollars) Input=1::base size, base price to be input for exponential Input=2::100 values of pipe size, pipe cost to be supplied Input=3::input two sizes, two costs for exponential fit
	J4	Col 20	Input=0::pipe cost is calculated (1962 dollars) Input=1::input base size, base price for exponential Input=2::100 values of pipe sizes and costs to be supplied Input=3::input two sizes, two costs for exponential fit
	J5	Col 25	Input=0::excavation cost is calculated

Input=1::input BASEE, $\$/ft^3$ excavated
 J6 Col 30 Input=0::calculates insulation cost
 (1962 dollars)
 Input=1::input BASEV, $\$/ft$ insulation cost
 J7 Col 35 Input=0::calculates manhole cost
 (1962 dollars)
 Input=1::input the hole cost ($\$/ft.$ depth)
 Input=2::input the hole cost and the
 hole spacing (feet)
 J8 Col 40 Input=0::calculates the conduit cost
 (1962 dollars)
 Input=1::50 values of size, cost of
 conduit to be supplied
 Input=2::input cost, size for exponential
 J9 Col 45 Input=0::calculate pumping power cost
 (1962 dollars)
 Input=1::input BASED and BASE\$ (base
 days and base cost of electricity,
 $\$/KWH$)
 I1 Col 50 Input=0::a standard condenser is the
 comparison base
 Input=1::a cooling tower is the
 comparison base
 Input=2::a cooling pond is the comparison
 base
 I2 Col 55 Input=0::use program calculations

Input=1::calculates for system
characterized by I1
Format(11I5), all (M)

Card 2	J10	Column 5	Input=0::the input fixed point data is not printed Input=1::the input fixed point data is printed
	J11	Col 10	Input=0::the limiting radii are not printed Input=1::the limiting radii are printed
	J12	Col 15	Input=0::density and viscosity are not printed Input=1::density and viscosity are printed
	J13	Col 20	Input=0::the cost-price indices are not printed Input=1::the cost-price indices are printed
	J14	Col 25	Input=0::no pipe table cost data output Input=1::pipe data table is output (this option only available if J4=2)
	J15	Col 30	Input=0::no conduit table cost data output Input=1::conduit cost data is output (this option only available is J8=1)

J16 Col 35 Input=0::no pump table cost data output
 Input=1::pump cost data table is output
 (this option only available if
 J3=2)

J17 Col 40 Input=0::base values from optional data
 cards are not printed
 Input=1::base values from optional data
 cards are printed

J18 Col 45 Input=0::manhole cost data not printed
 Input=1::manhole cost data is printed

J19 Col 50 Input=0::limiting velocity is not printed
 Input=1::limiting velocity is printed

J20 Col 55 Input=0::flow rate, length, building loss,
 and building delta temperature
 for each path are input
 Input=1::length, heat requirement (BTU/hr)
 and building loss for each path
 are input
 Input=2::flow rate, length, heat
 requirement and building loss
 for each path are input

Format(11I5), all (M)

Card 3 JJ1 Column 5 Input=0::finds true optimum
 Input=1::finds optimum for specified
 minimum number of pipes

JJ2 Col 10 Input=0::the minimum number of pipes is
 not output

Input=1::the minimum number of pipes is
output

JJ3 Col 15 Input=0::minimizes the installation and
pumping cost for a specified
time interval

Input=1::maximizes the rate of investment
return

JJ4 Col 20 Input=0::uses $\$0.23/10^6$ BTU as the selling
price of heat

Input=1::input sale price of heat

JJ5 Col 25 Input=0::straight line depreciation

Input=1::sum of the years digits
depreciation

Input=2::sinking fund depreciation

Input=3::declining balance depreciation

JJ6 Col 30 Input=0::outputs economics and flow edit

Input=1::outputs economic edit only

Input=2::outputs flow edit only

JJ7 Col 35 Input=0::sale price required to break
even not computed

Input=1::sale price required to break
even is computed

JJ8 Col 40 Input=0::economics input data is not
printed

Input=1::economics data is printed

Format(11I5), all (M)

Card 4 K1,K2,K3 Input the lower limit, mean and upper limit
 on pipe sizes under consideration
 (integers, inches) (3I10)(M)

Card 5 Rho, Pois Input the density and viscosity of the
 fluid under consideration (lbs/ft³)
 (lbs/ft-sec) (2F20.7)(M)

Card 6 CPI(7) Input the cost price indices (7) in the
 following order:

- 1 Pump
- 2 Pipe
- 3 Excavation
- 4 Insulation
- 5 Manhole
- 6 Conduit
- 7 Pumping cost

These values are used to adjust the program values of 1962 dollars (or the value of costs that the programmer inputs) to the year the programmer desires. For example, if CPI(1) is input as 1.36 and J3 is 0, then the 1962 dollars used in the program are adjusted to about the 1970 cost of the pump. (7F10.5) (M)

C. OPTIONAL DATA

Card 1 If J1 is 0, this card is not used.
 If J1 is 1, input limiting velocity (ft/sec)
 (F20.7)(0)

Card 2 If JJ1 is 0, this card is not used
 If JJ1 is 1, input (minimum pipes -1) (I5)(0)

Card 3 If J7 is 0, this card is not used
 If J7 is 1, input the hole cost (\$/ft. depth)
 (F20.7)(0)
 If J7 is 2, input the hole spacing (feet)
 (F20.7)(0)
 If J7 is 3, input the hole cost and hole spacing
 (2F20.7)(0)

Card(s) 4 (4A) If J3 is 3, input lower diameter in inches, lower
 cost, upper diameter and upper cost of pumps for
 exponential fit. (4F20.7)(0)

(Maximum
of 3
cards) (4B) If J4 is 3, input lower diameter in inches, lower
 cost, upper diameter and upper cost of pipng for
 exponential fit. (4F20.7)(0)

(4C) If J8 is 2, input lower diameter in inches, lower
 cost, upper diameter in inches, and upper cost of
 conduit for exponential fit. (4F20.7)(0)

Card 5 Blank (M)

Card(s) 6 If J3 is 2, input 100 cards with values of pump
 size and pump cost (1 inch to 100 inches).
 (I5,F20.7)(0)

(Maximum
of 250
cards) If J4 is 2, input 100 cards with values of pipe
 size and pipe cost (1 inch to 100 inches).
 (I5,F20.7)(0)

 If J8 is 1, input 50 values of conduit cost
 (from 4 inches to 200 inches by 4 inch increments).
 (I5,F20.7)(0)

- Card(s) 7 (7A) If J3 is 1, input base pump size (ft³/min) and base pump cost. (2F20.7)(0)
- (Maximum of 5 cards) (7B) If J4 is 1, input base pipe size and base pipe cost (inches). (2F20.7)(0)
- (7C) If J5 is 1, input base excavation cost (\$/ft³). (F20.7)(0)
- (7D) If J6 is 1, input base insulation cost (\$/ft). (F20.7)(0)
- (7E) If J9 is 1, input base days of operation for pumping cost analysis and base cost of electricity (\$/KWH). (2F20.7)(0)
- Card 8 Blank (M)

Extreme care must be used in supplying the input data above. For example, if J3 is 2 and only 99 data cards are supplied, the program will not get correct results. (An error will result also.)

D. FLOW PATH DATA

The input contained in this section is the most difficult to organize and is the most critical part of the program. To code this portion, it is recommended that an electrical analog be set up and the network reduced starting with the furthest point from the pumps (current source).

Card 1 Input the number of branches (I10)(M)

This card indicates to the program the number of sets of input data to follow. Each branch will be coded later as to the type of branch (series, parallel or series-parallel) and the number of paths in the branch.

To clarify the input required, Figure 13 shows three example circuits. Circuit A has one branch, three paths and is a series circuit. Circuit B has one branch, five paths, and is a parallel circuit. Circuit C has two branches, I and II. Branch I is a series branch with 3 paths; branch II is a series-parallel branch consisting of three parallel paths and three series paths. (The third series path is the parallel network.)

The parallel network, when calculated in the series path, is coded with a negative flowrate to insure that duplicate calculations are not performed.

Card 2	Column 10	Input=0::series circuit
		Input=1::parallel circuit
		Input=2::series-parallel circuit
	Col 11-20	The total number of paths in the branch.
	Col 21-30	The number of parallel paths in a parallel or series parallel network.
	Col 31-40	The path number which contains the pumps.


Format (4I10),(M)

This card for branch I of circuit C (Figure 13) would read:


Column	10	20	30	40
	0	3	0	33

There will be one card 2 supplied for each branch.


Card(s) 3 Flowpath data cards.



A.



B.



C.

FIGURE 13. THREE EXAMPLE CIRCUITS

The inputs on this card are variable depending on J20. The variables that may be input are:

- KK The path number. Must be sequential from 1 to a maximum of 1000. The paths with negative flowrates must be coded in sequence. It is absolutely mandatory that the last data card input KK as the greatest value (equals the total number of paths analyzed) for this is the index on the Economic Analysis printout.
- W The mass flowrate, lbs/hr. If this is input as a negative value, no cost calculations are performed nor printout given for this path.
- ZL The length of piping in the path (feet).
- BLOSS The building loss in feet of water head. If this is input as a negative number, there is no building on the leg of piping under consideration.
- DELTA The temperature drop across the building that is caused by the heat demand of the building. If this is input as 0.0, no heat is sold.
- QHEAT The amount of heat required by the building on the path, BTU/hour.
- INSULI Indicator to tell program if the path is to be insulated or uninsulated. (If = 0, path is not insulated, if = 1, path is insulated.)

These quantities are input in the following manner:

If J20 is 1, input KK, INSULI, W, ZL, BLOSS, DELTA

(2I15,4F15.5).

If J20 is 2, input KK, INSULI, ZL, QHEAT, BLOSS
(2I5,3F15.5).

If J20 is 3, input KK, INSULI, W, ZL, QHEAT, BLOSS
(2I5,4F15.5).

It is recommended that J20 equal to 2 be used.

The order of cards for this data set is:

Card 1

Card 2

Card(s) 3 For series flow, the number of cards equals the number of paths. For parallel flows, the number of paths equals the number of cards. For series-parallel, input the parallel paths first; then series paths. Total cards = total number of paths plus 1, the additional path having a negative flowrate.

Card 1

Card 2

Card(s) 3

etc. until there are as many card number 2 data cards as specified on card 1.

APPENDIX E
BALANCE SHEETS

The following pages show the annual balance sheets that the computer program calculated for the typical problem of section V. These are given from years 2-30 for the non-adjusted economic analysis and years 2-30 for the adjusted economic analysis.

YEAR 2		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1593623.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 3		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1538671.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 4		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1483718.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 5		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1428766.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 6		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1373813.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 7		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3737770.00
THE DEPRECIATION IS :		1318861.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 3		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS :		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1263908.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS :		941423.69	
THE ANNUAL PUMPING COST IS :		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE :		12000.00	
THE PROPERTY TAXES ARE :		2689.78	
THE ANNUAL INSURANCE CHARGES ARE :		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS :		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS :			294061.19

YEAR 9		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$ \$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1208955.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 10		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1154003.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 11		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1099050.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 12		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1044097.88	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRFCIATION IS:			294061.19

YEAR 13		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS :		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		989145.44	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS :		941423.69	
THE ANNUAL PUMPING COST IS :		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE :		12000.00	
THE PROPERTY TAXES ARE :		2689.78	
THE ANNUAL INSURANCE CHARGES ARE :		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS :		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS :			294061.19

YEAR 14

OUTFLOWS

INFLOWS

THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		934192.94	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 15		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		879240.50	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 16		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		824287.75	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 17		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$5	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		769335.31	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 19	OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$ 26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:	4452744.00	
THE GROSS ANNUAL INCOME IS :		3737770.00
THE DEPRECIATION IS :	714382.81	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:	941423.69	
THE ANNUAL PUMPING COST IS:	2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:	12000.00	
THE PROPERTY TAXES ARE:	2689.78	
THE ANNUAL INSURANCE CHARGES ARE:	7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:	2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:		294061.19

YEAR 19		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26997824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		659430.38	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 20		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26997324.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		604477.63	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 21		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		549525.19	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			297061.19

YEAR 22		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		494572.69	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 23		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		439620.25	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		96 423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PPROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 24		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		384667.50	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19

YEAR 25	OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$ 26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:	4452744.00	
THE GROSS ANNUAL INCOME IS :		3787770.00
THE DEPRECIATION IS :	329715.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:	941423.69	
THE ANNUAL PUMPING COST IS:	2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:	12000.00	
THE PROPERTY TAXES ARE:	2689.78	
THE ANNUAL INSURANCE CHARGES ARE:	7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:	2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:		294061.19

YEAR 26

OUTFLOWS

INFLOWS

THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		274762.63	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19
THE FEDERAL AND STATE INCOME TAXES ARE:		9649.28	

YEAR 27		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		219810.13	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19
THE FEDERAL AND STATE INCOME TAXES ARE:		37125.53	

YEAR 28		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		164857.63	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPFRTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19
THE FEDERAL AND STATE INCOME TAXES ARE:		64601.78	

YEAR 29

OUTFLOWS

INFLOWS

THE TOTAL INSTALLATION COST IS :	\$5	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		109905.06	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19
THE FEDERAL AND STATE INCOME TAXES ARE:		92078.06	

YEAR 30		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	26897824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		54952.53	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		268978.13	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		941423.69	
THE ANNUAL PUMPING COST IS:		2199313.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2689.78	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			294061.19
THE FEDERAL AND STATE INCOME TAXES ARE:		119554.31	

YEAR 2

	OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$5 21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:	4452744.00	
THE GROSS ANNUAL INCOME IS :		3787770.00
THE DEPRECIATION IS :	1264682.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:	747103.75	
THE ANNUAL PUMPING COST IS:	1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:	12000.00	
THE PROPERTY TAXES ARE:	2134.58	
THE ANNUAL INSURANCE CHARGES ARE:	7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:	2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:		1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:	81815.50	

YEAR 3		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1221072.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		103620.50	

YEAR 4	OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS :	4452744.00	
THE GROSS ANNUAL INCOME IS :		3787770.00
THE DEPRECIATION IS :	1177462.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:	747103.75	
THE ANNUAL PUMPING COST IS:	1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:	12000.00	
THE PROPERTY TAXES ARE:	2134.58	
THE ANNUAL INSURANCE CHARGES ARE:	7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:	2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:		1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:	125425.50	

YEAR 5	OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$ 21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:	4452744.00	
THE GROSS ANNUAL INCOME IS :		3787770.00
THE DEPRFCIATION IS :	1133853.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:	747103.75	
THE ANNUAL PUMPING COST IS:	1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:	12000.00	
THE PROPERTY TAXES ARE:	2134.58	
THE ANNUAL INSURANCE CHARGES ARE:	7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:	2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:		1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:	147230.00	

YEAR 6		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1090243.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		169035.00	

YEAR 7	OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$ 21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:	4452744.00	
THE GROSS ANNUAL INCOME IS :		3787770.00
THE DEPRECIATION IS :	1046633.94	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:	747103.75	
THE ANNUAL PUMPING COST IS:	1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:	12000.00	
THE PROPERTY TAXES ARE:	2134.58	
THE ANNUAL INSURANCE CHARGES ARE:	7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:	2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:		1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:	190839.50	

YEAR 9		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		1003023.94	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		212644.50	

YEAR 9		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		959414.19	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		234449.38	

YEAR 10		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		915804.44	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		256254.25	

YEAR 11		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		872194.75	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		278059.13	

YEAR 12		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		828585.00	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		299864.00	

YEAR 13		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		784975.25	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BFFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		321668.88	

YEAR 14		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		741365.50	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		343473.75	

YEAR 15		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		697755.75	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		365278.63	

YEAR 16

	OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$ 21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:	4452744.00	
THE GROSS ANNUAL INCOME IS :		3787770.00
THE DEPRECIATION IS :	654145.75	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:	747103.75	
THE ANNUAL PUMPING COST IS:	1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:	12000.00	
THE PROPERTY TAXES ARE:	2134.58	
THE ANNUAL INSURANCE CHARGES ARE:	7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:	2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:		1429313.00
THE FEDERAL AND STATE INCOME TAXES ARE:	397093.63	

YEAR 17

OUTFLOWS

INFLOWS

THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		610536.31	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		408888.31	

YEAR 18

	OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$ 21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:	4452744.00	
THE GROSS ANNUAL INCOME IS :		3787770.00
THE DEPRECIATION IS :	566926.56	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:	747103.75	
THE ANNUAL PUMPING COST IS:	1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:	12000.00	
THE PROPERTY TAXES ARE:	2134.58	
THE ANNUAL INSURANCE CHARGES ARE:	7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:	2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:		1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:	430693.19	

YEAR 19		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		523316.81	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		452498.06	

YEAR 20		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		479706.81	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		474303.06	

YEAR 21		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		436097.06	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		496107.94	

YEAR 22

	OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$ 21345924.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:	4452744.00	
THE GROSS ANNUAL INCOME IS :		3787770.00
THE DEPRECIATION IS :	392487.63	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:	747103.75	
THE ANNUAL PUMPING COST IS:	1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:	12000.00	
THE PROPERTY TAXES ARE:	2134.58	
THE ANNUAL INSURANCE CHARGES ARE:	7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:	2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:		1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:	517912.69	

YEAR 23

OUTFLOWS

INFLOWS

THE TOTAL INSTALLATION COST IS :	\$5	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		348877.88	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		539717.50	

YEAR 24

	OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$ 21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:	4452744.00	
THE GROSS ANNUAL INCOME IS :		3787770.00
THE DEPRECIATION IS :	305267.88	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:	747103.75	
THE ANNUAL PUMPING COST IS:	1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:	12000.00	
THE PROPERTY TAXES ARE:	2134.58	
THE ANNUAL INSURANCE CHARGES ARE:	7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:	2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:		1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:	561522.50	

YEAR 25

OUTFLOWS

INFLOWS

THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		261658.44	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		583327.00	

YEAR 26

OUTFLOWS

INFLOWS

THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS :		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		218048.69	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		605132.00	

YEAR 27

	OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	21345874.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS :	4452744.00	
THE GROSS ANNUAL INCOME IS :		3787770.00
THE DEPRECIATION IS :	174438.94	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS :	747103.75	
THE ANNUAL PUMPING COST IS :	1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE :	12000.00	
THE PROPERTY TAXES ARE :	2134.59	
THE ANNUAL INSURANCE CHARGES ARE :	7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS :	2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS :		1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE :	626937.00	

YEAR 28		OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		130829.19	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		648741.50	

YEAR 29

	OUTFLOWS	INFLOWS
THE TOTAL INSTALLATION COST IS :	\$ 21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:	4452744.00	
THE GROSS ANNUAL INCOME IS :		3787770.00
THE DEPRECIATION IS :	87219.44	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :	213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:	747103.75	
THE ANNUAL PUMPING COST IS:	1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:	12000.00	
THE PROPERTY TAXES ARE:	2134.58	
THE ANNUAL INSURANCE CHARGES ARE:	7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:	2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:		1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:	670546.50	

YEAR 30

OUTFLOWS

INFLOWS

THE TOTAL INSTALLATION COST IS :	\$	21345824.00	
THE TOTAL SUPPLEMENTARY INSTALLATION COST IS:		4452744.00	
THE GROSS ANNUAL INCOME IS :			3787770.00
THE DEPRECIATION IS :		43609.73	
THE ANNUAL OPERATING AND MAINTENANCE EXPENCE IS :		213458.19	
THE ANNUAL FINANCING AND SUPPLEMENTAL FINANCE COST IS:		747103.75	
THE ANNUAL PUMPING COST IS:		1315456.00	
THE ANNUAL SUPPLEMENTARY COSTS ARE:		12000.00	
THE PROPERTY TAXES ARE:		2134.58	
THE ANNUAL INSURANCE CHARGES ARE:		7623.00	
THE ANNUAL RIGHT-OF-WAY COST IS:		2056.00	
THE NET ANNUAL INCOME, BEFORE TAXES AND DEPRECIATION IS:			1428313.00
THE FEDERAL AND STATE INCOME TAXES ARE:		692351.50	

VIII. BIBLIOGRAPHY

- [1] Anonymous, "Guide for Economic Evaluation of Nuclear Reactor Plant Designs," NUS Corporation, Rockville, Maryland, January 1969 (NUS 531).
- [2] Anonymous, "Nuclear Energy Centers Industrial and Agro Industrial Complexes," Oak Ridge National Laboratories, Clearinghouse for Scientific and Technical Information, National Bureau of Standards, Springfield, Virginia, November 1968.
- [3] Anonymous, "Status of the Application of Nuclear Reactors in the Process Industries," Division of Reactor Development, Atomic Energy Commission, 1961.
- [4] Anonymous, "Sterilization of Sewage Containing Pathogenic Microorganisms. Nuclear Reactors," Addendum to Report No. 9, Chicago: Illinois Institute of Technology, May, 1956.
- [5] Anonymous, "Underground Stations Pondered in Sweden," Nuclear News, 13(6): 26, May, 1970.
- [6] Bygs, J.G., "Nuclear Station Waste Heat Can Extend the Saint Lawrence Seaway Season," Atomic Energy of Canada Limited, Clearinghouse for Scientific and Technical Information, U.S. National Bureau of Standards, Springfield, Virginia, November, 1967. (CONF 680601-25)
- [7] Blomberg, Pehr and Vogt, Jan, "Agesta," Nuclear News, 13(2) 37-42, February, 1970.
- [8] Dietz, Albert G.H., "Proceedings of a Symposium/Workshop on Underground Heat Distribution Systems," Publication 1412, Washington: National Academy of Sciences, National Research Council, 1966.
- [9] Dillon, Robert M., et al, "Evaluation of Components for Underground Heat Distribution Systems," Publication 828, Washington: National Academy of Sciences, National Research Council, 1960.
- [10] Drobish, William E., et al, "Course Notes for Electrical Circuits and Applications," unpublished, U.S. Naval Nuclear Power School, Bainbridge, Maryland, January, 1963.
- [11] Frank, Howard and Frisch, Ivan T., "Network Analysis," Scientific American, 233(1): 94-106, July, 1970.
- [12] Gaum, Carl G., et al, Report Writing, New Jersey: Prentice Hall Incorporated, 1950.

- [13] Gerringer, Paul L. and Goodfuaid, Morton J., "Potential Application of Nuclear Energy for Process and Space Heat in the United States," New York: American Hydrotherm Corporation, 1958 (NYO 2332).
- [14] Glasstone, Samuel and Sisonske, Alexander, Nuclear Reactor Engineering, New Jersey: D. Van Nostrand, Inc., 1963.
- [15] Godfrey, Robert S., editor, Building Construction Cost Data - 1962, Duxburg, Mass.: Robert Snow Means Co., 1963.
- [16] Govan, Francis A., High Temperature Water for Heating and Light Process Loads, Publication 753, Washington: National Academy of Sciences, National Research Council, 1959.
- [17] Hammond, S.B., Electrical Engineering, New York: McGraw-Hill Book Company, Inc., 1961.
- [18] Hendricks, James R., "Submarine Qualification Notebook," unpublished, 1968.
- [19] Jaske, R.T., "An Independent View of the Thermal Effects and Radioactive Pollution from Nuclear Power Plants." Clearinghouse for Federal Scientific and Technical Information, National Bureau of Standards, Springfield, Virginia, 1969.
- [20] McCabe, Warren, L. and Smith, Julian C., Unit Operations of Chemical Engineering, New York: McGraw-Hill Book Company, Inc., 1956.
- [21] Mead, William B., "Fight is on Against Thermal Pollution," Associated Press New Service, Rolla Daily News, Rolla, Missouri, September 28, 1970.
- [22] Miller, A.S., "Space Heating in Urban Environments," Clearinghouse for Federal Scientific and Technical Information, National Bureau of Standards, Springfield, Virginia, 1969.
- [23] Mittleman, Joseph, Circuit Theory Analysis, New York: Hayden Book Company, Inc., 1964.
- [24] Penman, H.L., "The Water Cycle," Scientific American, 233(3): 99-108, September, 1970.
- [25] Perry, John H., Editor, Chemical Engineering Handbook, Fourth Edition, New York: McGraw-Hill Book Company, Inc., 1963.
- [26] Peters, Max S., Plant Design and Economics for Chemical Engineers, New York: McGraw-Hill Book Company, Inc., 1958.
- [27] Sandstrom, S., "Operating Experience at the Agesta Nuclear Power Station," Artiebolajet Atomenergi, Stockholm, Sweden, September, 1966.

- [28] Siegel, Sideny, et al, "Application of Nuclear Energy to Large Scale Power and Desalting Plants," Engineering Design, 4(10): 225-232, October, 1966.
- [29] Tyler, Chaplin and Winter, C.H., Chemical Engineering Economics, Fourth Edition, New York: McGraw-Hill Book Company, Inc., 1959.
- [30] Wallace, Richard, Personnel Manager, Consumers Power Corporation, personal interview.
- [31] Wiostad, I., "ADAM - A 75 MW Nuclear Energy Plant for House Heating Purposes," paper presented at the Second United Nations International Conference on Peaceful Uses of the Atom, Sweden, June, 1958.
- [32] Underwood, G., Estimating Construction Costs, New York: McGraw-Hill Book Company, Inc., 1930.

IX. ACKNOWLEDGEMENTS

The author wishes to thank Dr. D. Ray Edwards for his assistance and continued encouragement in the preparation of this thesis. The financial assistance provided by the Atomic Energy Traineeship has been greatly appreciated. The author also wishes to acknowledge the efforts of Dr. Henry Wiebe, who suggested the format of the economic analysis. Mr. Daniel Smith assisted by testing the computer program on a sample problem. Finally, the author wishes to express his gratitude to the understanding and the efforts (both in proof reading and in other endeavors) of his wife, without whom this thesis would not be completed.

X. VITA

James Richard Hendricks was born on December 20, 1942 in Selinsgrove, Pennsylvania. After completing his high school education in Selinsgrove, he attended The Pennsylvania State University from 1960 until 1964, when he received a Bachelor of Science degree in Chemical Engineering.

He received a commission in the United States Navy in September, 1964. From 1964 until December, 1969, he served in the Naval Reactors Power Program, attaining the rank of Lieutenant and qualifying as Chief Engineer for Naval Nuclear Propulsion Plants.

Upon his resignation from the Naval Service, he entered the University of Missouri-Rolla in February, 1970. He has held an Atomic Energy Traineeship while enrolled at the University.

Mr. Hendricks is a member of the American Institute of Chemical Engineers and the American Nuclear Society. He is married and has one daughter, age five.

190865